



**Wajed Shah**

Drinking Water Officer  
Office of Drinking Water  
Environment and Climate Change  
Unit B – 284 Reimer Avenue  
Steinbach, MB R5G 0R5

February 18, 2026

Mr. Shah,

**Re: 2025 Kleefeld Public Water System Report**

Please find attached our annual Public Water System Report for the Community of Kleefeld.

This report will be posted on our website at [www.hanovermb.ca](http://www.hanovermb.ca) by March 31, 2026 and hard copies will be made available from our R.M.'s office at 28 Westland Drive in Mitchell, Manitoba. We will also notify residents that this report is available through our Facebook page.

If you have any questions or concerns, please contact Barry Broesky.

Sincerely,

A handwritten signature in black ink, appearing to read "Barry Broesky".

**Barry Broesky**

Manager of Utilities  
Phone: 204-371-0484  
E-Mail: [barry.broesky@hanovermb.ca](mailto:barry.broesky@hanovermb.ca)

**Kleefeld Public Water System  
Annual Report**

---

**2025**

Rural Municipality of Hanover  
February 19, 2026

# **Kleefeld Public Water System Annual Report 2025**

---

February 19, 2026

**Name of Public Water System:** Kleefeld Public Water System

**Name of legal owner:** The Rural Municipality of Hanover

**Contact:** Barry Broesky, Manager of Utilities  
Phone: (204) 371-0484  
E-Mail: [barry.broesky@hanovermb.ca](mailto:barry.broesky@hanovermb.ca)

**Website:** [www.hanovermb.ca](http://www.hanovermb.ca)

**Water Systems Emergency #:** (204) 326-4488

**Name of Operators:** Cliff Derksen, Utility Operator, Class I  
Phone: (204) 392-8285  
E-Mail: [cliff.derksen@hanovermb.ca](mailto:cliff.derksen@hanovermb.ca)

Mike Berg, Utility Operator, OIT  
Phone: (204) 381-2124  
E-Mail: [mike.berg@hanovermb.ca](mailto:mike.berg@hanovermb.ca)

# Table of Contents

---

## Introduction

- 1. Description of Water System**
  - 1.1 Water Supply Source
  - 1.2 Intake Structures
  - 1.3 Water Treatment Process
  - 1.4 Distribution System
  - 1.5 Storage Reservoirs
  - 1.6 Number of Connections, Population and Types of Water Users
  - 1.7 Classification and Certification
  
- 2. Disinfection System in Use**
  - 2.1 Types of disinfection system used
  - 2.2 Equipment redundancy and monitoring requirements
  - 2.3 Disinfectant residual overall performance results
  
- 3. List of Water Quality Standards**
  
- 4. Water System Failure and Corrective Actions**
  
- 5. Additional Records Required**
  
- 6. Drinking Water Safety Orders on your System and Actions Take in Response**
  
- 7. Warnings Issued or Charges Laid on the System in Accordance with Drinking water Safety Act**
  
- 8. Water Quality Advisories**
  
- 9. Major Expenses Incurred**
  
- 10. Future System Expansion and/or Increased Production**
  
- 11. Appendix**
  - a. Facility and Operators Certification
  - b. Testing Summary
  - c. Analyses
  - d. Operating License for Public Water System

- e. Monthly Disinfection Reports
- f. Incident Advisory Notification Plan

## **Introduction**

The 2025 Annual Report for the Town of Kleefeld summarizes the Water utility's ability to produce safe potable water and to meet Provincial regulations.

### **1. Description of Water System**

The Kleefeld Public Water System provides potable drinking water to approximately 2762 residents within the community. Treated water produced at the water plant meets all aesthetic objectives as set forth in the Guidelines for *Canadian Drinking Water Quality*.

#### **1.1 Water Supply Source**

The Kleefeld Public Water System receives groundwater from one main drilled well, as well as a back-up well. Both wells draw from a water source at roughly 170 to 180 feet below the ground surface. The main well in use at the time produces water at approximately 8.0 L/sec and this raw water is pumped to the water treatment plant reservoir. The raw water does contain some iron and manganese that it picks up in the rock aquifer.

#### **1.2 Intake Structures**

Not applicable.

#### **1.3 Water Treatment Process**

As the raw water enters the water treatment plant it is immediately treated with Chlorine and UV for disinfection along with Aqua Mag, which is an iron sequester which keeps any iron particles from settling out of the water causing staining in the piping. Once treated, the water is then stored in two reservoirs with a capacity of 790,000 litres, from where it can then be distributed throughout the watermain system.

#### **1.4 Distribution System**

Treated water from the reservoir is pumped through the mains into the distribution system via a 3hp jockey pump, 2-10hp duty pumps and a 30hp duty fire pump. The pumps distribute the water at pressures of around 60psi through 50mm, 100mm, 150mm, 200mm and 250mm watermains throughout the community. The watermains currently consists of either an AC or poly high density pipe construction.

#### **1.5 Storage Reservoirs**

As indicated above the storage in the reservoirs is 790,000 litres. Both reservoirs are constructed of concrete.

#### **1.6 Number of Connections, Population Served and Types of Water Users**

There are currently 691 water connections with an estimated population in the community of 2762 people.

### **1.7 Classification and Certification**

The Kleefeld Water Treatment Plant is classified as a Class 1 Water Treatment Facility and is currently operated by three utility operators with certification under the Environmental Act's Water and Wastewater Facility Operators Regulation. (See Appendix A – Operator Certification)

In addition the plant is regulated under license number PWS-21-655-01 and complies with The Drinking Water Safety Act.

## **2. Disinfection System in Use**

### **2.1 Type of Disinfection System Used**

The Kleefeld Public Water System disinfects by adding 12% sodium hypochlorite solution to the water via a chlorinator pump. This produces a monochloramination disinfection that is complimented by two Ultra Violet Reactors that were installed in the summer of 2020.

### **2.2 Equipment Redundancy and Monitoring Requirements**

As required by the *Drinking Water Safety Act*, the Kleefeld Public Water System ensures continuous disinfection as maintained at the plant by keeping stock of all spare parts required for the chlorinator. In addition, a complete spare chlorinator is kept at the plant.

Disinfectant residuals are monitored daily at the water treatment plant and periodically in the distribution system and recorded on the appropriate monitoring forms. Monthly monochloramine and UV report forms are sent to the regional Drinking Water Officer at the end of each month.

### **2.3 Disinfectant Residual Overall Performance Results**

For 2025, the Kleefeld Public Water System was compliant in the audited time period. 100% of the daily monochloramine residual tests taken in 2025 were over the 0.3 mg/L limit.

## **3. List of Water Quality Standards**

The Province of Manitoba has adopted a number of water quality standards from the *Guidelines for Canadian Drinking Water Quality*, developed by Health Canada. The parameters are health-based and they express the maximum acceptable concentration for a groundwater supply source. Concentration values in excess constitute a health-related issue and require corrective actions. The results for the Kleefeld Public Water System are summarized in the following table. It should be noted that the Barium test was taken from the mid-point of the distribution system, and the Nitrate- Nitrite sample from a dead end with in the distribution system, during 2025. The general chemistry results were taken in 2023.

Table : 1 Water Quality Results

SOURCE	PARAMETER	STANDARD	FREQUENCY	TEST RESULTS
<b>GROUND WATER</b>	Total Coliform	No TC	Bi-Weekly	100%
	E. Coli	No EC	Bi-Weekly	100%
	Monochloramine	A monochloramine residual of at least 0.3 mg/L at all times at any point in the distribution system	Daily	100%
	Ultraviolet Disinfection	95% of water produced per month is disinfected within validated conditions	Continuous monitoring of UV dosage for each operating UV unit	100%
	Barium	2.0 mg/l	One sample taken Quarterly at the mid-point in the distribution system each year	1.82
	Nitrate	45 mg/l	One sample taken during July or August every year at a dead end sampling location in the distribution system	<2.0
	Nitrite	3 mg/l		0.013

**Table : 2 Water Quality Results General Chemistry**

SOURCE	PARAMETER	STANDARD	FREQUENCY	TEST RESULTS
<b>GROUND WATER</b>	Arsenic	Less then or equal to 0.01 mg/L	One Raw and one treated sample done once every three years. (These results were taken Aug. 2023)	raw – 3.46 µg/L treated – 2.06 µg/L
	Benzene	Less then or equal to 0.005 mg/L		raw - <0.00050 mg/L
	Ethylbenzene	Less then or equal to 0.14 mg/L		raw - <0.00050 mg/L
	Fluoride	Less then or equal to 1.5 mg/L		raw - 0.307 mg/L treated - 0.299 mg/L
	Lead	Less then or equal to 0.005 mg/L in the water distribution system		raw -< 0.050 µg/L treated - <0.050 µg/L
	Manganese	Less then or equal to 0.12 mg/L		raw – 2.99 µg/L treated – 2.07 µg/L
	Trichloroethylene	Less then or equal to 0.005 mg/L		raw - <0.00050 mg/L
	Tetrachloroethylene	Less then or equal to 0.01 mg/L		raw - <0.00050 mg/L
	Toluene	Less then or equal to 0.06 mg/L		raw - <0.00050 mg/L
	Total Xylenes	Less then or equal to 0.09 mg/L		raw - <0.00050 mg/L
	Uranium	Less then or equal to 0.02 mg/L		raw - <0.000010 treated - <0.000010

**4. Water System Failures and Corrective Actions in 2025**

None

**5. Additional Records Required**

None

**6. Drinking Water Safety Order on your System and Actions Taken in Response**

None

**7. Warnings Issues or Charges Laid on the System in Accordance with the Drinking Water Safety Act**

None

**8. Water Quality Advisories**

None

**9. Major Expenses Incurred in 2025**

Installation of new truck fill station at Kleefeld WTP at a cost of \$50,000.00

**10. Future System Expansion and/or Increased Population**

In 2026, Second St and Third St will be getting watermain upgrades. Currently both streets have 50 mm water mains and they will be upgraded to 150 mm.

**11. Appendix**

- a. Operators Certification
- b. Testing Summary
- c. Analyses
- d. Operating License for Public Water System
- e. Monochloramine and UV Reports
- f. Incident Advisory Notification Plan
- g. Boil Water Documentation
- h. Construction Permits

# **Appendix A**

## **Operator Certification**

# Water and Wastewater Facility Operators Certification Program

This is to certify

*Barry A. Broesky*

has qualified as a

*Water Treatment*                      *Class II*

*Water Distribution*                      *Class II*

*Wastewater Treatment*                      *Class II*

*Wastewater Collection*                      *Class II*

**Operator**

in accordance with the Water and Wastewater Facility Operators Regulation under *The Environment Act*.

**Dated at**    Winnipeg, Manitoba                      **this**    7<sup>th</sup>                      **day of**    April 2020.

Certificate No.:    2009-312  
Expires:                      2025 April 7  
Operator ID:                      00107

*S. Kowlen*

Director

Manitoba Conservation and Climate

Certificate is the property of Manitoba Conservation and Climate and must be surrendered upon request.

**Manitoba** 

# Water and Wastewater Facility Operators Certification Program

This is to certify

*Clifford Derksen*

has qualified as a

<i>Water Treatment</i>	<i>Class I</i>
<i>Water Distribution</i>	<i>Class I</i>
<i>Wastewater Treatment</i>	<i>Class I</i>
<i>Wastewater Collection</i>	<i>Class I</i>

*Operator*

in accordance with the Water and Wastewater Facility Operators Regulation under *The Environment Act*.


Issued at Winnipeg, Manitoba this 15<sup>th</sup> day of December, 2025.

Certificate No.: 2025-338

Valid from: 2025 December 15 to: 2030 December 15

Operator ID: 04614

This Certificate repeals Certificate: 2025-046



Director

Manitoba Environment and Climate Change

Certificate is the property of Manitoba Environment and Climate Change and must be surrendered upon request.

**Manitoba** 

# Water and Wastewater Facility Operators Certification Program

This is to certify

*Mike Berg*

has qualified as a

<i>Water Treatment</i>	<i>Operator-In-Training</i>
<i>Water Distribution</i>	<i>Operator-In-Training</i>
<i>Wastewater Treatment</i>	<i>Operator-In-Training</i>
<i>Wastewater Collection</i>	<i>Operator-In-Training</i>
<i>Operator</i>	

in accordance with the Water and Wastewater Facility Operators Regulation under *The Environment Act*,

Issued at Winnipeg, Manitoba this 2<sup>nd</sup> day of February, 2026.

Certificate No.: 2026-018

Valid from: 2026 February 2 to: 2031 February 2

Operator ID: 04797



Director

Manitoba Environment and Climate Change

Certificate is the property of Manitoba Environment and Climate Change and must be surrendered upon request.

**Manitoba** 

# **Appendix B**

## **Testing Summary**

Duracan Kleffield Bacteria samplers

ID	Received Date	Site	Batch	Job #	Evaluation	Matrix	Sample Name	Sampling Date	Field Tests			Microbiological Tests	
									ammonia, free, field mg/L	Chlorine, mono, field mg/L	Chlorine, total, field mg/L	Coliforms, Escherichia coli (E. coli) MPN/100ml	Coliforms, total MPN/100ml
D15390	08-01-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	07-01-2025				<1	<1
D15390	08-01-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	07-01-2025				<1	<1
D15390	08-01-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN STREET	07-01-2025	0.00	7.93	4.7	<1	<1
D15998	22-01-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	21-01-2025				<1	<1
D15998	22-01-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	21-01-2025				<1	<1
D15998	22-01-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	21-01-2025	0.01	7.00	4.1	<1	<1
D16637	05-02-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	04-02-2025				<1	<1
D16637	05-02-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	06-02-2024				<1	<1
D16637	05-02-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN STREET	06-02-2024	0.00	2.82	4.3	<1	<1
D17340	19-02-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	18-02-2025				<1	<1
D17340	19-02-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	18-02-2025				<1	<1
D17340	19-02-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN STREET	18-02-2025	0.00	7.36	4.7	<1	<1
D18135	05-03-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	04-03-2025				<1	<1
D18135	05-03-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	04-03-2025				<1	<1
D18135	05-03-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	04-03-2025	0.05	5.11	3.7	<1	<1
D18797	19-03-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	18-03-2025				<1	<1
D18797	19-03-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	18-03-2025				<1	<1
D18797	19-03-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	18-03-2025	0.05	7.96	4.5	<1	<1
D19384	02-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	01-04-2025				<1	<1
D19384	02-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	01-04-2025				<1	<1
D19384	02-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	01-04-2025	0.00	7.58	4.0	<1	<1
D20050	16-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	15-04-2025				<1	<1
D20050	16-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	15-04-2025				<1	<1
D20050	16-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	15-04-2025	0.00	3.01	4.3	<1	<1
D20707	30-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	29-04-2025				<1	<1
D10987	30-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	29-04-2025				<1	<1
D10987	30-04-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	29-04-2025	0.00	2.83	4.4	<1	<1
D21798	14-05-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	13-05-2025				<1	<1
D21798	14-05-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	13-05-2025				<1	<1
D21798	14-05-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	13-05-2025	0.05	2.63	3.3	<1	<1
D23040	28-05-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	27-05-2025				<1	<1
D23040	28-05-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	27-05-2025				<1	<1
D23040	28-05-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	27-05-2025	0.00	2.79	4.4	<1	<1
D24008	11-06-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	10-06-2025				<1	<1
D24008	11-06-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	10-06-2025				<1	<1
D24008	11-06-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	10-06-2025	0.00	3.10	4.7	<1	<1
D25065	25-06-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	24-06-2025				<1	<1
D25065	25-06-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	24-06-2025				<1	<1
D25065	25-06-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	24-06-2025	0.00	2.88	4.8	<1	<1
D25945	09-07-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	08-07-2025				<1	<1
D25945	09-07-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	08-07-2025				<1	<1
D25945	09-07-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	08-07-2025	0.00	2.89	3.4	<1	<1
D26837	23-07-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	22-07-2025				<1	<1
D26837	23-07-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	22-07-2025				<1	<1
D26837	23-07-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	22-07-2025	0.06	1.76	2.0	<1	<1
D27807	06-08-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	05-08-2025				<1	<1
D27807	06-08-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	05-08-2025				<1	<1
D27807	06-08-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	05-08-2025	0.07	0.41	0.4	<1	<1
D28891	20-08-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	19-08-2025				<1	<1
D28891	20-08-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	19-08-2025				<1	<1
D28891	20-08-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	19-08-2025	0.22	2.31	3.0	<1	<1
D29903	03-09-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	03-09-2025				<1	<1
D29903	03-09-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	03-09-2025				<1	<1
D29903	03-09-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	03-09-2025	0.00	2.47	3.50	<1	<1
D30827	17-09-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	16-09-2025				<1	<1
D30827	17-09-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	16-09-2025				<1	<1
D30827	17-09-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	16-09-2025	0.00	2.04	4.3	<1	<1
D31708	02-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	01-10-2025				<1	<1
D31708	02-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	01-10-2025				<1	<1
D31708	02-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	01-10-2025	0.00	3.23	3.4	<1	<1
D32392	15-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	14-10-2025				<1	<1
D32392	15-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	14-10-2025				<1	<1
D32392	15-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	14-10-2025	0.00	2.80	4.1	<1	<1
D33096	29-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	28-10-2025				<1	<1
D33096	29-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	28-10-2025				<1	<1
D33096	29-10-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	28-10-2025	0.00	2.34	4.7	<1	<1
D33806	12-11-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	11-11-2025				<1	<1
D33806	12-11-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	11-11-2025				<1	<1
D33806	12-11-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	11-11-2025	0.00	2.91	3.7	<1	<1
D34689	26-11-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	25-11-2025				<1	<1
D34689	26-11-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	25-11-2025				<1	<1
D34689	26-11-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	25-11-2025	0.00	2.90	3.7	<1	<1
D35433	10-12-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	09-12-2025				<1	<1
D35433	10-12-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	09-12-2025				<1	<1
D35433	10-12-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	09-12-2025	0.00	2.98	3.9	<1	<1
D36104	23-12-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 1 - RAW	22-12-2025				<1	<1
D36104	23-12-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 2 - TREATED	22-12-2025				<1	<1
D36104	23-12-2025	104.00		104.00	Within Limit	Water/Drinking Water	KLEFFELD 3 - DISTRIBUTION @ MAIN ST	22-12-2025	0.00	3.12	4.1	<1	<1

# 2025 Lead Sampling Program

We initiated a lead monitoring program this year in accordance with direction from the Office of Drinking Water. Sampling was conducted at 20 locations throughout the community, and an additional 20 locations will be sampled next year. Please see the spreadsheet below for the results.

<b>2025 Residential Lead Monitoring Results- Kleeefeld Water System (104.00)</b>					
Sample #	Date	Address	Sampled By	Sample Type	Results
1	2025-07-08	15 Second St.	Operator	RDT	0.00137
2	2025-07-08	63 Third St.	Operator	RDT	0.000491
3	2025-07-08	31 Thlrd St.	Operator	RDT	0.000567
4	2025-07-08	48 Sceond St.	Operator	RDT	0.000166
5	2025-07-08	58 First St.	Operator	RDT	0.000706
6	2025-07-08	25 First St.	Operator	RDT	0.00421
7	2025-07-08	43 Barak Dr.	Operator	RDT	0.0037
8	2025-07-08	22 Lindsay Cove	Operator	RDT	0.000221
9	2025-07-08	60 Fourth St. N	Operator	RDT	0.00104
10	2025-07-08	32 Clara Cove	Operator	RDT	0.000593
11	2025-07-08	33 Ashley Cove	Operator	RDT	0.000572
12	2025-07-22	21 Main St.	Operator	RDT	0.00579
13	2025-08-07	21 Main St.	Operator	30 MS	0.00146 (Resample)
14	2025-07-22	117 Wesygrove Crescent	Operator	RDT	<0.000050
15	2025-07-22	52 Bramblewood St.	Operator	RDT	<0.000050
16	2025-07-22	82 Tanglewood Bay	Operator	RDT	0.00132
17	2025-07-22	24 Fourth St. N	Operator	RDT	0.000281
18	2025-07-22	69 Bergen Bay	Operator	RDT	0.0019
19	2025-07-22	60 Aspen Dr.	Operator	RDT	0.000417
20	2025-07-22	61 Fourth St. S	Operator	RDT	0.000143
21	2025-07-22	13 Beechwood St.	Operator	RDT	0.000219

# **Appendix C**

## **Analyses**

**CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)**

<b>Work Order</b>	: <b>WP2320500</b>	<b>Page</b>	: 1 of 6
<b>Client</b>	: <b>Manitoba Conservation &amp; Climate</b>	<b>Laboratory</b>	: ALS Environmental - Winnipeg
<b>Contact</b>	: Sarah Belisle	<b>Account Manager</b>	: Sheriza Rajack-Ahamed
<b>Address</b>	: 14 Fultz Boulevard Winnipeg MB Canada R3Y 0L6	<b>Address</b>	: 1329 Niakwa Road East, Unit 12 Winnipeg, Manitoba Canada R2J 3T4
<b>Telephone</b>	: 204 945 5776	<b>Telephone</b>	: +1 204 255 9720
<b>Project</b>	: 104.00	<b>Date Samples Received</b>	: 23-Aug-2023 10:09
<b>PO</b>	: ----	<b>Date Analysis Commenced</b>	: 23-Aug-2023
<b>C-O-C number</b>	: ----	<b>Issue Date</b>	: 30-Aug-2023 08:03
<b>Sampler</b>	: ----		
<b>Site</b>	: Kleefeld- PWS 104.00 Op Id: 7793		
<b>Quote number</b>	: WTP Chemistry		
<b>No. of samples received</b>	: 4		
<b>No. of samples analysed</b>	: 4		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Guideline Comparison

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

*Signatories*

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<u>Signatories</u>	<u>Position</u>	<u>Laboratory Department</u>
Gerry Vera	Analyst	Organics, Winnipeg, Manitoba
Lee McTavish		Inorganics, Winnipeg, Manitoba
Lee McTavish		Metals, Winnipeg, Manitoba
Matthew Bouch		Inorganics, Winnipeg, Manitoba



## No Breaches Found

### General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QC) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key : LOR: Limit of Reporting (detection limit).

Unit	Description
<	no units
%	percent
% T/cm	% transmittance per centimetre
µg/L	micrograms per litre
µS/cm	microsiemens per centimetre
AU/cm	absorbance units per centimetre
CU	colour units (1 cu = 1 mg/l pt)
meq/L	milliequivalents per litre
mg/L	milligrams per litre
NTU	nephelometric turbidity units
pH units	pH units

>: greater than.

<: less than.

Red shading is applied where the result or the LOR is greater than the Guideline Upper Limit (or lower than the Guideline Lower Limit, if applicable).

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.



**Analytical Results Evaluation**

Matrix: Water

Client sample ID

Sampling date/time

Sub-Matrix

				KLEEFELD 1 - RAW WELL 1	KLEEFELD 1 - RAW WELL 2 - BACKUP	KLEEFELD 2 - TREATED	KLEEFELD 3 - DISTRIBUTION MID-POINT 22 ASPEN BAY	****	****	****
				22-Aug-2023 09:45	22-Aug-2023 10:00	22-Aug-2023 10:15	22-Aug-2023 14:00	****	****	****
				Water	Water	Water	Water	****	****	****
Analyte	CAS Number	Method/Lab	Unit	WP2320500-001	WP2320500-002	WP2320500-003	WP2320500-004	****	****	****
<b>Physical Tests</b>										
Absorbance, UV (@ 254nm)	----	E404/WP		0.101	0.0890	0.104	----	****	****	****
Alkalinity, bicarbonate (as CaCO3)	----	E290/WP	mg/L	362	363	363	----	****	****	****
Alkalinity, carbonate (as CaCO3)	----	E290/WP		<1.0	<1.0	<1.0	----	****	****	****
Alkalinity, hydroxide (as CaCO3)	----	E290/WP	mg/L	<1.0	<1.0	<1.0	----	****	****	****
Alkalinity, total (as CaCO3)	----	E290/WP		362	363	363	----	****	****	****
Colour, true	----	E329/WP	CU	13.3	6.3	5.5	----	****	****	****
Conductivity	----	E100/WP		639	636	659	----	****	****	****
Hardness (as CaCO3), from total Ca/Mg	----	EC100A/WP	mg/L	317	322	316	----	****	****	****
Langelier index (@ 4°C)	----	EC105A/WP		0.474	0.484	0.547	----	****	****	****
Langelier index (@ 60°C)	----	EC105A/WP		1.24	1.25	1.31	----	****	****	****
pH	----	E108/WP		7.79	7.79	7.86	----	****	****	****
Solids, total dissolved [TDS]	----	E162-L/WP	mg/L	371	370	354	----	****	****	****
Turbidity	----	E121/WP		22.3	19.5	1.10	----	****	****	****
pH, saturation (@ 4°C)	----	EC105A/WP	pH units	7.32	7.30	7.31	----	****	****	****
Transmittance, UV (@ 254nm)	----	E404/WP		79.2	81.5	78.7	----	****	****	****
pH, saturation (@ 60°C)	----	EC105A/WP	pH units	6.55	6.54	6.55	----	****	****	****
<b>Anions and Nutrients</b>										
Ammonia, total (as N)	7664-41-7	E303/WP		1.20	1.12	0.638	----	****	****	****
Bromide	24959-67-9	E235.Br-L/WP	mg/L	<0.050	<0.050	<0.050	----	****	****	****
Chloride	16887-00-6	E235.Cl-L/WP		4.13	4.13	11.6	----	****	****	****
Fluoride	16984-48-8	E235.F/WP	mg/L	0.307	0.302	0.299	----	****	****	****
Nitrate (as N)	14797-55-8	E235.NO3-L/WP		<0.0050	<0.0050	0.0354	----	****	****	****
Nitrite (as N)	14797-65-0	E235.NO2-L/WP	mg/L	<0.0010	<0.0010	0.0159	----	****	****	****
Sulfate (as SO4)	14808-79-8	E235.SO4/WP		<0.30	<0.30	<0.30	----	****	****	****
<b>Organic / Inorganic Carbon</b>										
Carbon, dissolved organic [DOC]	----	E358-L/WP	mg/L	4.81	4.90	5.00	----	****	****	****



**Analytical Results Evaluation**

Matrix: Water

Client sample ID	KLEEFELD 1 - RAW WELL 1	KLEEFELD 1 - RAW WELL 2 - BACKUP	KLEEFELD 2 - TREATED	KLEEFELD 3 - DISTRIBUTION MID-POINT 22 ASPEN BAY			
Sampling date/time	22-Aug-2023 09:45	22-Aug-2023 10:00	22-Aug-2023 10:15	22-Aug-2023 14:00			
Sub-Matrix	Water	Water	Water	Water			

Analyte	CAS Number	Method/Lab	Unit	WP2320500-001	WP2320500-002	WP2320500-003	WP2320500-004			
<b>Organic / Inorganic Carbon</b>										
Carbon, total organic [TOC]		E355-L/WP		4.99	4.82	4.27				
<b>Ion Balance</b>										
Anion sum		EC101A/WP	meq/L	7.37	7.39	7.60				
Cation sum (total)		EC101A/WP		7.70	7.76	7.89				
Ion balance (cations/anions)		EC101A/WP	%	104	105	104				
Ion balance (APHA)		EC101A/WP		2.19	2.44	1.87				
<b>Total Metals</b>										
Aluminum, total	7429-90-5	E420/WP	µg/L	<3.0	123	<3.0	<3.0			
Antimony, total	7440-36-0	E420/WP		<0.10	<0.10	<0.10	<0.10			
Arsenic, total	7440-38-2	E420/WP	µg/L	3.46	3.66	2.06	1.40			
Barium, total	7440-39-3	E420/WP		2030	2040	1820	1850			
Beryllium, total	7440-41-7	E420/WP	µg/L	<0.020	<0.020	<0.020	<0.020			
Bismuth, total	7440-69-9	E420/WP		<0.050	<0.050	<0.050	<0.050			
Boron, total	7440-42-8	E420/WP	µg/L	143	144	149	144			
Cadmium, total	7440-43-9	E420/WP		<0.0050	<0.0050	<0.0050	<0.0050			
Calcium, total	7440-70-2	E420/WP	µg/L	65400	66800	65100	66100			
Cesium, total	7440-46-2	E420/WP		0.013	0.028	0.010	0.013			
Chromium, total	7440-47-3	E420/WP	µg/L	<0.50	1.87	<0.50	<0.50			
Cobalt, total	7440-48-4	E420/WP		<0.10	0.29	<0.10	<0.10			
Copper, total	7440-50-8	E420/WP	µg/L	<0.50	0.61	83.8	24.6			
Iron, total	7439-89-6	E420/WP		2040	2200	897	504			
Lead, total	7439-92-1	E420/WP	µg/L	<0.050	0.150	<0.050	0.222			
Lithium, total	7439-93-2	E420/WP		16.8	16.5	16.2	16.4			
Magnesium, total	7439-95-4	E420/WP	µg/L	37400	37800	37400	37200			
Manganese, total	7439-96-5	E420/WP		2.99	5.77	2.07	1.53			
Molybdenum, total	7439-98-7	E420/WP	µg/L	1.86	2.01	1.96	1.96			



**Analytical Results Evaluation**

Matrix: Water				Client sample ID				****	****	****
				KLEEFELD 1 - RAW WELL 1	KLEEFELD 1 - RAW WELL 2 - BACKUP	KLEEFELD 2 - TREATED	KLEEFELD 3 - DISTRIBUTION MID-POINT 22 ASPEN BAY			
Sub-Matrix				Sampling date/time				****	****	****
				22-Aug-2023 09:45	22-Aug-2023 10:00	22-Aug-2023 10:15	22-Aug-2023 14:00			
Sub-Matrix				Water	Water	Water	Water	****	****	****
Analyte	CAS Number	Method/Lab	Unit	WP2320500-001	WP2320500-002	WP2320500-003	WP2320500-004	****	****	****
<b>Total Metals</b>										
Nickel, total	7440-02-0	E420/WP		0.50	5.49	0.54	0.76	****	****	****
Phosphorus, total	7723-14-0	E420/WP	µg/L	1780	244	1440	849	****	****	****
Potassium, total	7440-09-7	E420/WP		4320	4390	4280	4300	****	****	****
Rubidium, total	7440-17-7	E420/WP	µg/L	3.23	3.36	2.95	3.12	****	****	****
Selenium, total	7782-49-2	E420/WP		0.073	0.074	0.122	0.051	****	****	****
Silicon, total	7440-21-3	E420/WP	µg/L	8110	8290	7980	8030	****	****	****
Silver, total	7440-22-4	E420/WP		<0.010	<0.010	<0.010	<0.010	****	****	****
Sodium, total	7440-23-5	E420/WP	µg/L	25200	23700	31600	32100	****	****	****
Strontium, total	7440-24-6	E420/WP		469	473	466	452	****	****	****
Sulfur, total	7704-34-9	E420/WP	µg/L	<500	<500	<500	<500	****	****	****
Tellurium, total	13494-80-9	E420/WP		<0.20	<0.20	<0.20	<0.20	****	****	****
Thallium, total	7440-28-0	E420/WP	µg/L	<0.010	<0.010	<0.010	<0.010	****	****	****
Thorium, total	7440-29-1	E420/WP		<0.10	<0.10	<0.10	<0.10	****	****	****
Tin, total	7440-31-5	E420/WP	µg/L	<0.10	<0.10	<0.10	0.16	****	****	****
Titanium, total	7440-32-6	E420/WP		<0.30	4.66	<0.30	<0.30	****	****	****
Tungsten, total	7440-33-7	E420/WP	µg/L	<0.10	<0.10	<0.10	<0.10	****	****	****
Uranium, total	7440-61-1	E420/WP		<0.010	0.017	<0.010	<0.010	****	****	****
Vanadium, total	7440-62-2	E420/WP	µg/L	<0.50	0.51	<0.50	<0.50	****	****	****
Zinc, total	7440-66-6	E420/WP		<3.0	59.3	4.3	7.0	****	****	****
Zirconium, total	7440-67-7	E420/WP	µg/L	<0.20	0.22	<0.20	<0.20	****	****	****
<b>Volatile Organic Compounds</b>										
Benzene	71-43-2	E611D/WP		<0.00050	<0.00050	****	****	****	****	****
Bromodichloromethane	75-27-4	E611D/WP	mg/L	<0.00050	<0.00050	****	****	****	****	****
Bromoform	75-25-2	E611D/WP		<0.00050	<0.00050	****	****	****	****	****
Chloroform	67-66-3	E611D/WP	mg/L	<0.00050	<0.00050	****	****	****	****	****
Dibromochloromethane	124-48-1	E611D/WP		<0.00050	<0.00050	****	****	****	****	****
Dichloromethane	75-09-2	E611D/WP	mg/L	<0.0010	<0.0010	****	****	****	****	****



**Analytical Results Evaluation**

				Client sample ID						
Matrix: Water				KLEEFELD 1 - RAW WELL 1	KLEEFELD 1 - RAW WELL 2 - BACKUP	KLEEFELD 2 - TREATED	KLEEFELD 3 - DISTRIBUTION MID-POINT 22 ASPEN BAY			
				Sampling date/time						
				Sub-Matrix						
Analyte	CAS Number	Method/Lab	Unit	WP2320500-001	WP2320500-002	WP2320500-003	WP2320500-004			
<b>Volatile Organic Compounds</b>										
Ethylbenzene	100-41-4	E611D/WP		<0.00050	<0.00050					
Methyl-tert-butyl ether [MTBE]	1634-04-4	E611D/WP	mg/L	<0.00050	<0.00050					
Tetrachloroethylene	127-18-4	E611D/WP		<0.00050	<0.00050					
Toluene	108-88-3	E611D/WP	mg/L	<0.00050	<0.00050					
Trichloroethane, 1,1,1-	71-55-6	E611D/WP		<0.00050	<0.00050					
Trichloroethane, 1,1,2-	79-00-5	E611D/WP	mg/L	<0.00050	<0.00050					
Trichloroethylene	79-01-6	E611D/WP		<0.00050	<0.00050					
Xylene, m+p-	179601-23-1	E611D/WP	mg/L	<0.00040	<0.00040					
Xylene, o-	95-47-6	E611D/WP		<0.00030	<0.00030					
Xylenes, total	1330-20-7	E611D/WP	mg/L	<0.00050	<0.00050					
BTEX, total	---	E611D/WP		<0.0010	<0.0010					
<b>Volatile Organic Compounds Surrogates</b>										
Bromofluorobenzene, 4-	460-00-4	E611D/WP	%	88.4	87.0					
Difluorobenzene, 1,4-	540-36-3	E611D/WP		105	104					

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

Key:

## QUALITY CONTROL INTERPRETIVE REPORT

<b>Work Order</b>	<b>: WP2320500</b>	<b>Page</b>	: 1 of 14
<b>Client</b>	: Manitoba Conservation & Climate	<b>Laboratory</b>	: ALS Environmental - Winnipeg
<b>Contact</b>	: Sarah Belisle	<b>Account Manager</b>	: Sheriza Rajack-Ahamed
<b>Address</b>	: 14 Fultz Boulevard Winnipeg MB Canada R3Y 0L6	<b>Address</b>	: 1329 Niakwa Road East, Unit 12 Winnipeg, Manitoba Canada R2J 3T4
<b>Telephone</b>	: -----	<b>Telephone</b>	: +1 204 255 9720
<b>Project</b>	: 104.00	<b>Date Samples Received</b>	: 23-Aug-2023 10:09
<b>PO</b>	: -----	<b>Issue Date</b>	: 30-Aug-2023 08:03
<b>C-O-C number</b>	: -----		
<b>Sampler</b>	: -----		
<b>Site</b>	: Kleefeld- PWS 104.00 Op Id: 7793		
<b>Quote number</b>	: WTP Chemistry		
<b>No. of samples received</b>	: 4		
<b>No. of samples analysed</b>	: 4		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

### Key

**Anonymous:** Refers to samples which are not part of this work order, but which formed part of the QC process lot.

**CAS Number:** Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

**DQO:** Data Quality Objective.

**LOR:** Limit of Reporting (detection limit)

**RPD:** Relative Percent Difference.

### **Workorder Comments**

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

### **Summary of Outliers**

#### **Outliers : Quality Control Samples**

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur.
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

#### **Outliers: Reference Material (RM) Samples**

- No Reference Material (RM) Sample outliers occur.

**Outliers : Analysis Holding Time Compliance (Breaches)**

- Analysis Holding Time Outliers exist - please see following pages for full details.

**Outliers : Frequency of Quality Control Samples**

- Quality Control Sample Frequency Outliers occur - please see following pages for full details.



## Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and /or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Water

Evaluation: \* = Holding time exceedance; ✓ = Within Holding Time

Analyte Group Container / Client Sample ID(s)	Method	Sampling Date	Extraction / Preparation				Analysis				
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval	
				Rec	Actual			Rec	Actual		
<b>Anions and Nutrients : Ammonia in Water by Colour</b>											
Amber glass total (sulfuric acid) KLEEFELD 1 - RAW WELL 1	E303	22-Aug-2023	24-Aug-2023	28 days	2 days	✓	24-Aug-2023	28 days	2 days	✓	
<b>Anions and Nutrients : Ammonia in Water by Colour</b>											
Amber glass total (sulfuric acid) KLEEFELD 1 - RAW WELL 2 - BACKUP	E303	22-Aug-2023	24-Aug-2023	28 days	2 days	✓	24-Aug-2023	28 days	2 days	✓	
<b>Anions and Nutrients : Ammonia in Water by Colour</b>											
Amber glass total (sulfuric acid) KLEEFELD 2 - TREATED	E303	22-Aug-2023	24-Aug-2023	28 days	2 days	✓	24-Aug-2023	28 days	2 days	✓	
<b>Anions and Nutrients : Bromide in Water by IC (Low Level)</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E235 Br-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Bromide in Water by IC (Low Level)</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E235 Br-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Bromide in Water by IC (Low Level)</b>											
HDPE KLEEFELD 2 - TREATED	E235 Br-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Chloride in Water by IC (Low Level)</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E235 Cl-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	



Matrix: **Water** Evaluation: \* = Holding time exceedance ; ✓ = Within Holding Time

Analyte Group Container / Client Sample ID(s)	Method	Sampling Date	Extraction / Preparation				Analysis				
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval	
				Rec	Actual			Rec	Actual		
<b>Anions and Nutrients : Chloride in Water by IC (Low Level)</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E235 Cl-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Chloride in Water by IC (Low Level)</b>											
HDPE KLEEFELD 2 - TREATED	E235 Cl-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Fluoride in Water by IC</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E235 F	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Fluoride in Water by IC</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E235 F	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Fluoride in Water by IC</b>											
HDPE KLEEFELD 2 - TREATED	E235 F	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Nitrate in Water by IC (Low Level)</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E235 NO3-L	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	
<b>Anions and Nutrients : Nitrate in Water by IC (Low Level)</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E235 NO3-L	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	
<b>Anions and Nutrients : Nitrate in Water by IC (Low Level)</b>											
HDPE KLEEFELD 2 - TREATED	E235 NO3-L	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	
<b>Anions and Nutrients : Nitrite in Water by IC (Low Level)</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E235 NO2-L	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	



Matrix: Water

Evaluation: \* = Holding time exceedance; ✓ = Within Holding Time

Analyte Group	Method	Sampling Date	Extraction / Preparation			Analysis					
			Preparation Date	Holding Times Rec	Actual	Eval	Analysis Date	Holding Times Rec	Actual	Eval	
<b>Anions and Nutrients : Nitrite in Water by IC (Low Level)</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E235 NO2-L	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	
<b>Anions and Nutrients : Nitrite in Water by IC (Low Level)</b>											
HDPE KLEEFELD 2 - TREATED	E235 NO2-L	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	
<b>Anions and Nutrients : Sulfate in Water by IC</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E235 SO4	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Sulfate in Water by IC</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E235 SO4	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Anions and Nutrients : Sulfate in Water by IC</b>											
HDPE KLEEFELD 2 - TREATED	E235 SO4	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Organic / Inorganic Carbon : Dissolved Organic Carbon by Combustion (Low Level)</b>											
Amber glass dissolved (lab preserved) KLEEFELD 1 - RAW WELL 1	E358-L	22-Aug-2023	24-Aug-2023	3 days	2 days	✓	25-Aug-2023	28 days	1 days	✓	
<b>Organic / Inorganic Carbon : Dissolved Organic Carbon by Combustion (Low Level)</b>											
Amber glass dissolved (lab preserved) KLEEFELD 1 - RAW WELL 2 - BACKUP	E358-L	22-Aug-2023	24-Aug-2023	3 days	2 days	✓	25-Aug-2023	28 days	1 days	✓	
<b>Organic / Inorganic Carbon : Dissolved Organic Carbon by Combustion (Low Level)</b>											
Amber glass dissolved (lab preserved) KLEEFELD 2 - TREATED	E358-L	22-Aug-2023	24-Aug-2023	3 days	2 days	✓	25-Aug-2023	28 days	1 days	✓	
<b>Organic / Inorganic Carbon : Total Organic Carbon (Non-Purgeable) by Combustion (Low Level)</b>											
Amber glass total (sulfuric acid) KLEEFELD 1 - RAW WELL 1	E355-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	



Matrix: Water Evaluation: \* = Holding time exceedance ; ✓ = Within Holding Time

Analyte Group	Method	Sampling Date	Extraction / Preparation				Analysis				
			Preparation Date	Holding Times Rec	Holding Times Actual	Eval	Analysis Date	Holding Times Rec	Holding Times Actual	Eval	
<b>Organic / Inorganic Carbon : Total Organic Carbon (Non-Purgeable) by Combustion (Low Level)</b>											
Amber glass total (sulfuric acid) KLEEFELD 1 - RAW WELL 2 - BACKUP	E355-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Organic / Inorganic Carbon : Total Organic Carbon (Non-Purgeable) by Combustion (Low Level)</b>											
Amber glass total (sulfuric acid) KLEEFELD 2 - TREATED	E355-L	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	
<b>Physical Tests : Alkalinity Species by Titration</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E290	22-Aug-2023	23-Aug-2023	14 days	1 days	✓	23-Aug-2023	14 days	1 days	✓	
<b>Physical Tests : Alkalinity Species by Titration</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E290	22-Aug-2023	23-Aug-2023	14 days	1 days	✓	23-Aug-2023	14 days	1 days	✓	
<b>Physical Tests : Alkalinity Species by Titration</b>											
HDPE KLEEFELD 2 - TREATED	E290	22-Aug-2023	23-Aug-2023	14 days	1 days	✓	23-Aug-2023	14 days	1 days	✓	
<b>Physical Tests : Colour (True) by Spectrometer (5 CU)</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E329	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	
<b>Physical Tests : Colour (True) by Spectrometer (5 CU)</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E329	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	
<b>Physical Tests : Colour (True) by Spectrometer (5 CU)</b>											
HDPE KLEEFELD 2 - TREATED	E329	22-Aug-2023	23-Aug-2023	3 days	1 days	✓	23-Aug-2023	3 days	1 days	✓	
<b>Physical Tests : Conductivity In Water</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E100	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓	



Matrix: Water Evaluation: \* = Holding time exceedance ; ✓ = Within Holding Time

Analyte Group	Method	Sampling Date	Extraction / Preparation				Analysis			
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval
Container / Client Sample ID(s)				Rec	Actual			Rec	Actual	
<b>Physical Tests : Conductivity in Water</b>										
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E100	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓
<b>Physical Tests : Conductivity in Water</b>										
HDPE KLEEFELD 2 - TREATED	E100	22-Aug-2023	23-Aug-2023	28 days	1 days	✓	23-Aug-2023	28 days	1 days	✓
<b>Physical Tests : pH by Meter</b>										
HDPE KLEEFELD 2 - TREATED	E108	22-Aug-2023	23-Aug-2023	0.25 hrs	32 hrs	* EHTR-FM	23-Aug-2023	0.25 hrs	32 hrs	* EHTR-FM
<b>Physical Tests : pH by Meter</b>										
HDPE KLEEFELD 1 - RAW WELL 1	E108	22-Aug-2023	23-Aug-2023	0.25 hrs	33 hrs	* EHTR-FM	23-Aug-2023	0.25 hrs	33 hrs	* EHTR-FM
<b>Physical Tests : pH by Meter</b>										
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E108	22-Aug-2023	23-Aug-2023	0.25 hrs	33 hrs	* EHTR-FM	23-Aug-2023	0.25 hrs	33 hrs	* EHTR-FM
<b>Physical Tests : TDS by Gravimetry (Low Level)</b>										
HDPE KLEEFELD 1 - RAW WELL 1	E162-L	22-Aug-2023	---	---	---		24-Aug-2023	7 days	2 days	✓
<b>Physical Tests : TDS by Gravimetry (Low Level)</b>										
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E162-L	22-Aug-2023	---	---	---		24-Aug-2023	7 days	2 days	✓
<b>Physical Tests : TDS by Gravimetry (Low Level)</b>										
HDPE KLEEFELD 2 - TREATED	E162-L	22-Aug-2023	---	---	---		24-Aug-2023	7 days	2 days	✓
<b>Physical Tests : Turbidity by Nephelometry</b>										
HDPE KLEEFELD 1 - RAW WELL 1	E121	22-Aug-2023	---	---	---		23-Aug-2023	3 days	1 days	✓



Matrix: Water Evaluation: ✖ = Holding time exceedance ; ✓ = Within Holding Time

Analyte Group	Method	Sampling Date	Extraction / Preparation				Analysis				
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval	
Container / Client Sample ID(s)				Rec	Actual			Rec	Actual		
<b>Physical Tests : Turbidity by Nephelometry</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E121	22-Aug-2023	----	----	----		23-Aug-2023	3 days	1 days	✓	
<b>Physical Tests : Turbidity by Nephelometry</b>											
HDPE KLEEFELD 2 - TREATED	E121	22-Aug-2023	----	----	----		23-Aug-2023	3 days	1 days	✓	
<b>Physical Tests : UV Absorbance and Transmittance by Spectrometry</b>											
HDPE KLEEFELD 1 - RAW WELL 1	E404	22-Aug-2023	----	----	----		23-Aug-2023	3 days	1 days	✓	
<b>Physical Tests : UV Absorbance and Transmittance by Spectrometry</b>											
HDPE KLEEFELD 1 - RAW WELL 2 - BACKUP	E404	22-Aug-2023	----	----	----		23-Aug-2023	3 days	1 days	✓	
<b>Physical Tests : UV Absorbance and Transmittance by Spectrometry</b>											
HDPE KLEEFELD 2 - TREATED	E404	22-Aug-2023	----	----	----		23-Aug-2023	3 days	1 days	✓	
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>											
HDPE total (nitric acid) KLEEFELD 1 - RAW WELL 1	E420	22-Aug-2023	25-Aug-2023	180 days	3 days	✓	25-Aug-2023	180 days	3 days	✓	
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>											
HDPE total (nitric acid) KLEEFELD 1 - RAW WELL 2 - BACKUP	E420	22-Aug-2023	25-Aug-2023	180 days	3 days	✓	25-Aug-2023	180 days	3 days	✓	
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>											
HDPE total (nitric acid) KLEEFELD 2 - TREATED	E420	22-Aug-2023	25-Aug-2023	180 days	3 days	✓	25-Aug-2023	180 days	3 days	✓	
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>											
HDPE total (nitric acid) KLEEFELD 3 - DISTRIBUTION MID-POINT 22 ASPEN BAY	E420	22-Aug-2023	25-Aug-2023	180 days	3 days	✓	25-Aug-2023	180 days	3 days	✓	



Matrix: Water

Evaluation: \* = Holding time exceedance ; ✓ = Within Holding Time

Analyte Group Container / Client Sample ID(s)	Method	Sampling Date	Extraction / Preparation				Analysis				
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval	
				Rec	Actual			Rec	Actual		
<b>Volatile Organic Compounds : VOCs (Eastern Canada List) by Headspace GC-MS</b>											
Glass vial (sodium bisulfate) KLEEFELD 1 - RAW WELL 1	E611D	22-Aug-2023	24-Aug-2023	14 days	2 days	✓	24-Aug-2023	14 days	2 days	✓	
<b>Volatile Organic Compounds : VOCs (Eastern Canada List) by Headspace GC-MS</b>											
Glass vial (sodium bisulfate) KLEEFELD 1 - RAW WELL 2 - BACKUP	E611D	22-Aug-2023	24-Aug-2023	14 days	2 days	✓	24-Aug-2023	14 days	2 days	✓	

**Legend & Qualifier Definitions**

EHTR-FM: Exceeded ALS recommended hold time prior to sample receipt. Field Measurement recommended  
Rec, HT: ALS recommended hold time (see units).



## Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Evaluation: ✖ = QC frequency outside specification, ✔ = QC frequency within specification.

Matrix: Water

Quality Control Sample Type	Method	QC Lot #	Count		Frequency (%)		Evaluation
			QC	Regular	Actual	Expected	
<b>Laboratory Duplicates (DUP)</b>							
Alkalinity Species by Titration	E290	1100911	1	10	10.0	5.0	✔
Ammonia in Water by Colour	E303	1101546	1	20	5.0	5.0	✔
Bromide in Water by IC (Low Level)	E235 Br-L	1099485	0	3	0.0	5.0	✖
Chloride in Water by IC (Low Level)	E235 Cl-L	1099481	1	18	5.5	5.0	✔
Colour (True) by Spectrometer (5 CU)	E329	1099662	1	10	10.0	5.0	✔
Conductivity in Water	E100	1100910	1	11	9.0	5.0	✔
Dissolved Organic Carbon by Combustion (Low Level)	E358-L	1100971	1	19	5.2	5.0	✔
Fluoride in Water by IC	E235 F	1099480	1	19	5.2	5.0	✔
Nitrate in Water by IC (Low Level)	E235 NO3-L	1099483	0	4	0.0	5.0	✖
Nitrite in Water by IC (Low Level)	E235 NO2-L	1099484	0	4	0.0	5.0	✖
pH by Meter	E108	1100912	1	11	9.0	5.0	✔
Sulfate in Water by IC	E235 SO4	1099482	1	18	5.5	5.0	✔
TDS by Gravimetry (Low Level)	E162-L	1099960	1	18	5.5	5.0	✔
Total Metals in Water by CRC ICPMS	E420	1103435	1	8	12.5	5.0	✔
Total Organic Carbon (Non-Purgeable) by Combustion (Low Level)	E355-L	1099628	1	10	10.0	5.0	✔
Turbidity by Nephelometry	E121	1099544	1	6	16.6	5.0	✔
UV Absorbance and Transmittance by Spectrometry	E404	1099673	1	17	5.8	5.0	✔
VOCs (Eastern Canada List) by Headspace GC-MS	E611D	1101590	1	11	9.0	5.0	✔
<b>Laboratory Control Samples (LCS)</b>							
Alkalinity Species by Titration	E290	1100911	1	10	10.0	5.0	✔
Ammonia in Water by Colour	E303	1101546	1	20	5.0	5.0	✔
Bromide in Water by IC (Low Level)	E235 Br-L	1099485	1	3	33.3	5.0	✔
Chloride in Water by IC (Low Level)	E235 Cl-L	1099481	1	18	5.5	5.0	✔
Colour (True) by Spectrometer (5 CU)	E329	1099662	1	10	10.0	5.0	✔
Conductivity in Water	E100	1100910	1	11	9.0	5.0	✔
Dissolved Organic Carbon by Combustion (Low Level)	E358-L	1100971	1	19	5.2	5.0	✔
Fluoride in Water by IC	E235 F	1099480	1	19	5.2	5.0	✔
Nitrate in Water by IC (Low Level)	E235 NO3-L	1099483	1	4	25.0	5.0	✔
Nitrite in Water by IC (Low Level)	E235 NO2-L	1099484	1	4	25.0	5.0	✔
pH by Meter	E108	1100912	1	11	9.0	5.0	✔
Sulfate in Water by IC	E235 SO4	1099482	1	18	5.5	5.0	✔
TDS by Gravimetry (Low Level)	E162-L	1099960	1	18	5.5	5.0	✔
Total Metals in Water by CRC ICPMS	E420	1103435	1	8	12.5	5.0	✔
Total Organic Carbon (Non-Purgeable) by Combustion (Low Level)	E355-L	1099628	1	10	10.0	5.0	✔
Turbidity by Nephelometry	E121	1099544	1	6	16.6	5.0	✔
UV Absorbance and Transmittance by Spectrometry	E404	1099673	1	17	5.8	5.0	✔



Matrix: Water

Evaluation: \* = QC frequency outside specification; ✓ = QC frequency within specification.

Quality Control Sample Type	Method	QC Lot #	Count		Frequency (%)			Evaluation
			QC	Regular	Actual	Expected		
<b>Analytical Methods</b>								
<b>Laboratory Control Samples (LCS) - Continued</b>								
VOCs (Eastern Canada List) by Headspace GC-MS	E611D	1101590	1	11	9.0	5.0	✓	
<b>Method Blanks (MB)</b>								
Alkalinity Species by Titration	E290	1100911	1	10	10.0	5.0	✓	
Ammonia in Water by Colour	E303	1101546	1	20	5.0	5.0	✓	
Bromide in Water by IC (Low Level)	E235 Br-L	1099485	1	3	33.3	5.0	✓	
Chloride in Water by IC (Low Level)	E235 Cl-L	1099481	1	18	5.5	5.0	✓	
Colour (True) by Spectrometer (5 CU)	E329	1099662	1	10	10.0	5.0	✓	
Conductivity in Water	E100	1100910	1	11	9.0	5.0	✓	
Dissolved Organic Carbon by Combustion (Low Level)	E358-L	1100971	1	19	5.2	5.0	✓	
Fluoride in Water by IC	E235 F	1099480	1	19	5.2	5.0	✓	
Nitrate in Water by IC (Low Level)	E235 NO3-L	1099483	1	4	25.0	5.0	✓	
Nitrite in Water by IC (Low Level)	E235 NO2-L	1099484	1	4	25.0	5.0	✓	
Sulfate in Water by IC	E235 SO4	1099482	1	18	5.5	5.0	✓	
TDS by Gravimetry (Low Level)	E162-L	1099960	1	18	5.5	5.0	✓	
Total Metals in Water by CRC ICPMS	E420	1103435	1	8	12.5	5.0	✓	
Total Organic Carbon (Non-Purgeable) by Combustion (Low Level)	E355-L	1099628	1	10	10.0	5.0	✓	
Turbidity by Nephelometry	E121	1099544	1	6	16.6	5.0	✓	
UV Absorbance and Transmittance by Spectrometry	E404	1099673	1	17	5.8	5.0	✓	
VOCs (Eastern Canada List) by Headspace GC-MS	E611D	1101590	1	11	9.0	5.0	✓	
<b>Matrix Spikes (MS)</b>								
Ammonia in Water by Colour	E303	1101546	1	20	5.0	5.0	✓	
Bromide in Water by IC (Low Level)	E235 Br-L	1099485	0	3	0.0	5.0	*✗	
Chloride in Water by IC (Low Level)	E235 Cl-L	1099481	1	18	5.5	5.0	✓	
Dissolved Organic Carbon by Combustion (Low Level)	E358-L	1100971	1	19	5.2	5.0	✓	
Fluoride in Water by IC	E235 F	1099480	1	19	5.2	5.0	✓	
Nitrate in Water by IC (Low Level)	E235 NO3-L	1099483	0	4	0.0	5.0	*✗	
Nitrite in Water by IC (Low Level)	E235 NO2-L	1099484	0	4	0.0	5.0	*✗	
Sulfate in Water by IC	E235 SO4	1099482	1	18	5.5	5.0	✓	
Total Metals in Water by CRC ICPMS	E420	1103435	1	8	12.5	5.0	✓	
Total Organic Carbon (Non-Purgeable) by Combustion (Low Level)	E355-L	1099628	1	10	10.0	5.0	✓	
VOCs (Eastern Canada List) by Headspace GC-MS	E611D	1101590	1	11	9.0	5.0	✓	



## Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Description
Conductivity in Water	E100 ALS Environmental - Winnipeg	Water	APHA 2510 (mod)	Conductivity also known as Electrical Conductivity (EC) or Specific Conductance, is measured by immersion of a conductivity cell with platinum electrodes into a water sample. Conductivity measurements are temperature-compensated to 25°C.
pH by Meter	E108 ALS Environmental - Winnipeg	Water	APHA 4500-H (mod)	pH is determined by potentiometric measurement with a pH electrode and is conducted at ambient laboratory temperature (normally 20 ± 5°C). For high accuracy test results pH should be measured in the field within the recommended 15 minute hold time.
Turbidity by Nephelometry	E121 ALS Environmental - Winnipeg	Water	APHA 2130 B (mod)	Turbidity is measured by the nephelometric method, by measuring the intensity of light scatter under defined conditions.
TDS by Gravimetry (Low Level)	E162-L ALS Environmental - Winnipeg	Water	APHA 2540 C (mod)	Total Dissolved Solids (TDS) are determined by filtering a sample through a glass fibre filter with evaporation of the filtrate at 180 ± 2°C for 16 hours or to constant weight with gravimetric measurement of the residue.
Bromide in Water by IC (Low Level)	E235 Br-L ALS Environmental - Winnipeg	Water	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.
Chloride in Water by IC (Low Level)	E235 Cl-L ALS Environmental - Winnipeg	Water	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.
Fluoride in Water by IC	E235.F ALS Environmental - Winnipeg	Water	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.
Nitrite in Water by IC (Low Level)	E235 NO2-L ALS Environmental - Winnipeg	Water	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.
Nitrate in Water by IC (Low Level)	E235 NO3-L ALS Environmental - Winnipeg	Water	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.
Sulfate in Water by IC	E235 SO4 ALS Environmental - Winnipeg	Water	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.



Analytical Methods	Method / Lab	Matrix	Method Reference	Method Description
Alkalinity Species by Titration	E290 ALS Environmental - Winnipeg	Water	APHA 2320 B (mod)	Total alkalinity is determined by potentiometric titration to a pH 4.5 endpoint. Bicarbonate, carbonate and hydroxide alkalinity are calculated from phenolphthalein alkalinity and total alkalinity values.
Ammonia in Water by Colour	E303 ALS Environmental - Winnipeg	Water	APHA 4500 NH3-NITROGEN (AMMONIA)	This analysis is carried out using procedures adapted from APHA Method 4500 NH3 "NITROGEN (AMMONIA)". Ammonia is determined using the automated phenate colourimetric method.
Colour (True) by Spectrometer (5 CU)	E329 ALS Environmental - Winnipeg	Water	APHA 2120 C (mod)	Colour (True Colour) is determined by filtering a sample through a 0.45 micron membrane filter followed by analysis of the filtrate using the platinum-cobalt colourimetric method. Colour measurements can be highly pH dependent, and apply to the pH of the sample as received (at time of testing) without pH adjustment.
Total Organic Carbon (Non-Purgeable) by Combustion (Low Level)	E355-L ALS Environmental - Winnipeg	Water	APHA 5310 B (mod)	Total Organic Carbon (Non-Purgeable), also known as NPOC (total), is a direct measurement of TOC after an acidified sample has been purged to remove inorganic carbon (IC). Analysis is by high temperature combustion with infrared detection of CO2. NPOC does not include volatile organic species that are purged off with IC. For samples where the majority of total carbon (TC) is comprised of IC (which is common), this method is more accurate and more reliable than the TOC by subtraction method (i.e. TC minus TIC).
Dissolved Organic Carbon by Combustion (Low Level)	E358-L ALS Environmental - Winnipeg	Water	APHA 5310 B (mod)	Dissolved Organic Carbon (Non-Purgeable), also known as NPOC (dissolved), is a direct measurement of DOC after a filtered (0.45 micron) sample has been acidified and purged to remove inorganic carbon (IC). Analysis is by high temperature combustion with infrared detection of CO2. NPOC does not include volatile organic species that are purged off with IC. For samples where the majority of DC (dissolved carbon) is comprised of IC (which is common) this method is more accurate and more reliable than the DOC by subtraction method (i.e. DC minus DIC).
UV Absorbance and Transmittance by Spectrometry	E400 ALS Environmental - Winnipeg	Water	APHA 5910 B (mod)	UV Absorbance is determined by first filtering a sample through a 0.45 micron filter, followed by UV absorbance measurement in a quartz cell at 254 nm. The analysis is carried out without pH adjustment.
Total Metals in Water by CRC ICPMS	E420 ALS Environmental - Winnipeg	Water	EPA 200.2/6020B (mod)	Water samples are digested with nitric and hydrochloric acids, and analyzed by Collision/Reaction Cell ICPMS.  Method Limitation (re Sulfur): Sulfide and volatile sulfur species may not be recovered by this method.
VOCs (Eisenher Canada List) by Headspace GC-MS	E611D ALS Environmental - Winnipeg	Water	EPA 8260D (mod)	Volatile Organic Compounds (VOCs) are analyzed by static headspace GC-MS. Samples are prepared in headspace vials and are heated and agitated on the headspace autosampler, causing VOCs to partition between the aqueous phase and the headspace in accordance with Henry's law.



Analytical Methods	Method / Lab	Matrix	Method Reference	Method Description
Hardness (Calculated) from Total Ca/Mg	EC100A ALS Environmental - Winnipeg	Water	APHA 2340B	'Hardness (as CaCO <sub>3</sub> ) from total Ca/Mg' is calculated from the sum of total Calcium and Magnesium concentrations, expressed in CaCO <sub>3</sub> equivalents. 'Total Hardness' refers to the sum of Calcium and Magnesium Hardness. Hardness is normally or preferentially calculated from dissolved Calcium and Magnesium concentrations, because it is a property of water due to dissolved divalent cations. Hardness from total Ca/Mg is normally comparable to Dissolved Hardness in non-turbid waters.
Ion Balance using Total Metals	EC101A ALS Environmental - Winnipeg	Water	APHA 1030E	Cation Sum (using total metals), Anion Sum, and Ion Balance are calculated based on guidance from APHA Standard Methods (1030E Checking Correctness of Analysis). Minor ions are included where data is present. Ion Balance cannot be calculated accurately for waters with very low electrical conductivity (EC).
Saturation Index using Laboratory pH (Ca-T)	EC105A ALS Environmental - Winnipeg	Water	APHA 2330B	Langelier index provides an indication of scale formation potential at a given pH and temperature, and is calculated as per APHA 2330B Saturation Index. Positive values indicate oversaturation with respect to CaCO <sub>3</sub> . Negative values indicate undersaturation of CaCO <sub>3</sub> . This calculation uses laboratory pH measurements and provides estimates of Langelier Index at temperatures of 4, 15, 20, 25, 66, and 77°C. Ryznar Stability Index is an alternative index used for scale formation and corrosion potential.

Preparation Methods	Method / Lab	Matrix	Method Reference	Method Description
Preparation for Ammonia	EP298 ALS Environmental - Winnipeg	Water		Sample preparation for Preserved Nutrients Water Quality Analysis.
Preparation for Total Organic Carbon by Combustion	EP355 ALS Environmental - Winnipeg	Water		Preparation for Total Organic Carbon by Combustion
Preparation for Dissolved Organic Carbon for Combustion	EP358 ALS Environmental - Winnipeg	Water	APHA 5310 B (mod)	Preparation for Dissolved Organic Carbon
VOCs Preparation for Headspace Analysis	EP581 ALS Environmental - Winnipeg	Water	EPA 5021A (mod)	Samples are prepared in headspace vials and are heated and agitated on the headspace autosampler. An aliquot of the headspace is then injected into the GC/MS-FID system.

**QUALITY CONTROL REPORT**

<b>Work Order</b>	<b>:WP2320500</b>	<b>Page</b>	<b>: 1 of 14</b>
<b>Client</b>	: Manitoba Conservation & Climate	<b>Laboratory</b>	: ALS Environmental - Winnipeg
<b>Contact</b>	: Sarah Bellisle	<b>Account Manager</b>	: Sheriza Rajack-Ahamed
<b>Address</b>	: 104.00 - Kleeefeld- PWS 28 Westland Drive Mitchell MB Canada R5G 2N9	<b>Address</b>	: 1329 Niakwa Road East, Unit 12 Winnipeg, Manitoba Canada R2J 3T4
<b>Telephone</b>	:	<b>Telephone</b>	: +1 204 255 9720
<b>Project</b>	: 104.00	<b>Date Samples Received</b>	: 23-Aug-2023 10:09
<b>PO</b>	: ----	<b>Date Analysis Commenced</b>	: 23-Aug-2023
<b>C-O-C number</b>	: ----	<b>Issue Date</b>	: 30-Aug-2023 08:03
<b>Sampler</b>	: ----		
<b>Site</b>	: Kleeefeld- PWS 104.00 Op Id: 7793		
<b>Quote number</b>	: WTP Chemistry		
<b>No. of samples received</b>	: 4		
<b>No. of samples analysed</b>	: 4		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full. This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives
- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

**Signatories**

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Gerry Vera	Analyst	Winnipeg Organics, Winnipeg, Manitoba
Lee McTavish		Winnipeg Inorganics, Winnipeg, Manitoba
Lee McTavish		Winnipeg Metals, Winnipeg, Manitoba
Matthew Bouch		Winnipeg Inorganics, Winnipeg, Manitoba



---

### General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key :

- Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.
- CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.
- DQO = Data Quality Objective.
- LOR = Limit of Reporting (detection limit).
- RPD = Relative Percent Difference
- # = Indicates a QC result that did not meet the ALS DQO.

---

### Workorder Comments

Holding times are displayed as "-" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references

---



### Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Water

Laboratory Duplicate (DUP) Report											
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
<b>Physical Tests (QC Lot: 1099544)</b>											
WP2320502-003	Anonymous	Turbidity	---	E121	0.10	NTU	1.48	1.33	10.7%	15%	---
<b>Physical Tests (QC Lot: 1099662)</b>											
WP2320448-001	Anonymous	Colour, true	---	E329	5.0	CU	24.3	25.1	0.8	Diff <2x LOR	---
<b>Physical Tests (QC Lot: 1099673)</b>											
WP2320256-001	Anonymous	Absorbance, UV (@ 254nm)	---	E404	0.0050	AU/cm	0.0560	0.0560	0.00%	20%	---
<b>Physical Tests (QC Lot: 1099960)</b>											
WP2320427-001	Anonymous	Solids, total dissolved [TDS]	---	E162-L	3.0	mg/L	317	316	0.158%	20%	---
<b>Physical Tests (QC Lot: 1100910)</b>											
WP2320427-001	Anonymous	Conductivity	---	E100	2.0	µS/cm	550	551	0.182%	10%	---
<b>Physical Tests (QC Lot: 1100911)</b>											
WP2320427-001	Anonymous	Alkalinity, total (as CaCO3)	---	E290	1.0	mg/L	343	348	1.39%	20%	---
<b>Physical Tests (QC Lot: 1100912)</b>											
WP2320427-001	Anonymous	pH	---	E108	0.10	pH units	8.49	8.48	0.118%	4%	---
<b>Anions and Nutrients (QC Lot: 1099480)</b>											
WP2320433-001	Anonymous	Fluoride	16984-48-8	E235 F	0.020	mg/L	0.078	0.077	0.0009	Diff <2x LOR	---
<b>Anions and Nutrients (QC Lot: 1099481)</b>											
WP2320433-001	Anonymous	Chloride	16887-00-6	E235 Cl-L	0.10	mg/L	1.94	1.90	2.57%	20%	---
<b>Anions and Nutrients (QC Lot: 1099482)</b>											
WP2320433-001	Anonymous	Sulfate (as SO4)	14808-79-8	E235 SO4	0.30	mg/L	10.2	10.2	0.203%	20%	---
<b>Anions and Nutrients (QC Lot: 1101546)</b>											
WP2320448-002	Anonymous	Ammonia, total (as N)	7664-41-7	E303	0.010	mg/L	<0.010	<0.010	0	Diff <2x LOR	---
<b>Organic / Inorganic Carbon (QC Lot: 1099628)</b>											
WP2320500-001	KLEEFELD 1 - RAW WELL 1	Carbon, total organic [TOC]	---	E355-L	0.50	mg/L	4.99	4.72	0.28	Diff <2x LOR	---
<b>Organic / Inorganic Carbon (QC Lot: 1100971)</b>											
WP2320502-001	Anonymous	Carbon, dissolved organic [DOC]	---	E358-L	0.50	mg/L	2.92	2.60	0.32	Diff <2x LOR	---
<b>Total Metals (QC Lot: 1103435)</b>											
WP2320448-003	Anonymous	Aluminum, total	7429-90-5	E420	0.0030	mg/L	<3.0 µg/L	<0.0030	0	Diff <2x LOR	---
		Antimony, total	7440-36-0	E420	0.00010	mg/L	<0.10 µg/L	<0.00010	0	Diff <2x LOR	---
		Arsenic, total	7440-38-2	E420	0.00010	mg/L	0.33 µg/L	0.00030	0.00003	Diff <2x LOR	---



Sub-Matrix: Water

Laboratory Duplicate (DUP) Report

Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
<b>Total Metals (QC Lot: 1103435) - continued</b>											
WP2320448-003	Anonymous	Barium, total	7440-39-3	E420	0.00010	mg/L	21.7 µg/L	0.0215	0.861%	20%	---
		Beryllium, total	7440-41-7	E420	0.000020	mg/L	<0.020 µg/L	<0.000020	0	Diff <2x LOR	---
		Bismuth, total	7440-69-9	E420	0.000050	mg/L	<0.050 µg/L	<0.000050	0	Diff <2x LOR	---
		Boron, total	7440-42-8	E420	0.010	mg/L	98 µg/L	0.094	0.004	Diff <2x LOR	---
		Cadmium, total	7440-43-9	E420	0.0000050	mg/L	0.0071 µg/L	0.0000058	0.0000013	Diff <2x LOR	---
		Calcium, total	7440-70-2	E420	0.050	mg/L	21100 µg/L	20.2	4.07%	20%	---
		Cesium, total	7440-46-2	E420	0.000010	mg/L	<0.010 µg/L	<0.000010	0	Diff <2x LOR	---
		Chromium, total	7440-47-3	E420	0.000050	mg/L	<0.50 µg/L	<0.000050	0	Diff <2x LOR	---
		Cobalt, total	7440-48-4	E420	0.00010	mg/L	<0.10 µg/L	<0.00010	0	Diff <2x LOR	---
		Copper, total	7440-50-8	E420	0.00050	mg/L	7.46 µg/L	0.00734	1.56%	20%	---
		Iron, total	7439-89-6	E420	0.010	mg/L	<10 µg/L	<0.010	0	Diff <2x LOR	---
		Lead, total	7439-92-1	E420	0.000050	mg/L	0.524 µg/L	0.000506	3.46%	20%	---
		Lithium, total	7439-93-2	E420	0.0010	mg/L	20.7 µg/L	0.0199	4.16%	20%	---
		Magnesium, total	7439-95-4	E420	0.0050	mg/L	12300 µg/L	12.0	2.62%	20%	---
		Manganese, total	7439-96-5	E420	0.00010	mg/L	4.78 µg/L	0.00465	2.69%	20%	---
		Molybdenum, total	7439-98-7	E420	0.000050	mg/L	0.095 µg/L	0.000093	0.000002	Diff <2x LOR	---
		Nickel, total	7440-02-0	E420	0.00050	mg/L	0.59 µg/L	0.00057	0.00002	Diff <2x LOR	---
		Phosphorus, total	7723-14-0	E420	0.050	mg/L	<50 µg/L	<0.050	0	Diff <2x LOR	---
		Potassium, total	7440-09-7	E420	0.050	mg/L	5010 µg/L	4.94	1.39%	20%	---
		Rubidium, total	7440-17-7	E420	0.00020	mg/L	1.30 µg/L	0.00114	0.00016	Diff <2x LOR	---
		Selenium, total	7782-49-2	E420	0.000050	mg/L	0.239 µg/L	0.000156	0.000083	Diff <2x LOR	---
		Silicon, total	7440-21-3	E420	0.10	mg/L	5620 µg/L	5.52	1.72%	20%	---
		Silver, total	7440-22-4	E420	0.000010	mg/L	<0.010 µg/L	<0.000010	0	Diff <2x LOR	---
		Sodium, total	7440-23-5	E420	0.050	mg/L	17500 µg/L	17.3	1.34%	20%	---
		Strontium, total	7440-24-6	E420	0.00020	mg/L	99.7 µg/L	0.0986	1.07%	20%	---
		Sulfur, total	7704-34-9	E420	0.50	mg/L	600 µg/L	<0.50	0.10	Diff <2x LOR	---
		Tellurium, total	13494-80-9	E420	0.00020	mg/L	<0.20 µg/L	<0.00020	0	Diff <2x LOR	---
		Thallium, total	7440-28-0	E420	0.000010	mg/L	<0.010 µg/L	<0.000010	0	Diff <2x LOR	---
		Thorium, total	7440-29-1	E420	0.00010	mg/L	<0.10 µg/L	<0.00010	0	Diff <2x LOR	---
		Tin, total	7440-31-5	E420	0.00010	mg/L	<0.10 µg/L	<0.00010	0	Diff <2x LOR	---
		Titanium, total	7440-32-6	E420	0.00030	mg/L	<0.30 µg/L	<0.00030	0	Diff <2x LOR	---
		Tungsten, total	7440-33-7	E420	0.00010	mg/L	<0.10 µg/L	<0.00010	0	Diff <2x LOR	---
		Uranium, total	7440-61-1	E420	0.000010	mg/L	0.061 µg/L	0.000062	0.000001	Diff <2x LOR	---
		Vanadium, total	7440-62-2	E420	0.00050	mg/L	1.32 µg/L	0.00131	0.00001	Diff <2x LOR	---



Sub-Matrix: Water

Sub-Matrix: Water					Laboratory Duplicate (DUP) Report						
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
<b>Total Metals (QC Lot: 1103435) - continued</b>											
WP2320548-001	Anonymous	Zinc, total	7440-66-6	E420	0.0030	mg/L	28.3 µg/L	0.0281	0.0002	Diff <2x LOR	---
		Zirconium, total	7440-67-7	E420	0.00020	mg/L	<0.20 µg/L	<0.00020	0	Diff <2x LOR	---
<b>Volatile Organic Compounds (QC Lot: 1101590)</b>											
WP2320256-001	Anonymous	Benzene	71-43-2	E611D	0.50	µg/L	<0.00050 mg/L	<0.50	0	Diff <2x LOR	---
		Bromodichloromethane	75-27-4	E611D	0.50	µg/L	<0.50	<0.50	0	Diff <2x LOR	---
		Bromoforn	75-25-2	E611D	0.50	µg/L	<0.50	<0.50	0	Diff <2x LOR	---
		Chloroform	67-66-3	E611D	0.50	µg/L	<0.50	<0.50	0	Diff <2x LOR	---
		Dibromochloromethane	124-48-1	E611D	0.50	µg/L	<0.50	<0.50	0	Diff <2x LOR	---
		Dichloromethane	75-09-2	E611D	1.0	µg/L	<0.0010 mg/L	<1.0	0	Diff <2x LOR	---
		Ethylbenzene	100-41-4	E611D	0.50	µg/L	<0.00050 mg/L	<0.50	0	Diff <2x LOR	---
		Methyl-tert-butyl ether [MTBE]	1634-04-4	E611D	0.50	µg/L	<0.00050 mg/L	<0.50	0	Diff <2x LOR	---
		Tetrachloroethylene	127-18-4	E611D	0.50	µg/L	<0.00050 mg/L	<0.50	0	Diff <2x LOR	---
		Toluene	108-88-3	E611D	0.50	µg/L	<0.00050 mg/L	<0.50	0	Diff <2x LOR	---
		Trichloroethane, 1,1,1-	71-55-6	E611D	0.50	µg/L	<0.00050 mg/L	<0.50	0	Diff <2x LOR	---
		Trichloroethane, 1,1,2-	79-00-5	E611D	0.50	µg/L	<0.00050 mg/L	<0.50	0	Diff <2x LOR	---
		Trichloroethylene	79-01-6	E611D	0.50	µg/L	<0.00050 mg/L	<0.50	0	Diff <2x LOR	---
		Xylene, m+p-	179601-23-1	E611D	0.40	µg/L	<0.00040 mg/L	<0.40	0	Diff <2x LOR	---
		Xylene, o-	95-47-6	E611D	0.30	µg/L	<0.00030 mg/L	<0.30	0	Diff <2x LOR	---



**Method Blank (MB) Report**

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
<b>Physical Tests (QCLot: 1099544)</b>						
Turbidity	---	E121	0.1	NTU	<0.10	---
<b>Physical Tests (QCLot: 1099662)</b>						
Colour, true	---	E329	5	CU	<5.0	---
<b>Physical Tests (QCLot: 1099673)</b>						
Absorbance, UV @ 254nm	---	E404	0.005	AU/cm	<0.0050	---
<b>Physical Tests (QCLot: 1099960)</b>						
Solids, total dissolved [TDS]	---	E162-L	3	mg/L	<3.0	---
<b>Physical Tests (QCLot: 1100910)</b>						
Conductivity	---	E100	1	µS/cm	<1.0	---
<b>Physical Tests (QCLot: 1100911)</b>						
Alkalinity, total (as CaCO3)	---	E290	1	mg/L	<1.0	---
<b>Anions and Nutrients (QCLot: 1099480)</b>						
Fluoride	16985-48-2	E735-F	0.02	mg/L	<0.020	---
<b>Anions and Nutrients (QCLot: 1099481)</b>						
Chloride	16887-00-0	E235-Cl-L	0.1	mg/L	<0.10	---
<b>Anions and Nutrients (QCLot: 1099482)</b>						
Sulfate (as SO4)	14808-79-8	E235-SO4	0.3	mg/L	<0.30	---
<b>Anions and Nutrients (QCLot: 1099483)</b>						
Nitrate (as N)	14797-55-8	E235-NO3-L	0.005	mg/L	<0.0050	---
<b>Anions and Nutrients (QCLot: 1099484)</b>						
Nitro (as N)	14797-65-0	E235-NO2-L	0.001	mg/L	<0.0010	---
<b>Anions and Nutrients (QCLot: 1099485)</b>						
Bromide	24959-67-9	E235-Br-L	0.05	mg/L	<0.050	---
<b>Anions and Nutrients (QCLot: 1101546)</b>						
Ammonia, total (as N)	7664-41-7	E303	0.01	mg/L	<0.010	---
<b>Organic / Inorganic Carbon (QCLot: 1099628)</b>						
Carbon, total organic [TOC]	---	E355-L	0.5	mg/L	<0.50	---
<b>Organic / Inorganic Carbon (QCLot: 1100971)</b>						
Carbon, dissolved organic [DOC]	---	E358-L	0.5	mg/L	<0.50	---
<b>Total Metals (QCLot: 1103435)</b>						
Aluminum, total	7429-90-5	E420	0.003	mg/L	<0.0030	---
Antimony, total	7440-36-0	E420	0.0001	mg/L	<0.00010	---



Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
<b>Total Metals (QCLo: 1103435) - continued</b>						
Arsenic, total	7440-38-2	E420	0.0001	mg/L	<0.00010	----
Barium, total	7440-39-3	E420	0.0001	mg/L	<0.00010	----
Beryllium, total	7440-41-7	E420	0.00002	mg/L	<0.000020	----
Bismuth, total	7440-69-9	E420	0.00005	mg/L	<0.000050	----
Boron, total	7440-42-8	E420	0.01	mg/L	<0.010	----
Cadmium, total	7440-43-9	E420	0.000005	mg/L	<0.0000050	----
Calcium, total	7440-70-2	E420	0.05	mg/L	<0.050	----
Cesium, total	7440-46-2	E420	0.00001	mg/L	<0.000010	----
Chromium, total	7440-47-3	E420	0.0005	mg/L	<0.00050	----
Cobalt, total	7440-48-4	E420	0.0001	mg/L	<0.00010	----
Copper, total	7440-50-8	E420	0.0005	mg/L	<0.00050	----
Iron, total	7439-89-6	E420	0.01	mg/L	<0.010	----
Lead, total	7439-92-1	E420	0.00005	mg/L	<0.000050	----
Lithium, total	7439-93-2	E420	0.001	mg/L	<0.0010	----
Magnesium, total	7439-95-4	E420	0.005	mg/L	<0.0050	----
Manganese, total	7439-96-5	E420	0.0001	mg/L	<0.00010	----
Molybdenum, total	7439-98-7	E420	0.00005	mg/L	<0.000050	----
Nickel, total	7440-02-0	E420	0.0005	mg/L	<0.00050	----
Phosphorus, total	7723-14-0	E420	0.05	mg/L	<0.050	----
Potassium, total	7440-09-7	E420	0.05	mg/L	<0.050	----
Rubidium, total	7440-17-7	E420	0.0002	mg/L	<0.00020	----
Selenium, total	7782-49-2	E420	0.00005	mg/L	<0.000050	----
Silicon, total	7440-21-3	E420	0.1	mg/L	<0.10	----
Silver, total	7440-22-4	E420	0.00001	mg/L	<0.000010	----
Sodium, total	7440-23-5	E420	0.05	mg/L	<0.050	----
Strontium, total	7440-24-6	E420	0.0002	mg/L	<0.00020	----
Sulfur, total	7704-34-9	E420	0.5	mg/L	<0.50	----
Tellurium, total	13494-80-9	E420	0.0002	mg/L	<0.00020	----
Thallium, total	7440-28-0	E420	0.00001	mg/L	<0.000010	----
Thorium, total	7440-29-1	E420	0.0001	mg/L	<0.00010	----
Tin, total	7440-31-5	E420	0.0001	mg/L	<0.00010	----
Titanium, total	7440-32-6	E420	0.0003	mg/L	<0.00030	----
Tungsten, total	7440-33-7	E420	0.0001	mg/L	<0.00010	----
Uranium, total	7440-61-1	E420	0.00001	mg/L	<0.000010	----
Vanadium, total	7440-62-2	E420	0.0005	mg/L	<0.00050	----



Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
<b>Total Metals (QCLot: 1103435) - continued</b>						
Zinc, total	7440-66-6	E420	0.003	mg/L	<0.0030	---
Zinc, total	7440-67-7	E420	0.0002	mg/L	<0.00020	---
<b>Volatile Organic Compounds (QCLot: 1101590)</b>						
Benzene	71-43-2	E611D	0.5	ug/L	<0.50	---
Bromodichloromethane	75-27-4	E611D	0.5	ug/L	<0.50	---
Bromoform	75-25-2	E611D	0.5	ug/L	<0.50	---
Chloroform	67-66-3	E611D	0.5	ug/L	<0.50	---
Dibromochloromethane	124-48-1	E611D	0.5	ug/L	<0.50	---
Dichloromethane	75-09-2	E611D	1	ug/L	<1.0	---
Ethylbenzene	100-41-4	E611D	0.5	ug/L	<0.50	---
Methyl-tert-butyl ether (MTBE)	1634-04-4	E611D	0.5	ug/L	<0.50	---
Tetrachloroethylene	127-18-4	E611D	0.5	ug/L	<0.50	---
Toluene	108-88-3	E611D	0.5	ug/L	<0.50	---
Trichloroethane 1,1,1-	71-55-6	E611D	0.5	ug/L	<0.50	---
Trichloroethane 1,1,2-	79-00-5	E611D	0.5	ug/L	<0.50	---
Trichloroethylene	79-01-6	E611D	0.5	ug/L	<0.50	---
Xylene, m+p-	179601-23-1	E611D	0.4	ug/L	<0.40	---
Xylene, o-	95-47-6	E611D	0.3	ug/L	<0.30	---



**Laboratory Control Sample (LCS) Report**

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Water

					Laboratory Control Sample (LCS) Report				
Analyte	CAS Number	Method	LOR	Unit	Spike	Recovery (%)	Recovery Limits (%)		Qualifier
					Concentration	LCS	Low	High	
<b>Physical Tests (QCLot: 1099544)</b>									
Turbidity	---	E121	0.1	NTU	200 NTU	103	85.0	115	---
<b>Physical Tests (QCLot: 1099662)</b>									
Colour, true	---	E329	5	CU	250 CU	98.4	85.0	115	---
<b>Physical Tests (QCLot: 1099673)</b>									
Absorbance, UV (@ 254nm)	---	E404	0.005	AU/cm	0.463 AU/cm	102	85.0	115	---
<b>Physical Tests (QCLot: 1099960)</b>									
Solids, total dissolved (TDS)	---	E162-L	3	mg/L	1000 mg/L	95.8	85.0	115	---
<b>Physical Tests (QCLot: 1100910)</b>									
Conductivity	---	E100	1	uS/cm	1412 uS/cm	101	90.0	110	---
<b>Physical Tests (QCLot: 1100911)</b>									
Alkalinity, total (as CaCO3)	---	E200	1	mg/L	100 mg/L	101	85.0	115	---
<b>Physical Tests (QCLot: 1100912)</b>									
pH	---	E108	---	pH units	7 pH units	100	98.0	102	---
<b>Anions and Nutrients (QCLot: 1099480)</b>									
Fluoride	16984-48-0	E235 F	0.02	mg/L	1 mg/L	102	90.0	110	---
<b>Anions and Nutrients (QCLot: 1099481)</b>									
Chloride	16887-00-6	E235 Cl-L	0.1	mg/L	100 mg/L	100	90.0	110	---
<b>Anions and Nutrients (QCLot: 1099482)</b>									
Sulfate (as SO4)	14808-79-0	E235 SO4	0.3	mg/L	100 mg/L	101	90.0	110	---
<b>Anions and Nutrients (QCLot: 1099483)</b>									
Nitrate (as N)	14797-55-8	E235 NO3-L	0.095	mg/L	2.5 mg/L	100	90.0	110	---
<b>Anions and Nutrients (QCLot: 1099484)</b>									
Nitrite (as N)	14797-65-0	E235 NO2-L	0.001	mg/L	0.5 mg/L	99.1	90.0	110	---
<b>Anions and Nutrients (QCLot: 1099485)</b>									
Bromide	21959-67-0	E235 Br-L	0.05	mg/L	0.5 mg/L	98.9	85.0	115	---
<b>Anions and Nutrients (QCLot: 1101546)</b>									
Ammonia, total (as N)	7864-41-7	E303	0.01	mg/L	0.25 mg/L	97.7	85.0	115	---
<b>Organic / Inorganic Carbon (QCLot: 1099628)</b>									
Carbon, total organic [TOC]	---	E359-L	0.5	mg/L	8.57 mg/L	102	80.0	120	---
<b>Organic / Inorganic Carbon (QCLot: 1100971)</b>									



Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Laboratory Control Sample (LCS) Report				Qualifier
					Spike	Recovery (%)	Recovery Limits (%)		
					Concentration	LCS	Low	High	
<b>Organic / Inorganic Carbon (QCLot: 1100971) - continued</b>									
Carbon, dissolved organic [DOC]		E398-L	0.5	mg/L	8.57 mg/L	101	80.0	120	
<b>Total Metals (QCLot: 1103435)</b>									
Aluminum, total	7429-90-5	E420	0.003	mg/L	2 mg/L	111	80.0	120	
Antimony, total	7440-36-0	E420	0.0001	mg/L	1 mg/L	113	80.0	120	
Arsenic, total	7440-38-2	E420	0.0001	mg/L	1 mg/L	113	80.0	120	
Barium, total	7440-39-3	E420	0.0001	mg/L	0.25 mg/L	114	80.0	120	
Beryllium, total	7440-41-7	E420	0.00002	mg/L	0.1 mg/L	106	80.0	120	
Bismuth, total	7440-69-9	E420	0.00005	mg/L	1 mg/L	111	80.0	120	
Boron, total	7440-42-8	E420	0.01	mg/L	1 mg/L	109	80.0	120	
Cadmium, total	7440-43-8	E420	0.000005	mg/L	0.1 mg/L	111	80.0	120	
Calcium, total	7440-70-2	E420	0.05	mg/L	50 mg/L	108	80.0	120	
Cesium, total	7440-46-2	E420	0.00001	mg/L	0.05 mg/L	108	80.0	120	
Chromium, total	7440-47-3	E420	0.0005	mg/L	0.25 mg/L	112	80.0	120	
Cobalt, total	7440-48-4	E420	0.0001	mg/L	0.25 mg/L	111	80.0	120	
Copper, total	7440-50-8	E420	0.0005	mg/L	0.25 mg/L	110	80.0	120	
Cyanide, total	7439-89-6	E420	0.01	mg/L	1 mg/L	102	80.0	120	
Lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	106	80.0	120	
Lithium, total	7439-93-2	E420	0.001	mg/L	0.25 mg/L	95.4	80.0	120	
Magnesium, total	7439-95-4	E420	0.005	mg/L	50 mg/L	113	80.0	120	
Manganese, total	7439-96-5	E420	0.0001	mg/L	0.25 mg/L	111	80.0	120	
Molybdenum, total	7439-98-7	E420	0.00005	mg/L	0.25 mg/L	111	80.0	120	
Nickel, total	7440-02-0	E420	0.0005	mg/L	0.5 mg/L	110	80.0	120	
Phosphorus, total	7723-14-0	E420	0.05	mg/L	10 mg/L	113	80.0	120	
Potassium, total	7440-09-7	E420	0.05	mg/L	50 mg/L	107	80.0	120	
Rubidium, total	7440-17-7	E420	0.0002	mg/L	0.1 mg/L	118	80.0	120	
Selenium, total	7782-49-2	E420	0.00005	mg/L	1 mg/L	106	80.0	120	
Silicon, total	7440-21-3	E420	0.1	mg/L	10 mg/L	105	80.0	120	
Silver, total	7440-22-4	E420	0.00001	mg/L	0.1 mg/L	101	80.0	120	
Sodium, total	7440-23-5	E420	0.05	mg/L	50 mg/L	106	80.0	120	
Strontium, total	7440-24-6	E420	0.0002	mg/L	0.25 mg/L	107	80.0	120	
Sulfur, total	7704-34-9	E420	0.5	mg/L	50 mg/L	107	80.0	120	
Tellurium, total	13494-80-9	E420	0.0002	mg/L	0.1 mg/L	107	80.0	120	
Thallium, total	7440-28-0	E420	0.00001	mg/L	1 mg/L	109	80.0	120	
Thorium, total	7440-29-1	E420	0.0001	mg/L	0.1 mg/L	103	80.0	120	
Tin, total	7440-31-5	E420	0.0001	mg/L	0.5 mg/L	111	80.0	120	



Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Laboratory Control Sample (LCS) Report				
					Spike	Recovery (%)	Recovery Limits (%)		Qualifier
					Concentration	LCS	Low	High	
<b>Total Metals (QCLot: 1103435) - continued</b>									
Titanium, total	7440-32-6	E420	0.0003	mg/L	0.25 mg/L	110	80.0	120	Pass
Tungsten, total	7440-33-7	E420	0.0001	mg/L	0.1 mg/L	109	80.0	120	Pass
Uranium, total	7440-61-1	E420	0.00001	mg/L	0.005 mg/L	106	80.0	120	Pass
Vanadium, total	7440-62-2	E420	0.0005	mg/L	0.5 mg/L	113	80.0	120	Pass
Zinc, total	7440-66-6	E420	0.003	mg/L	0.5 mg/L	110	80.0	120	Pass
Zirconium, total	7440-67-7	E420	0.0002	mg/L	0.1 mg/L	103	80.0	120	Pass
<b>Volatile Organic Compounds (QCLot: 1101590)</b>									
Benzene	71-43-2	E811D	0.5	µg/L	100 µg/L	89.6	70.0	130	Pass
Bromodichloromethane	75-27-4	E811D	0.5	µg/L	100 µg/L	80.5	70.0	130	Pass
Bromoform	75-25-2	E811D	0.5	µg/L	100 µg/L	75.9	70.0	130	Pass
Chloroform	67-66-3	E811D	0.5	µg/L	100 µg/L	86.6	70.0	130	Pass
Dibromochloromethane	124-48-1	E811D	0.5	µg/L	100 µg/L	78.6	70.0	130	Pass
Dichloromethane	75-09-2	E811D	1	µg/L	100 µg/L	82.2	70.0	130	Pass
Ethylbenzene	100-41-4	E811D	0.5	µg/L	100 µg/L	103	70.0	130	Pass
Methyl-tert-butyl ether (MTBE)	1634-04-4	E811D	0.5	µg/L	100 µg/L	102	70.0	130	Pass
Tetrachloroethylene	127-18-4	E811D	0.5	µg/L	100 µg/L	92.8	70.0	130	Pass
Toluene	108-88-3	E811D	0.5	µg/L	100 µg/L	97.2	70.0	130	Pass
Trichloroethane, 1,1,1-	71-55-6	E811D	0.5	µg/L	100 µg/L	94.9	70.0	130	Pass
Trichloroethane, 1,1,2-	79-00-5	E811D	0.5	µg/L	100 µg/L	85.6	70.0	130	Pass
Trichloroethylene	79-01-8	E811D	0.5	µg/L	100 µg/L	88.8	70.0	130	Pass
Xylene, m+p-	179601-23-1	E811D	0.4	µg/L	200 µg/L	105	70.0	130	Pass
Xylene, o-	95-47-9	E811D	0.3	µg/L	100 µg/L	93.1	70.0	130	Pass



**Matrix Spike (MS) Report**

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DOO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: Water

Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Matrix Spike (MS) Report					
					Spike		Recovery (%)	Recovery Limits (%)		Qualifier
					Concentration	Target	MS	Low	High	
<b>Anions and Nutrients (QCLot: 1099480)</b>										
WP2320433-001	Anonymous	Fluoride	16984-48-8	E235 F	103 mg/L	1 mg/L	103	75.0	125	---
<b>Anions and Nutrients (QCLot: 1099481)</b>										
WP2320433-001	Anonymous	Chloride	16887-00-6	E235 Cl L	101 mg/L	100 mg/L	101	75.0	125	---
<b>Anions and Nutrients (QCLot: 1099482)</b>										
WP2320433-001	Anonymous	Sulfate (as SO4)	14808-79-8	E235 SO4	99.6 mg/L	100 mg/L	99.6	75.0	125	---
<b>Anions and Nutrients (QCLot: 1101546)</b>										
WP2320448-002	Anonymous	Ammonia, total (as N)	7664-41-7	E303	0.214 mg/L	0.25 mg/L	85.8	75.0	125	---
<b>Organic / Inorganic Carbon (QCLot: 1099628)</b>										
WP2320500-002	KLEEFELD 1 - RAW WELL 2 - BACKUP	Carbon, total organic (TOC)	---	E355 L	4.98 mg/L	5 mg/L	97.5	70.0	130	---
<b>Organic / Inorganic Carbon (QCLot: 1100971)</b>										
WP2320502-002	Anonymous	Carbon, dissolved organic (DOC)	---	E358 L	5.10 mg/L	5 mg/L	102	70.0	130	---
<b>Total Metals (QCLot: 1103435)</b>										
WP2320548-003	Anonymous	Aluminum, total	7429-90-5	E420	0.199 mg/L	0.2 mg/L	99.7	70.0	130	---
		Antimony, total	7440-36-0	E420	0.0196 mg/L	0.02 mg/L	99.2	70.0	130	---
		Arsenic, total	7440-38-2	E420	0.0202 mg/L	0.02 mg/L	101	70.0	130	---
		Barium, total	7440-39-3	E420	ND mg/L	0.02 mg/L	ND	70.0	130	---
		Beryllium, total	7440-41-7	E420	0.0402 mg/L	0.04 mg/L	100	70.0	130	---
		Bismuth, total	7440-69-9	E420	0.0102 mg/L	0.01 mg/L	102	70.0	130	---
		Boron, total	7440-42-8	E420	0.102 mg/L	0.1 mg/L	102	70.0	130	---
		Cadmium, total	7440-43-9	E420	0.00398 mg/L	0.004 mg/L	99.6	70.0	130	---
		Calcium, total	7440-70-2	E420	ND mg/L	1 mg/L	ND	70.0	130	---
		Cesium, total	7440-46-2	E420	0.00986 mg/L	0.01 mg/L	98.6	70.0	130	---
		Chromium, total	7440-47-3	E420	0.0404 mg/L	0.04 mg/L	101	70.0	130	---
		Cobalt, total	7440-48-4	E420	0.0201 mg/L	0.02 mg/L	100	70.0	130	---
		Copper, total	7440-50-8	E420	0.0189 mg/L	0.02 mg/L	94.3	70.0	130	---
		Iron, total	7439-89-6	E420	2.09 mg/L	2 mg/L	105	70.0	130	---
		Lead, total	7439-92-1	E420	0.0198 mg/L	0.02 mg/L	99.0	70.0	130	---
		Lithium, total	7439-93-2	E420	0.0955 mg/L	0.1 mg/L	95.5	70.0	130	---
		Magnesium, total	7439-95-4	E420	ND mg/L	1 mg/L	ND	70.0	130	---



Sub-Matrix: Water

Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Matrix Spike (MS) Report					Qualifier
					Spike		Recovery (%)	Recovery Limits (%)		
					Concentration	Target	MS	Low	High	
<b>Total Metals (QCLot: 1103435) - continued</b>										
WP2320448-003	Anonymous	Manganese, total	7439-96-5	E420	0.0201 mg/L	0.02 mg/L	100	70.0	130	----
		Molybdenum, total	7439-98-7	E420	0.0208 mg/L	0.02 mg/L	104	70.0	130	----
		Nickel, total	7440-02-0	E420	0.0391 mg/L	0.04 mg/L	97.7	70.0	130	----
		Phosphorus, total	7723-14-0	E420	10.4 mg/L	10 mg/L	104	70.0	130	----
		Potassium, total	7440-09-7	E420	ND mg/L	4 mg/L	ND	70.0	130	----
		Rubidium, total	7440-17-7	E420	0.0204 mg/L	0.02 mg/L	102	70.0	130	----
		Selenium, total	7782-49-2	E420	0.0434 mg/L	0.04 mg/L	108	70.0	130	----
		Silicon, total	7440-21-3	E420	9.93 mg/L	10 mg/L	99.3	70.0	130	----
		Silver, total	7440-22-4	E420	0.00402 mg/L	0.004 mg/L	101	70.0	130	----
		Sodium, total	7440-23-5	E420	ND mg/L	2 mg/L	ND	70.0	130	----
		Strontium, total	7440-24-6	E420	ND mg/L	0.02 mg/L	ND	70.0	130	----
		Sulfur, total	7704-34-9	E420	20.5 mg/L	20 mg/L	103	70.0	130	----
		Tellurium, total	13494-80-9	E420	0.0388 mg/L	0.04 mg/L	97.0	70.0	130	----
		Thallium, total	7440-28-0	E420	0.00393 mg/L	0.004 mg/L	98.3	70.0	130	----
		Thorium, total	7440-29-1	E420	0.0201 mg/L	0.02 mg/L	101	70.0	130	----
		Tin, total	7440-31-5	E420	0.0202 mg/L	0.02 mg/L	101	70.0	130	----
		Titanium, total	7440-32-6	E420	0.0405 mg/L	0.04 mg/L	101	70.0	130	----
		Tungsten, total	7440-33-7	E420	0.0207 mg/L	0.02 mg/L	103	70.0	130	----
		Uranium, total	7440-61-1	E420	0.00398 mg/L	0.004 mg/L	99.5	70.0	130	----
		Vanadium, total	7440-62-2	E420	0.102 mg/L	0.1 mg/L	102	70.0	130	----
		Zinc, total	7440-66-6	E420	0.400 mg/L	0.4 mg/L	100.0	70.0	130	----
		Zirconium, total	7440-67-7	E420	0.0436 mg/L	0.04 mg/L	109	70.0	130	----
<b>Volatile Organic Compounds (QCLot: 1101590)</b>										
WP2320256-001	Anonymous	Benzene	71-43-2	E611D	92.6 µg/L	100 µg/L	92.6	60.0	140	----
		Bromodichloromethane	75-27-4	E611D	84.7 µg/L	100 µg/L	84.7	60.0	140	----
		Bromoform	75-25-2	E611D	79.0 µg/L	100 µg/L	79.0	60.0	140	----
		Chloroform	67-66-3	E611D	89.1 µg/L	100 µg/L	89.1	60.0	140	----
		Dibromochloromethane	124-48-1	E611D	82.1 µg/L	100 µg/L	82.1	60.0	140	----
		Dichloromethane	75-09-2	E611D	85.4 µg/L	100 µg/L	85.4	60.0	140	----
		Ethylbenzene	100-41-4	E611D	104 µg/L	100 µg/L	104	60.0	140	----
		Methyl-tert-butyl ether [MTBE]	1634-04-4	E611D	103 µg/L	100 µg/L	103	60.0	140	----
		Tetrachloroethylene	127-18-4	E611D	91.0 µg/L	100 µg/L	91.0	60.0	140	----
		Toluene	108-88-3	E611D	96.9 µg/L	100 µg/L	96.9	60.0	140	----
		Trichloroethane, 1,1,1-	71-55-6	E611D	96.8 µg/L	100 µg/L	96.8	60.0	140	----
		Trichloroethane, 1,1,2-	79-00-5	E611D	88.7 µg/L	100 µg/L	88.7	60.0	140	----



Sub-Matrix: Water

					Matrix Spike (MS) Report					
					Spike		Recovery (%)	Recovery Limits (%)		
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier
<b>Volatile Organic Compounds (QCLo: 1101590) - continued</b>										
WP2320256-001	Anonymous	Trichloroethylene	79-01-6	E611D	90.7 µg/L	100 µg/L	90.7	60.0	140	---
		Xylene, m+p-	179601-23-1	E611D	210 µg/L	200 µg/L	105	60.0	140	---
		Xylene, o-	95-47-6	E611D	94.7 µg/L	100 µg/L	94.7	60.0	140	---



Environment, Climate and Parks  
Office of Drinking Water  
1007 Century Street, Winnipeg, Manitoba,  
Canada R3H 0W4

Chain of Custody (COC)  
Manitoba Drinking Water Systems

Regular Service (default):	<input type="checkbox"/> Regular Service (is 5-7 Days):
Unless otherwise requested	<input checked="" type="checkbox"/> 1 Day, rush / priority
	<input checked="" type="checkbox"/> 2 Day, rush / priority
	<input checked="" type="checkbox"/> 3 Day, rush / priority

**Report to Operator (email PDF):**  
Contact: Barry Broesky  
Address: 28 Westland Drive, Mitchell, MB R5G 2N9  
Phone: (204) 371-0484  
Email: barry.broesky@hanovermb.ca;  
rob.driedger@hanovermb.ca;  
rob.friesen@hanovermb.ca

**Report to Owner (email PDF):**  
Contact: Rob Driedger  
Address: 28 Westland Drive, Mitchell, MB R5G 2N9  
Phone: (204) 346-7121  
Email: rob.driedger@hanovermb.ca

**Email PDF copy to:**  
DWO: Sarah Belisle  
DWO Address: Unit B-284 Reimer Ave., Steinbach, MB R5G  
DWO Phone: (204) 371-5065  
DWO Email: Sarah.Belisle@gov.mb.ca  
Additional Email: Joern.Muenster@gov.mb.ca;  
Melanie.Betsill@gov.mb.ca;

**If an update in Owner or Operator contact information is required, please contact your Drinking Water Officer**

<b>Client / Project Information:</b>	<b>Lab:</b>	<b>Account:</b>	<b>Agency Code:</b> 382	<b>Report Type:</b> EMS (Lab-MWS)	<b>Project:</b> DWQ-C
Operation Name: KLEEFELD - PWS			Expected Sample Time:	<b>February-2023</b>	
Operation Code: 104.00					
Operation ID: 7793					
Sampled by: <i>Robert...</i>					

**Please record Free & Total Chlorine residuals for Distribution By-product Sampling**  
**DO NOT COPY or RE-USE this form. Sample Number are unique to the Office of Drinking Water**  
**and provided by Drinking Water Officer.**

Sample Number	Station Number	Sample Identification	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Sample Date dd-mmm-yyyy	Sample Time hh:mm	Sample Matrix	Sample Type	MB-VOC-PWS-V2013	MB-MET-1-CCMS	MB-VOC-PWS-V2013	# of Containers
2302SB5005	MB05OED031	Kleefeld 1 - Raw Well 1			22-Aug-2023	9:45	6	1	X		X	6
2302SB5006	MB05OED031	Kleefeld 1 - Raw Well 2 - backup			22-Aug-2023	10:00	6	1	X		X	6
2302SB5007	MB05OED032	Kleefeld 2 - Treated			22-Aug-2023	10:15	10	1	X			4
2302SB5008	MB05OED033	Kleefeld 3 - Distribution mid-point <i>22 Aspen way</i>	1.30	5.1	22-Aug-2023	2:00	9	1		X		1

**Failure to complete all portions of this form may delay analysis.**  
**Please fill in this form LEGIBLY.**

By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified by the Laboratory.  
For ALL other testing, please use Laboratory specific forms.

Relinquished By:	Date & Time:	Validated By (lab use only):	Date & Time:
Received By: (lab use only)	Date & Time: (lab use only)	Temperature	Samples Received in Good Condition
	<i>10:00</i>	<i>15.6</i>	

Environmental Division  
Winnipeg  
Work Order Reference  
**WP2320500**



Telephone: +1 204 255 9720

# **Appendix D**

## **Operating License for Public Water System**

**OPERATING LICENCE FOR  
A PUBLIC WATER SYSTEM**

**LICENCE NUMBER: PWS-21-655-01**

**THE DRINKING WATER SAFETY ACT  
CHAPTER D101, C.C.S.M.**

**WATER SYSTEM CODE: 104.00**  
**OPERATION ID: 7793**  
**EFFECTIVE DATE: JUNE 1, 2023**  
**EXPIRY DATE: MAY 31, 2028**

IN ACCORDANCE WITH THE DRINKING WATER SAFETY ACT, THIS OPERATING LICENCE IS ISSUED PURSUANT TO SUBSECTION 8(1) TO:

**RURAL MUNICIPALITY OF HANOVER: "THE LICENSEE"**

FOR THE OPERATION OF THE **KLEEFELD PUBLIC WATER SYSTEM**, WHICH INCLUDES SECURE WELLS, TREATMENT FACILITIES, WATER STORAGE RESERVOIRS, AND DISTRIBUTION LINES, SUBJECT TO THE ATTACHED TERMS AND CONDITIONS.

THIS LICENCE DOES NOT AFFECT THE LICENSEE'S OBLIGATIONS WITH RESPECT TO COMPLIANCE WITH ALL APPLICABLE MUNICIPAL, PROVINCIAL, AND FEDERAL LEGISLATION. THIS LICENCE SUPERSEDES ALL PREVIOUS LICENCES FOR THIS PUBLIC WATER SYSTEM.

DATE: October 31, 2023

  
Digitally signed  
by Sacha Janzen  
Date: 2023.10.31  
11:34:32 -05'00'

**Sacha Janzen**  
A/Director, Office of Drinking Water

## TERMS AND CONDITIONS

### 1. GENERAL

- 1.1. The Licensee shall operate the public water system in accordance with all applicable requirements of The Drinking Water Safety Act and its regulations, and the requirements of this licence. In the event that specific terms and conditions of this licence imposed under the authority of subsection 8(3) of the Act exceed the general requirements of the Act and regulations, the specific requirements of this licence shall apply.
- 1.2. The Licensee shall obtain approval from the Office of Drinking Water prior to making any significant alterations to the water source, the water treatment process, the water storage facilities, or the water distribution system.
- 1.3. This licence may be amended by the director where, in the opinion of the director, an amendment is necessary and the amendment will not negatively impact the safety of water obtained from the water system, or effective environmental management.
- 1.4. The Licensee may request an amendment to this licence by submitting an amendment application to the Office of Drinking Water.
- 1.5. This licence may be suspended or cancelled by the director for any of the reasons identified in Section 11 of Manitoba Regulation 40/2007, Drinking Water Safety Regulation or due to a failure to comply with any term or condition of this licence.
- 1.6. The Licensee shall provide written notice to the Office of Drinking Water of any change in ownership of the water system within seven days of the transfer of ownership.
- 1.7. The Licensee shall provide written notice to the Office of Drinking Water of any changes in the operational status of the water system, such as a permanent cessation of service, or changing the length of service from year-round to seasonal or the opposite.
- 1.8. The director of the Office of Drinking Water, medical officer of health or drinking water officer may enter any water system facility as necessary to carry out the provisions of The Drinking Water Safety Act and its regulations.
- 1.9. The Licensee shall post a copy of the first page of this licence at the water treatment facility.
- 1.10. The Licensee shall keep a copy of this licence in its entirety at a location established by the drinking water officer and ensure all operators are familiar with its terms and conditions.
- 1.11. The Licensee shall apply for renewal of this licence at least 60 days prior to its expiry.

## **2. OPERATION - GENERAL**

- 2.1. The Licensee shall operate all water system facilities, control systems, equipment, any reservoirs/cisterns and/or distribution lines as efficiently as possible, inspect them on a regular basis, maintain them in good working order, and ensure that the water system is protected from the risks associated with contamination.
- 2.2. The Licensee shall ensure that all chemicals and components that may come into contact with potable water are certified safe for potable water use through AWWA Standards, ANSI/NSF Standard 60 or 61, Health Canada, or other standards acceptable to the director.
- 2.3. No alternate water source shall be brought into service without the consent of the drinking water officer and the maintenance of adequate cross connection control between the alternate source and the primary source.
- 2.4. The Licensee shall follow the requirements as specified in *Operational Guideline ODW-OG-02 Seasonal Water Systems Start-up Shut-down Procedures* for any portion(s) of the distribution system that operate on a seasonal basis.
- 2.5. The Licensee shall have re-assessments of the water system infrastructure and water supply sources completed by a qualified person, who is not an employee of the water system, in accordance with assessment checklist GW by March 1, 2021, and every five years thereafter. The Licensee may instead have the assessment completed by a qualified professional engineer, who is not an employee of the water system, in accordance with terms of reference for engineering assessments.
- 2.6. The Licensee shall, upon request from the Office of Drinking Water, submit or re-submit a compliance plan, in a form satisfactory to the director, to address any non-compliance issues identified at the time.

## **3. OPERATION – EMERGENCIES**

- 3.1. The Licensee shall ensure that disinfection is undertaken following construction, repair or maintenance activities on the water system, in accordance with applicable AWWA standards, or Manitoba Water Services Board specifications, or any other standards approved by the director. A copy of all associated test results must be kept available for review by the Office of Drinking Water for a minimum of 24 months.
- 3.2. The Licensee shall ensure that all equipment used for disinfection is maintained in effective working order and keep available for immediate use all spare parts and chemical supplies as may be necessary to ensure continuous disinfection, including a spare disinfection unit, if necessary.
- 3.3. The Licensee shall immediately notify the Office of Drinking Water of any condition that may affect the ability of the water system to produce or deliver safe drinking water including but not limited to treatment upsets or bypass conditions, contamination of the source water or treated water, a disinfection system failure, or a distribution system failure.
- 3.4. If a medical officer of health, the director of the Office of Drinking Water, or a drinking water officer issues a water advisory on the water system, the Licensee shall provide notice of the advisory to all water users in accordance with the advisory notification plan or by a method acceptable to the issuer.

#### 4. WATER QUALITY/TREATMENT STANDARDS

- 4.1. The Licensee shall operate the water system in a manner that achieves the water quality/treatment standards specified in Table 1, as determined through the monitoring requirements specified in Table 2:

Table 1: Water Quality/Treatment Standards

Parameter	Quality Standard
Total coliform	Less than one total coliform bacteria detectable per 100 mL in all treated and distributed water
<i>E. coli</i>	Less than one <i>E. coli</i> bacteria detectable per 100 mL in all treated and distributed water
Ultraviolet Disinfection	95% of water produced per month is disinfected within validated conditions
Monochloramine	A monochloramine residual of at least 0.3 mg/L at all times at any point in the water distribution system
Arsenic	Less than or equal to 0.01 mg/L
Barium	Less than or equal to 2.0 mg/L
Benzene	Less than or equal to 0.005 mg/L
Ethylbenzene	Less than or equal to 0.14 mg/L
Fluoride	Less than or equal to 1.5 mg/L
Lead	Less than or equal to 0.005 mg/L based on a sample(s) collected at a cold water tap or other appropriate location where water may be used for drinking or food preparation
Manganese	Less than or equal to 0.12 mg/L
Nitrate	Less than or equal to 45 mg/L measured as nitrate (10 mg/L measured as nitrogen)
Nitrite	Less than or equal to 3 mg/L measured as nitrite (1 mg/L measured as nitrogen)
Trichloroethylene	Less than or equal to 0.005 mg/L
Tetrachloroethylene	Less than or equal to 0.01 mg/L
Toluene	Less than or equal to 0.06 mg/L
Total Xylenes	Less than or equal to 0.09 mg/L
Uranium	Less than or equal to 0.02 mg/L

- 4.2. If a bacteriological standard is not met, the Licensee shall immediately undertake the applicable corrective actions as listed in "Schedule A" of Manitoba Regulation 41/2007, Drinking Water Quality Standards Regulation.
- 4.3. If a microbial, chemical, radiological, or physical standard is not met, the Licensee shall immediately undertake the applicable corrective actions specified in "Schedule C" of Manitoba Regulation 41/2007, the Drinking Water Quality Standards Regulation.
- 4.4. The Licensee shall maintain in effective working order ultraviolet (UV) light disinfection equipment and controls for primary disinfection that result in greater than or equal to 95% of the water produced per month undergoing UV light disinfection within validated conditions and at a minimum dose of 40 mJ/cm<sup>2</sup>.

## 5. WATER QUALITY MONITORING

5.1. The Licensee shall ensure monitoring is completed as set out in Table 2.

Table 2: Monitoring Schedule

Parameter	Monitoring Requirement
Bacteriological (total coliform and <i>E. coli</i> )	Biweekly sampling program with each set of samples consisting of one raw, one treated, and a minimum of one distribution sample Consecutive sample sets to be separated by at least 12 days
Ultraviolet Disinfection	Daily operation verification of continuous UV unit monitoring
UV Transmittance (UVT)	One sample per week of water entering the UV disinfection units
Monochloramine (treated water)	One sample per day of water entering the distribution system
Monochloramine (distribution system)	At the same times and location(s) as bacteriological distribution system sampling
Total Chlorine (treated water)	One sample per week of water entering the distribution system
Total Chlorine (distribution system)	At the same times and location(s) as bacteriological distribution system sampling
Free Ammonia (treated water)	One sample per week of water entering the distribution system
Free Ammonia (distribution system)	At the same times and location(s) as bacteriological distribution system sampling
Nitrite and Nitrate (distribution system)	One sample taken during July or August every year at a dead end sampling location in the distribution system
General Chemistry (parameter list provided by Office of Drinking Water)	One raw and one treated water sample once every three years
Total Metals (distribution system)	One sample taken at the same time(s) as general chemistry sampling at a mid-point in the distribution system
Barium	One raw, one treated, and one distribution water sample every year
Lead	As per the instructions of the drinking water officer
Manganese	Monitoring included in the general chemistry and total metals analysis
Other Parameters	As per the instructions of the drinking water officer

5.2. The Licensee shall ensure that an accredited laboratory, as specified in section 35 of Manitoba Regulation 40/2007 the Drinking Water Safety Regulation, undertake the following analysis required in Table 2:

- a) bacteriological (total coliform and *E. coli*)
- b) barium
- c) nitrite and nitrate
- d) general chemistry
- e) manganese
- f) total metals
- g) any other parameter required by the drinking water officer

and that all samples are collected, handled, and submitted in a manner that is satisfactory to the accredited laboratory.

- 5.3. The Licensee shall ensure that parameters listed in Table 2 but not specified in clause 5.2 are measured utilizing certified water quality monitoring equipment and methods approved by the latest edition of *Standard Methods for the Examination of Water and Wastewater* published jointly by the American Public Health Association, the American Water Works Association and the Water Environment Federation.
- 5.4. The Licensee shall ensure that all water quality monitoring equipment is properly maintained and calibrated by a qualified person according to manufacturer recommendations and that records are maintained to that effect.
- 5.5. The Licensee shall ensure that sampling within the distribution system takes place at varied locations acceptable to the drinking water officer.

## **6. RECORD-KEEPING AND REPORTING**

- 6.1. The Licensee shall maintain in a secure location all construction drawings for the life of the water system components.
- 6.2. The Licensee shall retain in chronological order for a minimum of 24 months all information specified in subsection 34(2) of Manitoba Regulation 40/2007, Drinking Water Safety Regulation.
- 6.3. The Licensee shall ensure the information identified in clause 6.2 is available for inspection by any member of the public during normal business hours at the office of the water supplier or at a location convenient to the users of the system.
- 6.4. The Licensee shall record disinfectant residual measurements on the monthly disinfection report or other forms satisfactory to the director.
- 6.5. The Licensee shall record other measurements as specified in *Table 2: Monitoring Schedule* on the monthly report forms or other forms satisfactory to the director.
- 6.6. The Licensee shall record UV alarms and maintenance procedures performed on the water system and its supporting equipment on the monthly UV report forms or other forms satisfactory to the director.
- 6.7. The Licensee shall record validated UV condition verifications on the monthly report forms or other forms satisfactory to the director.
- 6.8. The Licensee shall keep one copy of all monthly report forms required in this licence, and forward the original copy to the drinking water officer within seven days after the end of each calendar month.
- 6.9. The Licensee shall record all distribution system measurements specified in *Table 2: Monitoring Schedule* on the chain of custody form (laboratory submission form) which accompanies the bacteriological sample bottles to the laboratory.
- 6.10. The Licensee shall ensure that water metering devices at the water treatment plant or storage reservoir are maintained in good working order and that flow meter readings are recorded on a daily basis and such records are made available for inspection by a drinking water officer.

- 6.11. The Licensee shall submit an annual report to the director by March 31<sup>st</sup> of each year on the operation of the water system in the immediately preceding calendar year. The report shall include the information as set out in subsection 32(2) of Manitoba Regulation 40/2007, Drinking Water Safety Regulation.
- 6.12. The Licensee shall inform the public, in a form satisfactory to the director, when an annual report has been prepared and identify how a free copy can be obtained.
- 6.13. The Licensee shall make a copy of each annual report available to the public at no charge on an internet website within two weeks of the issuance of the report, unless otherwise approved by the director. The annual report shall remain available to the public for at least one year.
- 6.14. The Licensee shall maintain and submit an advisory notification plan to the drinking water officer by May 1<sup>st</sup> of each year. The plan must include a detailed description of communication tools and methods to be used to notify the public of a drinking water emergency, considering key contacts, fan-outs, critical customers, susceptible or difficult-to-reach sub-groups, and template notices where applicable.

# **Appendix E**

## **Monochloramine and UV Reports**

# Monthly Chloramination Report

Water System Name: Klee field Water System Code: 104.0

Month: January Year: 2025 Type of Measurement Device: Electronic

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen

Daily Consumption Units: m<sup>3</sup> Steph Duvai

Flow Meter for Daily Consumption: (circle choice) Raw  Treated  No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	9:30	R.F.	2.51		300
2	8:30	R.F.	3.19		295
3	8:00	R.F.	2.16	4.6	287
4	6:00	B.B.	2.67		263
5	9:45	B.B.	2.10		351
6	8:00	R.F.	2.91		271
7	8:00	R.F.	2.66		269
8	8:00	R.F.	3.03		257
9	8:00	R.F.	3.29		249
10	8:00	R.F.	2.87	4.2	251
11	10:00	R.F.	2.38		262
12	11:30	R.F.	1.82		301
13	7:00	B.B.	2.16		197
14	7:30	B.B.	2.89		264
15	7:30	B.B.	2.78		242
16	7:30	B.B.	2.63		235

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	7:30	B.B.	2.63	4.3	250
18	6:00	B.B.	2.28		241
19	8:30	B.B.	2.24		277
20	7:15	B.B.	2.35		254
21	7:00	B.B.	3.01		251
22	7:00	B.B.	2.99		253
23	6:45	B.B.	3.06		247
24	6:45	B.B.	2.99	4.5	252
25	6:00	B.B.	3.06		238
26	9:00	B.B.	2.92		313
27	7:30	R.F.	3.05		249
28	7:30	R.F.	1.52		248
29	7:00	R.F.	2.57		255
30	8:00	R.F.	2.92		286
31	7:30	R.F.	1.86	4.4	234
Total Monthly Consumption					8142

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)
3	8:00	R.F.	0.09
10	8:00	R.F.	0.05

Date	Time	Initials	Ammonia (mg/L)
17	7:30	B.B.	0.05
24	6:45	B.B.	0.03

Date	Time	Initials	Ammonia (mg/L)
31	7:30	R.F.	0.08

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
Jan. 7	10:30	R.F.	Main St.	2.93	4.2	0.00
Jan. 21	9:00	R.F.	Main St.	2.00	4.1	0.01

Submitted by (Print): BARRY BROESKY

Signature: 

# Monthly Ultraviolet (UV) Report

Water System Name: Klee field Water System Code: 104.0

Month: January Year: 2025

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen

Unit: mJ/cm<sup>2</sup> Steph Duval

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	9:30	R.F.	58.08	-
2	8:30	R.F.	58.08	-
3	8:00	R.F.	58.08	-
4	6:15	B.B.	58.08	-
5	9:45	B.B.	56.48	-
6	8:30	B.B.	56.48	-
7	8:00	R.F.	56.48	-
8	8:00	R.F.	56.48	-
9	8:00	R.F.	56.48	-
10	8:00	R.F.	56.48	-
11	10:00	R.F.	56.48	-
12	11:30	R.F.	58.47	-
13	7:15	B.B.	56.86	-
14	7:15	B.B.	56.86	-
15	7:30	B.B.	56.86	-
16	7:00	B.B.	56.86	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	7:00	B.B.	56.86	-
18	6:15	B.B.	56.53	-
19	8:45	B.B.	56.53	-
20	7:15	B.B.	56.53	-
21	7:00	B.B.	56.53	-
22	7:15	B.B.	56.53	-
23	6:45	B.B.	56.53	-
24	7:15	B.B.	57.57	-
25	6:00	B.B.	56.61	-
26	9:00	B.B.	56.61	-
27	7:30	R.F.	55.80	-
28	7:30	R.F.	55.80	-
29	7:00	R.F.	55.80	-
30	8:00	R.F.	55.80	-
31	7:30	R.F.	55.80	-

Date	UVT readings and Alarm or Warning History and actions taken to resolve
3	UVT TEST: 79.4
10	UVT TEST: 82.5
17	UVT TEST: 80.9
24	UVT TEST: 81.4
31	UVT TEST: 79.4

Submitted by (Print): BARRY BROESKY Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

Water System Name: RM of Hanover - Kleeefeld Water Treatment Plant

Water System Code: 104.0

Design Minimum UVT 70%

Minimum Dose Required 40 mj/cm2

Month: January Year: 2025

Operator-in-charge (Print): BARRY BROSZYK

Other Operators (Print): ROB FRIESEN  
STEPH DUVAL

Flow Units: Imperial Gallons, U.S. Gallons, Cubic Meters

UV Unit No.2								
Date	Time	Alarm or Warning	UV mj/cm2 Minimum	UV mj/cm2 Average	UV mj/cm2 Measured	Unit Flow M3	Bypass Flow M3	% Disinfected
2025-01-01	0:00:00							
2025-01-01	0:00:00							
2025-01-01	0:00:00							
2025-01-01	0:00:00							
2025-01-02	0:00:00							
2025-01-02	0:00:00							
2025-01-02	0:00:00							
2025-01-03	0:00:00							
2025-01-03	0:00:00							
2025-01-03	0:00:00							
2025-01-03	0:00:00							
2025-01-04	0:00:00							
2025-01-04	0:00:00							
2025-01-04	0:00:00							
2025-01-04	0:00:00							
2025-01-04	0:00:00							
2025-01-05	0:00:00							
2025-01-05	0:00:00							
2025-01-05	0:00:00							
2025-01-06	0:00:00							
2025-01-06	0:00:00							
2025-01-06	0:00:00							
2025-01-07	0:00:00							
2025-01-07	0:00:00							
2025-01-07	0:00:00							
2025-01-08	0:00:00							
2025-01-08	0:00:00							
2025-01-08	0:00:00							
2025-01-09	0:00:00							
2025-01-09	0:00:00							
2025-01-09	0:00:00							
2025-01-09	0:00:00							
2025-01-10	0:00:00							
2025-01-10	0:00:00							
2025-01-10	0:00:00							
2025-01-10	0:00:00							

2025-01-10	0:00:00						
2025-01-10	0:00:00						
2025-01-11	0:00:00						
2025-01-11	0:00:00						
2025-01-11	9:47:55						
2025-01-11	0:00:00						
2025-01-11	0:00:00						
2025-01-11	23:16:51						
2025-01-12	0:00:00						
2025-01-12	0:00:00						
2025-01-12	0:00:00						
2025-01-12	0:00:00						
2025-01-13	0:00:00						
2025-01-13	0:00:00						
2025-01-13	0:00:00						
2025-01-13	0:00:00						
2025-01-14	5:26:50						
2025-01-14	0:00:00						
2025-01-17	0:00:00	0	56.03	59.85		0.7	
2025-01-17	0:00:00	0	0.00	56.61		40.5	
2025-01-17	0:00:00	0	0.00	56.73		47.3	
2025-01-18	0:00:00	0	0.00	56.69		13.2	
2025-01-18	0:00:00	0	0.00	57.51		0.3	
2025-01-18	0:00:00	0	0.00	56.62		62.3	
2025-01-18	0:00:00	0	0.00	56.68		40.3	
2025-01-18	0:00:00	0	0.00	56.55		18.3	
2025-01-19	8:36:50	0	0.00	56.70		42.6	
2025-01-19	0:00:00	0	0.00	56.83		37.2	
2025-01-19	0:00:00	0	0.00	56.77		42.6	
2025-01-20	6:38:50	0	0.00	56.64		26.8	
2025-01-20	0:00:00	0	0.00	56.85		30.0	
2025-01-20	0:00:00	0	0.00	56.55		79.3	
2025-01-21	0:00:00	0	0.00	56.68		27.6	
2025-01-21	0:00:00	0	55.72	57.00		27.5	
2025-01-22	0:00:00	0	55.72	57.62		5.7	
2025-01-22	0:00:00	0	0.00	56.56		28.2	
2025-01-22	0:00:00	0	0.00	56.54		80.6	
2025-01-23	0:00:00	0	0.00	56.90		32.7	
2025-01-23	12:02:10	0	0.00	56.55		28.3	
2025-01-23	0:00:00	0	0.00	56.62		67.4	
2025-01-24	0:00:00	0	0.00	56.62		15.3	
2025-01-24	0:00:00	0	0.00	57.17		16.0	
2025-01-24	0:00:00	0	0.00	56.73		53.0	
2025-01-24	0:00:00	0	0.00	56.79		58.5	
2025-01-25	0:00:00	0	55.80	59.07		0.9	
2025-01-25	0:00:00	0	0.00	56.51		71.5	
2025-01-25	0:00:00	0	0.00	56.49		53.4	
2025-01-25	0:00:00	0	0.00	56.61		22.2	
2025-01-26	8:21:00	0	0.00	56.81		49.6	
2025-01-26	0:00:00	0	55.30	56.70		44.9	
2025-01-26	0:00:00	0	0.00	56.54		38.5	
2025-01-27	0:00:00	0	55.30	56.61		34.4	



# Monthly Chloramination Report

Water System Name: Kleeefeld Water System Code: 104.0  
 Month: February Year: 2025 Type of Measurement Device: Electronic  
 Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen  
 Daily Consumption Units: m<sup>3</sup> Steph Duval  
 Flow Meter for Daily Consumption: (circle choice) Raw  **Treated**  No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	7:30	R.F.	2.72		255
2	12:30	R.F.	2.59		348
3	7:30	R.F.	2.13		206
4	7:00	B.B.	2.91		270
5	8:00	B.B.	2.66		253
6	8:00	B.B.	2.66		272
7	7:00	B.B.	2.74	4.1	239
8	7:45	B.B.	2.77		246
9	7:15	B.B.	2.69		270
10	7:15	B.B.	3.01		288
11	7:00	B.B.	3.03		248
12	7:00	B.B.	3.04		249
13	7:00	B.B.	3.06		257
14	7:00	B.B.	3.02	4.3	252
15	6:00	B.B.	2.98		227
16	9:30	B.B.	2.92		291

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	7:00	B.B.	2.98		211
18	7:00	R.F.	3.24		292
19	7:00	R.F.	3.14		267
20	7:00	R.F.	3.09		253
21	7:00	R.F.	2.70	4.5	256
22	8:15	R.F.	2.86		247
23	5:45	R.F.	2.82		253
24	7:30	S.D.	3.03		287
25	7:30	S.D.	3.15		259
26	7:30	S.D.	2.96		303
27	7:15	C.D.	3.02		385
28	7:30	C.D.	2.79	4.4	377
29					
30					
31					
Total Monthly Consumption					7,547

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)
7	7:00	B.B.	0.00	21	7:30	R.F.	0.00				
14	7:00	B.B.	0.00	28	7:30	C.D.	0.00				

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
4	10:00	B.B.	Main Street	2.82	4.3	0.0
18	10:30	R.F.	Main Street	2.36	4.0	0.0

Submitted by (Print): BARRY BROESKY Signature: [Signature]

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS.  
 PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: Kleefeld Water System Code: 104.0

Month: February Year: 2025

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen

Unit: mJ/cm<sup>2</sup> Steph Duval

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	9:30	R.F.	55.64	1 A
2	12:30	R.F.	55.64	-
3	7:30	R.F.	55.64	-
4	7:00	B.B.	55.64	-
5	8:00	B.B.	55.64	-
6	8:00	B.B.	55.64	-
7	7:00	B.B.	55.64	-
8	7:45	B.B.	55.70	-
9	7:15	B.B.	55.70	-
10	7:30	B.B.	55.70	-
11	7:00	B.B.	55.70	-
12	7:15	B.B.	55.70	-
13	7:00	B.B.	56.51	-
14	7:15	B.B.	54.06	-
15	6:15	B.B.	54.02	-
16	9:30	B.B.	54.02	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	7:00	B.B.	56.66	-
18	7:00	R.F.	55.66	-
19	7:00	R.F.	54.02	-
20	7:00	R.F.	54.02	-
21	7:00	R.F.	54.12	-
22	8:15	R.F.	54.12	-
23	5:45	R.F.	54.12	-
24	7:30	S.D.	54.12	-
25	7:30	S.D.	54.12	-
26	7:30	S.D.	54.12	-
27	7:15	C.D.	54.12	-
28	7:30	C.D.	54.12	-
29				
30				
31				

Date	UVT readings and Alarm or Warning History and actions taken to resolve
1	UVMajor - will unable to turn on Revoly Flowmeter reset Flowmeter re-started w/20/11
7	UVT TEST - 80.7
14	UVT TEST: 78.9
21	UVT TEST: 81.2
28	UVT TEST: 81.7

Submitted by (Print): BARRY BROESKY

Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

Water System Name: RM of Hanover - Kleefeld Water Treatment Plant

Water System Code: 104.0

Design Minimum UVT 70%

Minimum Dose Required 40 mj/cm2

Month: February Year: 2025

Operator-in-charge (Print): BARRY BROOKLY

Other Operators (Print): ROB FRIEBEN  
STEPH DUVAL

Flow Units: Imperial Gallons, U.S. Gallons, Cubic Meters

UV Unit No.2								
Date	Time	Alarm or Warning	UV mj/cm2 Minimum	UV mj/cm2 Average	UV mj/cm2 Measured	Unit Flow M3	Bypass Flow M3	% Disinfected
2025-02-01	0:00:00	0	0.00	55.80		237.8		
2025-02-01	0:00:00	0	0.00	56.10		41.4		
2025-02-02	0:00:00	0	0.00	55.79		13.3		
2025-02-02	0:00:00	0	0.00	55.93		56.2		
2025-02-02	0:00:00	0	0.00	55.96		54.6		
2025-02-02	0:00:00	0	0.00	56.00		31.7		
2025-02-03	0:00:00	0	54.00	56.09		33.9		
2025-02-03	0:00:00	0	0.00	55.66		28.4		
2025-02-03	0:00:00	0	0.00	55.75		71.5		
2025-02-05	0:00:00	0	0.00	55.82		29.0		
2025-02-05	0:00:00	0	0.00	55.84		84.1		
2025-02-06	0:00:00	0	0.00	55.86		21.6		
2025-02-06	0:00:00	0	0.00	55.80		1.7		
2025-02-06	0:00:00	0	0.00	55.98		28.4		
2025-02-06	0:00:00	0	0.00	55.64		78.4		
2025-02-07	0:00:00	0	0.00	55.89		18.1		
2025-02-07	0:00:00	0	0.00	55.46		34.7		
2025-02-07	0:00:00	0	0.00	55.95		50.6		
2025-02-07	0:00:00	0	0.00	55.92		17.6		
2025-02-08	0:00:00	0	0.00	55.83		27.0		
2025-02-08	0:00:00	0	0.00	54.03		43.3		
2025-02-08	0:00:00	0	0.00	55.64		55.1		
2025-02-09	0:00:00	0	0.00	56.28		13.5		
2025-02-09	0:00:00	0	0.00	56.23		0.7		
2025-02-09	0:00:00	0	0.00	56.02		43.7		
2025-02-09	0:00:00	0	0.00	55.77		43.4		
2025-02-09	0:00:00	0	0.00	56.05		29.0		
2025-02-10	0:00:00	0	0.00	55.96		36.9		
2025-02-10	0:00:00	0	0.00	56.13		25.2		
2025-02-10	0:00:00	0	0.00	55.68		70.7		
2025-02-11	0:00:00	0	0.00	56.13		25.8		
2025-02-11	0:00:00	0	0.00	55.36		26.3		
2025-02-11	0:00:00	0	0.00	55.95		70.9		
2025-02-12	0:00:00	0	0.00	56.23		13.4		
2025-02-12	0:00:00	0	0.00	55.49		9.1		
2025-02-12	0:00:00	0	0.00	53.85		23.4		





# Monthly Chloramination Report

Water System Name: Kleeferd Water System Code: 104.0

Month: March Year: 2025 Type of Measurement Device: Electronic

Operator-in-charge (Print): Barry Braesky Other Operators (Print): Rob Friesen

Daily Consumption Units: m<sup>3</sup> Cliff Derksen

Flow Meter for Daily Consumption: (circle choice) Raw  Treated  No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	8:15	C.D.	2.36		306
2	7:00	C.D.	2.68		274
3	7:00	B.B.	2.91		296
4	7:00	B.B.	3.00		271
5	7:00	B.B.	2.76		283
6	7:15	B.B.	3.05		281
7	7:15	B.B.	3.00	4.2	285
8	6:00	R.F.	2.88		253
9	12:00	R.F.	3.19		363
10	7:00	R.F.	3.18		220
11	7:00	R.F.	3.36		310
12	8:00	C.D.	2.55		274
13	7:45	C.D.	2.94		268
14	8:00	C.D.	2.80	4.3	264
15	6:15	B.B.	2.74		252
16	11:30	B.B.	2.99		369

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	7:15	C.D.	2.69		239
18	7:30	C.D.	2.81		284
19	7:30	C.D.	2.67		249
20	7:30	C.D.	2.66		259
21	7:15	C.D.	2.81	4.3	244
22	6:30	C.D.	2.26		244
23	7:15	C.D.	2.47		277
24	7:00	B.B.	2.96		283
25	7:00	B.B.	2.84		246
26	7:00	B.B.	2.82		248
27	7:00	B.B.	2.59		249
28	7:00	B.B.	2.86	4.4	253
29	6:30	C.D.	2.75		259
30	6:45	C.D.	2.69		288
31	7:30	C.D.	2.59		276

Total Monthly Consumption ~~8457~~ 8467

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)
7	7:15	B.B.	0.06
14	8:00	C.D.	0.00

Date	Time	Initials	Ammonia (mg/L)
21	7:15	C.D.	0.00
28	7:00	B.B.	0.00

Date	Time	Initials	Ammonia (mg/L)

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
4	9:00	R.F.	Main St.	3.11	3.7	0.05
18	10:00	B.B.	Main St.	2.96	4.5	0.05

Submitted by (Print): Rob Friesen Signature: 

# Monthly Ultraviolet (UV) Report

Water System Name: Kleefeld Water System Code: 104.0

Month: March Year: 2025

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen

Unit: m<sup>3</sup> Cliff Derksen

Date	Time	Operator Initials	UV Dose mJ/cm2	Number of Alarms (A) or Warnings (W)
1	8:15	C.D.	54.21	—
2	7:00	C.D.	54.21	—
3	7:15	B.B.	53.38	—
4	7:00	B.B.	54.21	—
5	7:15	B.B.	54.21	—
6	7:30	B.B.	54.21	—
7	7:30	B.B.	54.21	—
8	6:00	R.F.	54.21	—
9	12:00	R.F.	54.21	—
10	7:30	R.F.	54.14	—
11	7:00	R.F.	54.14	—
12	8:00	C.D.	54.14	—
13	7:45	C.D.	54.14	—
14	8:00	C.D.	53.84	—
15	6:30	B.B.	54.54	—
16	11:30	B.B.	54.54	—

Date	Time	Operator Initials	UV Dose mJ/cm2	Number of Alarms (A) or Warnings (W)
17	7:15	C.D.	54.54	—
18	7:30	C.D.	53.70	—
19	7:30	C.D.	53.70	—
20	7:30	C.D.	53.70	—
21	7:15	C.D.	54.04	—
22	6:30	C.D.	54.04	—
23	7:15	C.D.	52.37	—
24	7:30	B.B.	53.21	—
25	7:00	B.B.	54.04	—
26	7:00	B.B.	54.04	—
27	7:00	B.B.	54.04	—
28	7:15	B.B.	54.04	—
29	6:30	C.D.	52.80	—
30	6:45	C.D.	52.80	—
31	7:30	C.D.	52.80	—

Date	UVT readings and Alarm or Warning History and actions taken to resolve
7	UVT TEST: 81.3
14	UVT TEST: 83.0
21	UVT TEST: 80.5
28	UVT TEST: 82.8

Submitted by (Print): Rob Friesen Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.



Water System Name: RM of Hanover - Kleeefeld Water Treatment Plant

Water System Code: 104.0

Design Minimum UVT 70%

Minimum Dose Required 40 mj/cm2

Month: March Year: 2025

Operator-in-charge (Print): Barry Broesky

Other Operators (Print): Rob Friesen  
Cliff Derksen

Flow Units: Imperial Gallons, U.S. Gallons, Cubic Meters

UV Unit No.2

Date	Time	Alarm or Warning	UV mj/cm2 Minimum	UV mj/cm2 Average	UV mj/cm2 Measured	Unit Flow M3	Bypass Flow M3	% Disinfected
2025-03-03	0:00:00	0	0.00	54.20		35.6		
2025-03-03	0:00:00	0	0.00	54.62		27.7		
2025-03-03	0:00:00	0	0.00	54.26		81.8		
2025-03-04	0:00:00	0	0.00	54.23		30.5		
2025-03-04	0:00:00	0	0.00	55.91		0.9		
2025-03-04	0:00:00	0	0.00	54.51		29.1		
2025-03-04	0:00:00	0	0.00	54.19		88.1		
2025-03-05	0:00:00	0	0.00	54.55		17.1		
2025-03-05	0:00:00	0	53.38	55.11		7.5		
2025-03-05	0:00:00	0	0.00	54.23		29.4		
2025-03-05	0:00:00	0	0.00	54.21		104.6		
2025-03-06	0:00:00	0	0.00	54.06		31.2		
2025-03-06	0:00:00	0	0.00	53.85		84.5		
2025-03-07	0:00:00	0	0.00	54.15		18.8		
2025-03-07	0:00:00							
2025-03-07	0:00:00	0	52.83	54.12		28.2		
2025-03-07	0:00:00	0	0.00	54.44		47.9		
2025-03-08	0:00:00	0	0.00	54.11		14.8		
2025-03-09	0:00:00	0	0.00	54.37		50.2		
2025-03-09	0:00:00	0	53.31	54.46		54.4		
2025-03-10	0:00:00	0	0.00	54.16		38.3		
2025-03-10	0:00:00	0	0.00	54.42		39.8		
2025-03-12	0:00:00	0	0.00	54.07		28.3		
2025-03-12	0:00:00	0	0.00	54.05		80.8		
2025-03-13	0:00:00	0	0.00	54.55		33.2		
2025-03-13	0:00:00	0	0.00	54.18		30.1		
2025-03-13	0:00:00	0	0.00	54.25		67.4		
2025-03-14	0:00:00	0	0.00	54.60		15.2		
2025-03-14	0:00:00	0	0.00	54.42		26.8		
2025-03-15	0:00:00	0	53.70	55.91		0.7		
2025-03-15	0:00:00	0	0.00	54.45		85.0		
2025-03-15	0:00:00	0	0.00	54.75		66.8		
2025-03-15	0:00:00	0	0.00	54.77		17.0		
2025-03-16	0:00:00	0	0.00	54.45		62.2		
2025-03-16	0:00:00	0	0.00	54.59		50.1		
2025-03-16	0:00:00	0	0.00	54.81		49.9		





# Monthly Chloramination Report

Water System Name: Kleeefeld Water System Code: 104.0

Month: April Year: 2025 Type of Measurement Device: Electronic

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen

Daily Consumption Units: m<sup>3</sup> Cliff Derksen

Flow Meter for Daily Consumption: (circle choice) Raw  Treated  No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	7:45	C.D.	2.82		258
2	7:30	C.D.	3.04		250
3	7:45	C.D.	2.81		257
4	7:45	C.D.	2.92	4.1	272
5	8:30	R.F.	3.05		257
6	11:00	R.F.	3.10		314
7	7:00	C.D.	2.78		220
8	7:15	C.D.	2.70		270
9	7:00	R.F.	3.10		256
10	7:00	C.D.	2.85		257
11	7:00	C.D.	2.79	4.4	260
12	6:45	C.D.	2.77		243
13	7:00	C.D.	2.67		280
14	7:15	B.B.	3.03		290
15	6:45	B.B.	2.91		253
16	7:00	B.B.	2.85		264

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	6:45	B.B.	2.95		245
18	6:00	B.B.	3.00	4.1	249
19	7:00	B.B.	2.97		6264
20	8:00	B.B.	3.03		300
21	7:30	R.F.	3.20		276
22	7:30	R.F.	3.13		285
23	7:00	R.F.	3.19		271
24	7:00	R.F.	3.26		261
25	7:00	R.F.	3.35	3.9	270
26	8:30	R.F.	3.12		274
27	6:30	R.F.	3.16		254
28	7:00	C.D.	2.84		296
29	7:00	C.D.	2.65		264
30	7:00	C.D.	3.12		280
31	7:00	C.D.			254

Total Monthly Consumption ~~7970~~  
7990

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)
4	8:00	C.D.	0.00
11	7:00	C.D.	0.00

Date	Time	Initials	Ammonia (mg/L)
18	6:00	B.B.	0.00
25	7:00	R.F.	0.00

Date	Time	Initials	Ammonia (mg/L)

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
1		C.D.	Main street	2.58	4.0	0.00
15	8:00	B.B.	MAIN STREET	3.01	4.3	0.01
29	8:00	C.D.	Main street	2.82	4.4	0.00

Submitted by (Print): BARRY BROESKY

Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS.  
PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: Hleefeld Water System Code: 104.0

Month: April Year: 2025

Operator-in-charge (Print): Barry Brofsky Other Operators (Print): Rob Friesen

Unit: mJ/cm<sup>2</sup> Cliff Derksen

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	7:45	C.D.	54.48	~
2	7:30	C.D.	52.80	~
3	7:45	C.D.	52.80	~
4	7:45	C.D.	52.80	~
5	8:30	R.F.	52.83	-
6	11:00	R.F.	52.83	-
7	7:00	C.D.	52.83	-
8	7:15	C.D.	52.83	-
9	7:00	R.F.	52.83	-
10	7:00	C.D.	52.83	-
11	7:00	C.D.	52.83	-
12	6:45	C.D.	52.42	-
13	7:00	C.D.	52.42	~
14	7:30	B.B.	52.42	-
15	7:00	B.B.	52.42	-
16	7:15	B.B.	52.42	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	6:45	B.B.	52.42	-
18	6:15	B.B.	53.26	-
19	7:00	B.B.	56.76	-
20	8:15	B.B.	52.62	-
21	7:30	R.F.	52.62	-
22	7:30	R.F.	52.15	-
23	7:00	R.F.	52.62	-
24	7:00	R.F.	52.62	-
25	7:00	R.F.	52.62	-
26	8:30	R.F.	53.36	-
27	6:30	R.F.	53.36	-
28	7:00	C.D.	52.52	-
29	7:00	C.D.	52.52	-
30	7:00	C.D.	52.52	-
31				

Date	UVT readings and Alarm or Warning History and actions taken to resolve
4	82.9 - UVT TEST
11	81.0 - UVT TEST
18	UVT TEST: 82.1
25	UVT TEST: 81.6

Submitted by (Print): BARRY BROFSKY Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

Water System Name: RM of Hanover - Kleefeld Water Treatment Plant

Water System Code: 104.0

Design Minimum UVT 70%

Minimum Dose Required 40 mj/cm2

Month: April Year: 2025

Operator-in-charge (Print): Barry Broesky

Other Operators (Print): Rob Friesen

Cliff Derksen

Flow Units: Imperial Gallons, U.S. Gallons, Cubic Meters

UV Unit No.2								
Date	Time	Alarm or Warning	UV mj/cm2 Minimum	UV mj/cm2 Average	UV mj/cm2 Measured	Unit Flow M3	Bypass Flow M3	% Disinfected
2025-04-01	0:00:00	0	0.00	53.27		21.7		
2025-04-01	0:00:00	0	0.00	56.76		0.4		
2025-04-01	0:00:00	0	0.00	53.28		27.6		
2025-04-01	0:00:00	0	0.00	54.10		74.5		
2025-04-02	0:00:00	0	0.00	54.15		16.3		
2025-04-02	0:00:00	0	0.00	53.52		6.0		
2025-04-02	0:00:00	0	0.00	53.84		32.6		
2025-04-02	0:00:00	0	0.00	53.92		67.4		
2025-04-03	0:00:00	0	0.00	53.15		15.5		
2025-04-03	0:00:00	0	0.00	53.72		7.7		
2025-04-03	0:00:00	0	0.00	53.29		33.4		
2025-04-03	0:00:00	0	0.00	54.16		66.3		
2025-04-04	0:00:00	0	0.00	53.23		16.2		
2025-04-04	0:00:00	0	0.00	53.08		15.0		
2025-04-04	0:00:00	0	0.00	53.40		12.6		
2025-04-04	0:00:00	0	0.00	52.99		53.9		
2025-04-04	0:00:00	0	0.00	53.30		15.5		
2025-04-05	0:00:00	0	0.00	53.61		74.0		
2025-04-05	0:00:00	0	0.00	53.61		74.0		
2025-04-05	0:00:00	0	0.00	53.23		38.2		
2025-04-05	0:00:00	0	0.00	53.23		38.2		
2025-04-05	0:00:00	0	0.00	53.52		39.3		
2025-04-05	0:00:00	0	0.00	53.52		39.3		
2025-04-06	0:00:00	0	0.00	53.28		52.9		
2025-04-08	0:00:00	0	0.00	53.25		28.7		
2025-04-08	0:00:00	0	0.00	23.17		132.0		
2025-04-09	0:00:00	0	0.00	53.41		28.6		
2025-04-09	0:00:00	0	0.00	54.09		69.5		
2025-04-10	0:00:00	0	0.00	53.96		15.8		
2025-04-10	0:00:00	0	0.00	53.96		15.8		
2025-04-10	0:00:00	0	51.97	53.94		11.5		
2025-04-10	0:00:00	0	51.97	53.94		11.5		
2025-04-10	0:00:00	0	0.00	53.62		24.7		
2025-04-10	0:00:00	0	0.00	53.62		24.7		
2025-04-10	0:00:00	0	0.00	53.62		67.1		
2025-04-10	0:00:00	0	0.00	53.62		67.1		

2025-04-11	0:00:00	0	0.00	53.90	16.6		
2025-04-11	0:00:00	0	0.00	53.90	16.6		
2025-04-11	0:00:00	0	0.00	53.13	9.0		
2025-04-11	0:00:00	0	0.00	53.00	29.0		
2025-04-11	17:17:50	0	0.00	53.33	52.6		
2025-04-11	0:00:00	0	0.00	53.33	52.6		
2025-04-12	0:00:00	0	0.00	52.96	13.7		
2025-04-12	0:31:25	0	0.00	52.96	13.7		
2025-04-12	0:00:00	0	0.00	53.21	5.1		
2025-04-12	0:00:00	0	0.00	53.43	50.1		
2025-04-12	0:00:00	0	0.00	53.43	50.1		
2025-04-12	0:00:00	0	0.00	52.49	44.4		
2025-04-12	0:00:00	0	0.00	52.49	44.4		
2025-04-12	0:00:00	0	0.00	52.45	28.2		
2025-04-13	0:00:00	0	0.00	52.67	19.6		
2025-04-13	0:00:00	0	0.00	53.11	42.0		
2025-04-13	17:32:05	0	0.00	52.65	79.5		
2025-04-14	0:00:00	0	0.00	52.80	14.1		
2025-04-14	0:00:00	0	0.00	52.80	14.1		
2025-04-14	0:00:00	0	0.00	53.51	5.7		
2025-04-14	0:00:00	0	0.00	52.48	31.5		
2025-04-14	0:00:00	0	0.00	52.48	31.5		
2025-04-14	0:00:00	0	0.00	53.30	81.1		
2025-04-15	0:00:00	0	0.00	52.55	16.0		
2025-04-15	0:00:00	0	0.00	53.55	1.8		
2025-04-15	0:00:00	0	0.00	52.70	28.8		
2025-04-16	7:04:44	0	51.96	52.68	15.2		
2025-04-16	0:00:00	0	0.00	52.51	21.4		
2025-04-16	0:00:00	0	0.00	52.96	69.5		
2025-04-17	5:22:10	0	0.00	52.47	28.2		
2025-04-17	0:00:00	0	0.00	52.65	31.8		
2025-04-17	0:00:00	0	0.00	52.60	50.0		
2025-04-17	0:00:00	0	0.00	52.39	18.3		
2025-04-18	0:00:00	0	0.00	53.45	3.3		
2025-04-18	0:00:00	0	0.00	52.82	72.3		
2025-04-18	0:00:00	0	0.00	52.97	32.8		
2025-04-18	0:00:00	0	0.00	52.97	19.3		
2025-04-19	0:00:00	0	0.00	53.04	10.1		
2025-04-19	10:49:50	0	0.00	53.02	74.3		
2025-04-19	0:00:00	0	0.00	52.84	53.6		
2025-04-20	0:00:00	0	0.00	53.14	15.3		
2025-04-20	0:00:00	0	0.00	52.74	55.5		
2025-04-20	0:00:00	0	0.00	52.68	30.0		
2025-04-20	0:00:00	0	0.00	52.70	56.4		
2025-04-21	0:00:00	0	0.00	52.80	52.0		
2025-04-21	0:00:00	0	0.00	52.67	33.9		
2025-04-21	0:00:00	0	0.00	25.18	159.5		
2025-04-23	0:00:00	0	0.00	52.77	8.1		
2025-04-23	12:33:12	0	0.00	52.67	25.6		
2025-04-23	0:00:00	0	0.00	52.90	73.9		
2025-04-24	0:00:00	0	0.00	52.86	31.3		
2025-04-24	0:00:00	0	0.00	52.64	81.7		

2025-04-24	0:00:00	0	0.00	53.14		14.1		
2025-04-25	0:00:00	0	0.00	53.12		29.7		
2025-04-25	0:00:00	0	0.00	52.59		26.3		
2025-04-25	0:00:00	0	52.05	52.93		58.3		
2025-04-26	0:00:00	0	0.00	52.82		15.4		
2025-04-26	0:00:00	0	51.67	52.66		55.4		
2025-04-26	15:01:07	0	0.00	52.60		44.4		
2025-04-26	0:00:00	0	0.00	52.84		37.4		
2025-04-26	0:00:00	0	0.00	21.57		273.4		
2025-04-28	18:23:24	0	0.00	52.56		71.7		
2025-04-29	0:00:00	0	0.00	52.61		35.2		
2025-04-29	0:00:00	0	0.00	52.75		34.0		
2025-04-29	0:00:00	0	0.00	52.56		77.4		
2025-04-30	0:00:00	0	0.00	52.79		14.2		
2025-04-30	0:00:00	0	0.00	52.54		14.6		
2025-04-30	0:00:00	0	0.00	52.52		25.0		
2025-04-30	0:00:00	0	0.00	52.37		66.5		

Monthly Values	0	0.00	52.3	4143.4	0.0	100.0%
----------------	---	------	------	--------	-----	--------

Submitted By (Print): BARRY BROENKY

Signature: 

# Monthly Chloramination Report

Water System Name: Kleeefeld Water System Code: 104.0

Month: May Year: 2025 Type of Measurement Device: Electronic

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen

Daily Consumption Units: m<sup>3</sup> Cliff Dertsen

Flow Meter for Daily Consumption: (circle choice) Raw  Treated  No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	7:00	C.D.	3.00		254
2	7:00	C.D.	3.01	4.1	272
3	7:30	C.D.	3.03		263
4	8:00	C.D.	3.15		371
5	7:00	B.B.	3.36		437
6	7:00	B.B.	3.30		380
7	7:30	B.B.	3.02		341
8	7:00	B.B.	3.10		348
9	7:00	B.B.	3.27	4.2	359
10	7:30	B.B.	3.06		347
11	10:30	B.B.	1.91		501
12	8:30	R.F.	2.49		408
13	8:30	R.F.	2.75		417
14	7:30	R.F.	3.11		426
15	8:00	R.F.	3.55		675
16	8:30	R.F.	3.07	5.3	590

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	9:00	R.F.	2.55		247
18	11:30	R.F.	2.97		314
19	8:00	R.F.	2.75		217
20	7:00	C.D.	2.64		359
21	7:30	C.D.	2.87		276
22	7:00	C.D.	2.58		303
23	7:00	C.D.	2.94	4.5	346
24	6:30	C.D.	3.01		383
25	7:00	C.D.	3.01		500
26	8:00	R.F.	3.42		569
27	8:00	R.F.	3.51		387
28	8:00	R.F.	3.06		548
29	8:00	R.F.	3.02		455
30	8:00	R.F.	3.28	4.9	481
31	6:15	B.B.	3.42		520
Total Monthly Consumption					12,294

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)
2	7:00	C.D.	0.00
9	7:00	B.B.	0.05

Date	Time	Initials	Ammonia (mg/L)
16	8:30	R.F.	0.06
23	7:00	C.D.	<del>0.01</del> 0.01

Date	Time	Initials	Ammonia (mg/L)
30	8:00	R.F.	0.01

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
13	9:00	R.F.	Main Street	2.63	3.3	0.05
27	9:00	R.F.	Main Street	2.79	4.4	0.00

Submitted by (Print): Barry Broesky Signature: [Signature]

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: Hleefeld Water System Code: 104.0

Month: May Year: 2025

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen

Unit: mJ/cm<sup>2</sup> Cliff Derksen

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	7:00	C.D.	52.52	-
2	7:00	C.D.	52.52	-
3	7:30	C.D.	52.25	-
4	8:00	C.D.	52.25	-
5	7:15	B.B.	52.25	-
6	7:15	B.B.	52.72	-
7	7:45	B.B.	52.72	-
8	7:00	B.B.	52.72	-
9	7:00	B.B.	53.09	-
10	7:30	B.B.	54.01	-
11	10:30	B.B.	54.01	-
12	8:30	R.F.	54.01	-
13	8:30	R.F.	54.01	-
14	7:30	R.F.	54.01	-
15	8:00	R.F.	54.94	-
16	8:30	R.F.	56.46	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	9:00	R.F.	64.21	-
18	11:30	R.F.	62.39	-
19	8:00	R.F.	62.39	-
20	7:00	C.D.	62.39	-
21	7:30	C.D.	63.34	-
22	7:00	C.D.	63.34	-
23	7:15	C.D.	64.28	-
24	6:30	C.D.	55.94	-
25	7:00	C.D.	55.94	-
26	8:00	R.F.	55.94	-
27	8:00	R.F.	55.94	-
28	8:00	R.F.	56.76	-
29	8:00	R.F.	55.94	-
30	8:00	R.F.	55.45	-
31	6:30	B.B.	56.63	-

Date	UVT readings and Alarm or Warning History and actions taken to resolve
2	82.5 UVT
9	UVT TEST: 80.1
16	UVT TEST: 93.0
23	UVT TEST: 82.1
30	UVT TEST: 81.5

Submitted by (Print): Barry Broesky Signature: [Signature]

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.





# Monthly Chloramination Report

Water System Name: KLEEFELD Water System Code: 104.0

Month: JUNE Year: 2025 Type of Measurement Device: ELECTRONIC

Operator-in-charge (Print): BARRY BROESLY Other Operators (Print): ROB FRIESEN

Daily Consumption Units: m<sup>3</sup> CLIFF DERKSEN

Flow Meter for Daily Consumption: (circle choice) Raw Treated No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	9:30	B.B.	3.54		772
2	7:30	R.F.	3.81		573
3	7:30	R.F.	3.38		292
4	7:00	R.F.	3.42		320
5	7:30	R.F.	3.84		433
6	7:30	C.D.	3.19	4.7	451
7	10:00	R.F.	3.62		2-
8	5:30	R.F.	2.82		278
9	7:00	C.D.	2.44		348
10	7:00	C.D.	3.09		287
11	7:00	C.D.	3.00		318
12	7:00	C.D.	3.11		657
13	6:30	C.D.	3.44	4.6	650
14	6:45	C.D.	3.32		436
15	7:00	C.D.	3.05		486
16	6:45	B.B.	3.44		492

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	6:45	B.B.	3.22		422
18	7:00	B.B.	2.97		338
19	7:00	B.B.	2.79		341
20	7:00	B.B.	1.21	0.8	432
21	6:30	B.B.	2.39		421
22	6:15	B.B.	2.97		498
23	7:00	R.F.	2.82		333
24	7:00	R.F.	2.80		327
25	7:00	R.F.	2.79		346
26	7:00	R.F.	2.93	3.7	321
27	7:00	R.F.	3.12	3.7	378
28	7:00	R.F.	2.63		357
29	6:00	R.F.	3.10		390
30	9:30	C.D.	2.31		493
31	<del>6:30</del>	<del>C.D.</del>			<del>473</del>
Total Monthly Consumption					12,693

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)
6	7:30	C.D.	0.00
13	6:30	C.D.	0.00

Date	Time	Initials	Ammonia (mg/L)
20	7:00	B.B.	0.05
27	7:00	R.F.	0.02

Date	Time	Initials	Ammonia (mg/L)

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
10	9:00	C.D.	Main St.	3.10	4.7	0.00
24	11:15	R.F.	Main St.	2.98	4.9	0.00

Submitted by (Print): BARRY BROESLY

Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS.  
PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: KLEEFELD Water System Code: 104.0

Month: JUNE Year: 2025

Operator-in-charge (Print): BARRY BROESKY Other Operators (Print): ROB FRIESEN

Unit: mJ/cm<sup>2</sup> CLIFF DERKSEN

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	9:30	B.B.	56.63	-
2	7:30	R.F.	56.63	-
3	7:30	R.F.	56.63	-
4	7:00	R.F.	56.63	-
5	7:00	R.F.	56.63	-
6	7:30	C.D.	56.63	-
7	10:00	R.F.	57.53	-
8	5:30	R.F.	57.53	-
9	7:00	C.D.	57.53	-
10	7:00	C.D.	57.53	-
11	7:00	C.D.	58.58	-
12	7:00	C.D.	58.58	-
13	6:30	C.D.	58.58	-
14	6:45	C.D.	57.13	-
15	7:00	C.D.	57.96	-
16	7:00	B.B.	57.96	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	7:00	B.B.	57.96	-
18	7:15	R.R.	57.96	-
19	7:15	B.B.	57.96	-
20	7:00	B.B.	57.96	-
21	6:45	B.B.	59.15	-
22	6:30	B.B.	59.15	-
23	7:00	R.F.	59.15	-
24	7:00	R.F.	59.15	-
25	7:00	R.F.	59.15	-
26	7:00	R.F.	59.15	-
27	7:00	R.F.	60.51	-
28	7:00	R.F.	59.96	-
29	6:00	R.F.	59.96	-
30	9:30	C.D.	60.25	-
31	<del>6:30</del>	<del>C.D.</del>	<del>60.25</del>	-

Date	UVT readings and Alarm or Warning History and actions taken to resolve
JUNE 6	UVT TEST: 84.3
JUNE 13	UVT TEST: 82.7
20	UVT TEST: 78.7
27	UVT TEST: 80.5

Submitted by (Print): BARRY BROESKY Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.







# Monthly Chloramination Report

Water System Name: Kliefeld Water System Code: 104.0

Month: July Year: 2025 Type of Measurement Device: Electronic

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Rob Friesen

Daily Consumption Units: m<sup>3</sup> Cliff Derksen

Flow Meter for Daily Consumption: (circle choice) Raw  Treated / No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	6:30	C.D.	2.47		359
2	7:00	C.D.	2.31		538
3	7:00	C.D.	1.69		338
4	7:09	C.D.	1.66	2.90	391
5	7:00	C.D.	2.04		368
6	6:00	C.D.	2.49		423
7	7:00	B.B.	2.56		468
8	7:00	B.B.	2.64		343
9	7:00	B.B.	2.38		345
10	7:00	B.B.	3.35		622
11	6:45	B.B.	3.32	4.5	629
12	6:15	B.B.	1.96		285
13	6:00	B.B.	1.42		373
14	6:45	C.D.	1.98		410
15	6:45	C.D.	1.35		300
16	7:00	R.F.	1.70		283

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	7:00	R.F.	1.98		291
18	7:00	R.F.	1.69	2.0	331
19	10:00	R.F.	1.10		374
20	8:00	R.F.	1.06		377
21	7:09	C.D.	1.16		311
22	7:09	C.D.	1.97		286
23	7:00	C.D.	1.58		263
24	7:00	C.D.	1.18		280
25	7:00	C.D.	1.77	1.8	300
26	7:00	C.D.	1.48		336
27	7:00	C.D.	1.12		372
28	6:30	B.B.	1.73		297
29	7:00	B.B.	1.35		281
30	6:45	B.B.	1.14		307
31	6:45	B.B.	1.81		346
Total Monthly Consumption					11,187

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)
4	7:00	C.D.	0.01	18	7:00	R.F.	0.02				
11	7:00	B.B.	0.02	25	7:00	C.D.	0.09				

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
8	8:15	B.B.	MAIN Lt.	2.89	3.4	0.00
22	8:15	C.D.	Main st.	1.76	2.0	0.06

Submitted by (Print): Barry Broesky Signature: [Signature]

# Monthly Ultraviolet (UV) Report

Water System Name: Kleeefeld Water System Code: 104.0

Month: July Year: 2025

Operator-in-charge (Print): Barry Brodesky Other Operators (Print): Rob Friesen

Unit: mJ/cm<sup>2</sup> Cliff Derksen

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	7:00	C.D.	63.11	-
2	7:00	C.D.	59.15	-
3	7:00	C.D.	60.75	-
4	7:00	C.D.	59.70	-
5	7:00	C.D.	59.17	-
6	6:00	C.D.	60.78	-
7	<del>6:00</del> 7:15	R.B.	60.78	-
8	7:00	R.B.	60.78	-
9	7:00	R.B.	60.78	-
10	7:15	R.B.	60.78	-
11	7:00	R.B.	61.57	-
12	6:15	R.B.	61.98	-
13	6:00	R.B.	61.98	-
14	6:45	C.D.	61.98	-
15	6:45	C.D.	61.98	-
16	7:00	R.F.	62.77	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	7:00	R.F.	63.56	-
18	7:00	R.F.	63.56	-
19	10:00	R.F.	63.56	-
20	8:00	R.F.	63.56	-
21	7:00	C.D.	63.56	-
22	7:00	C.D.	61.98	-
23	7:00	C.D.	61.98	-
24	7:00	C.D.	61.98	-
25	7:00	C.D.	61.98	-
26	7:00	C.D.	61.81	-
27	7:00	C.D.	61.81	-
28	6:45	R.B.	61.81	-
29	7:00	R.B.	61.81	-
30	6:45	R.B.	63.38	-
31	7:00	R.B.	61.81	-

Date	UVT readings and Alarm or Warning History and actions taken to resolve
4	UVT TEST: 80.7
11	UVT TEST: 82.6
18	UVT TEST: 83.5
25	UVT TEST: 82.0

Submitted by (Print): Barry Brodesky Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

Water System Name: RM of Hanover - Kleefeld Water Treatment Plant

Water System Code: 104.0

Design Minimum UVT 70%

Minimum Dose Required 40 mj/cm2

Month: July Year: 2025

Operator-in-charge (Print): Barry Broesky

Other Operators (Print): Rob Friesen

Cliff Derksen

Flow Units: Imperial Gallons, U.S. Gallons, Cubic Meters

UV Unit No.1								
Date	Time	Alarm or Warning	UV mj/cm2 Minimum	UV mj/cm2 Average	UV mj/cm2 Measured	Unit Flow M3	Bypass Flow M3	% Disinfected
2024-12-04	0:00:00	99	0.00	0.43		78194.5		
2024-12-04	0:00:00	99	0.00	0.58		78603.9		
2025-07-03	0:00:00	0	0.00	59.16		48.1		
2025-07-03	0:00:00	0	0.00	65.39		0.2		
2025-07-03	0:00:00	0	0.00	59.47		26.1		
2025-07-03	0:00:00	0	0.00	59.08		166.1		
2025-07-04	0:00:00	0	0.00	59.90		86.4		
2025-07-04	0:00:00	0	0.00	60.02		134.2		
2025-07-04	0:00:00	0	0.00	59.27		74.7		
2025-07-05	0:00:00	0	0.00	59.31		202.3		
2025-07-05	0:00:00	0	0.00	60.33		399.9		
2025-07-06	0:00:00	0	0.00	61.05		143.5		
2025-07-06	0:00:00	0	0.00	60.22		493.6		
2025-07-07	0:00:00	0	0.00	61.10		109.9		
2025-07-07	0:00:00	0	0.00	61.16		43.1		
2025-07-07	0:00:00	0	0.00	60.89		19.5		
2025-07-07	0:00:00	0	0.00	60.86		65.0		
2025-07-08	0:00:00	0	0.00	61.10		54.3		
2025-07-08	0:00:00	0	0.00	60.81		36.1		
2025-07-08	0:00:00	0	0.00	60.85		179.2		
2025-07-09	0:00:00	0	0.00	60.87		69.2		
2025-07-09	0:00:00	0	0.00	59.60		2154.3		
2025-07-10	0:00:00	0	0.00	61.43		2.3		
2025-07-10	0:00:00	0	0.00	61.30		3004.9		
2025-07-11	0:00:00	0	0.00	62.47		29.6		
2025-07-11	0:00:00	0	0.00	62.31		58.4		
2025-07-12	0:00:00	0	0.00	62.45		27.1		
2025-07-12	0:00:00	0	0.00	62.12		222.3		
2025-07-12	0:00:00	0	0.00	62.25		104.8		
2025-07-13	0:00:00	0	0.00	62.14		30.5		
2025-07-13	0:00:00	0	0.00	62.16		95.0		
2025-07-13	0:00:00	0	0.00	62.04		311.1		
2025-07-14	0:00:00	0	0.00	62.18		82.3		
2025-07-14	0:00:00	0	0.00	62.13		20.4		
2025-07-14	0:00:00	0	0.00	62.06		71.6		
2025-07-15	0:00:00	0	0.00	62.40		15.8		

2025-07-15	0:00:00	0	0.00	62.55	32.9	
2025-07-15	0:00:00	0	0.00	62.11	32.7	
2025-07-15	0:00:00	0	0.00	62.07	86.9	
2025-07-16	0:00:00	0	0.00	62.83	34.7	
2025-07-16	6:12:55	0	0.00	62.83	34.7	
2025-07-16	0:00:00	0	0.00	63.42	40.5	
2025-07-16	0:00:00	0	0.00	63.42	40.5	
2025-07-16	17:41:41	0	0.00	34.68	298.8	
2025-07-18	0:00:00	0	0.00	63.38	55.1	
2025-07-18	0:00:00	0	0.00	62.41	142.3	
2025-07-19	0:00:00	0	0.00	63.41	21.8	
2025-07-19	0:00:00	0	0.00	63.08	178.9	
2025-07-19	0:00:00	0	0.00	63.66	175.4	
2025-07-20	0:00:00	0	0.00	64.23	28.9	
2025-07-20	0:00:00	0	0.00	63.51	74.8	
2025-07-20	0:00:00	0	0.00	63.55	148.5	
2025-07-21	5:51:40	0	0.00	64.17	5.6	
2025-07-21	0:00:00	0	0.00	62.63	12.9	
2025-07-21	0:00:00	0	0.00	62.67	31.8	
2025-07-21	0:00:00	0	0.00	62.29	87.8	
2025-07-22	0:00:00	0	0.00	62.66	14.8	
2025-07-22	0:00:00	0	0.00	62.89	15.6	
2025-07-22	0:00:00	0	0.00	62.74	2.7	
2025-07-22	0:00:00	0	0.00	62.15	40.1	
2025-07-22	0:00:00	0	0.00	62.25	58.6	
2025-07-23	0:00:00	0	0.00	62.56	2.8	
2025-07-23	17:43:50	0	0.00	62.07	106.7	
2025-07-24	0:00:00	0	0.00	62.33	30.8	
2025-07-24	0:00:00	0	0.00	63.37	2.5	
2025-07-24	12:54:50	0	0.00	62.34	5.0	
2025-07-24	0:00:00	0	0.00	64.99	0.7	
2025-07-24	0:00:00	0	0.00	62.71	13.9	
2025-07-24	0:00:00	0	0.00	62.04	124.5	
2025-07-25	0:00:00	0	0.00	62.26	42.2	
2025-07-25	0:00:00	0	0.00	61.91	60.0	
2025-07-25	0:00:00	0	0.00	62.05	123.7	
2025-07-26	0:00:00	0	0.00	62.36	18.3	
2025-07-26	0:00:00	0	0.00	61.93	3.7	
2025-07-26	10:38:00	0	0.00	61.96	270.3	
2025-07-26	0:00:00	0	0.00	62.12	77.1	
2025-07-27	0:00:00	0	0.00	62.01	52.3	
2025-07-27	0:00:00	0	0.00	61.87	12.4	
2025-07-27	0:00:00	0	0.00	61.48	71.0	
2025-07-27	0:00:00	0	0.00	62.01	29.5	
2025-07-28	0:00:00	0	61.02	62.36	25.8	
2025-07-28	0:00:00	0	61.02	62.36	25.8	
2025-07-28	0:00:00	0	0.00	61.70	37.9	
2025-07-28	0:00:00	0	0.00	61.70	37.9	
2025-07-28	17:46:00	0	0.00	61.56	89.1	
2025-07-28	0:00:00	0	0.00	61.56	89.1	
2025-07-29	0:00:00	0	0.00	62.34	31.7	
2025-07-29	0:00:00	0	0.00	61.94	53.3	



# Monthly Chloramination Report

Water System Name: KLEEFELD Water System Code: 104.0

Month: August Year: 2025 Type of Measurement Device: ELECTRONIC

Operator-in-charge (Print): Rob Friesen Other Operators (Print): Cliff Derksen

Daily Consumption Units: m<sup>3</sup> Barry Braesky

Flow Meter for Daily Consumption: (circle choice) Raw Treated No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	8:30	R.F.	1.60	3.6	378
2	6:45	B.B.	1.35		311
3	7:30	B.B.	1.44		394
4	7:00	B.B.	1.57		345
5	8:00	R.F.	1.48		403
6	8:00	R.F.	1.42		308
7	8:30	R.F.	1.60		2927
8	8:30	R.F.	1.30		293
9	9:30	R.F.	1.24		278
10	6:30	R.F.	1.00		274
11	7:00	C.D.	1.73		283
12	7:00	C.D.	1.30		294
13	7:00	C.D.	1.54		276
14	7:00	C.D.	2.35		295
15	7:00	C.D.	1.99	3.5	301
16	6:00	C.D.	2.59		300

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	5:45	C.D.	2.73		303
18	7:30	C.D.	2.49		304
19	8:00	R.F.	3.72		315
20	7:00	R.F.	3.54		276
21	7:00	R.F.	3.32		292
22	8:00	R.F.	2.95	4.1	275
23	9:30	R.F.	3.21		298
24	9:30	C.D.	2.83		256
25	8:00	R.F.	2.97		273
26	8:00	R.F.	3.05		281
27	8:30	R.F.	2.22		308
28	8:30	R.F.	3.31		272
29	8:30	R.F.	3.14	4.3	297
30	9:30	R.F.	2.90		312
31	10:30	R.F.	3.25		330
Total Monthly Consumption					9,402

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)
1	8:30	R.F.	0.04
15	7:00	C.D.	0.00

Date	Time	Initials	Ammonia (mg/L)
22	8:00	R.F.	0.01
29	8:30	R.F.	0.04

Date	Time	Initials	Ammonia (mg/L)

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
5	9:15	R.F.	Main Street	0.41	0.02	0.4
19	9:00	R.F.	Main Street	2.31	2.0	0.22

Submitted by (Print): Rob Friesen Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: KLIEFELD Water System Code: 104.0

Month: August Year: 2025

Operator-in-charge (Print): Rob Friesen Other Operators (Print): Cliff Berkson

Unit: mJ/cm<sup>2</sup> Barry Brosky

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	8:30	R.F.	61.81	-
2	7:00	B.B.	63.02	-
3	7:30	B.B.	62.23	-
4	7:15	B.B.	63.81	-
5	8:00	R.F.	69.92	-
6	8:00	R.F.	62.23	-
7	8:30	R.F.	62.22	-
8	8:30	R.F.	62.22	-
9	9:30	R.F.	62.23	-
10	6:30	R.F.	62.22	-
11	7:00	C.D.	62.23	-
12	7:00	C.D.	62.23	-
13	7:00	C.D.	62.23	-
14	7:00	C.D.	62.23	-
15	7:00	C.D.	62.23	-
16	6:00	C.D.	62.88	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	5:45	C.D.	62.88	-
18	7:30	C.D.	62.88	-
19	8:00	R.F.	62.08	-
20	7:00	R.F.	62.08	-
21	7:00	R.F.	62.08	-
22	8:00	R.F.	62.08	-
23	9:30	R.F.	61.84	-
24	9:30	C.D.	61.84	-
25	8:00	R.F.	61.84	-
26	8:00	R.F.	61.84	-
27	8:30	R.F.	61.84	-
28	9:30	R.F.	61.84	-
29	8:30	R.F.	61.84	-
30	9:30	R.F.	61.02	-
31	10:30	R.F.	61.02	-

Date	UVT readings and Alarm or Warning History and actions taken to resolve
1	UVT TEST: 83.3
8	UVT TEST: 81.8
15	UVT TEST: 84.7
22	UVT TEST: 82.1
29	UVT TEST: 82.0

Submitted by (Print): Rob Friesen Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS.  
PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

**Water System Name:** RM of Hanover - Kleefeld Water Treatment Plant

**Water System Code:** 104.0

**Design Minimum UVT** 70%

**Minimum Dose Required** 40 mj/cm2

**Month:** August **Year:** 2025

**Operator-in-charge (Print):** Barry Broesky

**Other Operators (Print):** Rob Friesen

Cliff Derksen

**Flow Units:** Imperial Gallons, U.S. Gallons, Cubic Meters

UV Unit No.1								
Date	Time	Alarm or Warning	UV mj/cm2 Minimum	UV mj/cm2 Average	UV mj/cm2 Measured	Unit Flow M3	Bypass Flow M3	% Disinfected
2025-07-31	0:00:00	0	0.00	62.05		106.5		
2025-08-01	0:00:00	0	0.00	62.42		65.6		
2025-08-01	0:00:00	0	0.00	62.42		65.6		
2025-08-01	0:00:00	0	0.00	62.51		102.4		
2025-08-01	0:00:00	0	0.00	62.51		102.4		
2025-08-01	0:00:00	0	0.00	62.52		80.7		
2025-08-01	0:00:00	0	0.00	62.52		80.7		
2025-08-02	0:00:00	0	0.00	62.95		48.8		
2025-08-02	0:00:00	0	0.00	62.38		281.6		
2025-08-02	0:00:00	0	0.00	63.59		55.1		
2025-08-03	0:00:00	0	0.00	63.13		95.9		
2025-08-03	0:00:00	0	0.00	62.64		227.8		
2025-08-04	0:00:00	0	0.00	62.96		13.2		
2025-08-04	0:00:00	0	0.00	62.96		13.2		
2025-08-04	0:00:00	0	0.00	62.50		31.8		
2025-08-04	0:00:00	0	0.00	63.53		518.6		
2025-08-05	0:00:00	0	0.00	62.88		18.7		
2025-08-05	0:00:00	0	0.00	62.67		24.0		
2025-08-05	0:00:00	0	0.00	31.68		183.8		
2025-08-06	0:00:00	0	0.00	62.83		30.2		
2025-08-06	0:00:00	0	0.00	62.57		93.1		
2025-08-07	0:00:00	0	0.00	62.45		27.9		
2025-08-07	0:00:00	0	0.00	62.49		37.3		
2025-08-07	0:00:00	0	0.00	62.41		223.1		
2025-08-08	0:00:00	0	0.00	62.77		23.6		
2025-08-08	0:00:00	0	0.00	62.99		6.0		
2025-08-08	0:00:00	0	0.00	62.36		40.0		
2025-08-08	0:00:00	0	0.00	62.33		57.4		
2025-08-09	0:00:00	0	0.00	62.94		15.5		
2025-08-09	0:00:00	0	0.00	62.33		107.9		
2025-08-09	0:00:00	0	0.00	62.53		101.7		
2025-08-10	0:00:00	0	0.00	62.68		16.4		
2025-08-10	0:00:00	0	0.00	40.24		1419.3		
2025-08-12	0:00:00	0	0.00	62.33		81.5		
2025-08-12	0:00:00	0	171.98	171.98		0.2		
2025-08-12	0:00:00	0	0.00	61.60		202.4		

2025-08-12	0:00:00	0	0.00	61.71	50.6		
2025-08-13	0:00:00	0	0.00	62.09	9.0		
2025-08-13	0:00:00	0	0.00	62.39	4.8		
2025-08-13	0:00:00	0	0.00	61.65	24.3		
2025-08-13	15:10:55	0	0.00	61.93	37.9		
2025-08-13	0:00:00	0	0.00	61.54	50.5		
2025-08-14	0:00:00	0	0.00	61.82	9.9		
2025-08-14	6:48:45	0	0.00	62.40	7.6		
2025-08-14	0:00:00	0	0.00	61.97	21.1		
2025-08-14	0:00:00	0	0.00	61.64	2.0		
2025-08-14	0:00:00	0	0.00	61.64	140.1		
2025-08-14	0:00:00	0	0.00	62.37	20.9		
2025-08-15	0:00:00	0	0.00	63.25	34.3		
2025-08-15	0:00:00	0	0.00	63.03	179.8		
2025-08-15	0:00:00	0	0.00	63.23	51.7		
2025-08-16	0:00:00	0	0.00	63.38	26.9		
2025-08-16	11:08:40	0	0.00	62.94	63.9		
2025-08-16	0:00:00	0	0.00	63.02	95.2		
2025-08-17	0:00:00	0	0.00	63.29	18.4		
2025-08-17	0:00:00	0	0.00	62.96	26.8		
2025-08-17	0:00:00	0	0.00	62.25	14.0		
2025-08-17	0:00:00	0	0.00	62.25	14.0		
2025-08-18	0:00:00	0	0.00	62.81	9.6		
2025-08-18	0:00:00	0	0.00	62.14	23.7		
2025-08-18	0:00:00	0	0.00	62.14	23.8		
2025-08-18	0:00:00	0	0.00	62.46	1363.8		
2025-08-19	6:53:30	0	0.00	62.67	241.8		
2025-08-19	0:00:00	0	0.00	63.18	55.8		
2025-08-19	0:00:00	0	0.00	63.35	26.7		
2025-08-20	4:40:55	0	0.00	63.90	7.3		
2025-08-21	0:00:00	0	0.00	62.73	40.3		
2025-08-21	0:00:00	0	0.00	63.09	54.8		
2025-08-21	0:00:00	0	0.00	62.94	34.7		
2025-08-22	0:00:00	0	0.00	62.20	38.3		
2025-08-22	0:00:00	0	0.00	62.40	43.1		
2025-08-22	0:00:00	0	60.49	61.68	66.7		
2025-08-23	0:00:00	0	0.00	61.88	41.8		
2025-08-23	0:00:00	0	0.00	27.61	347.3		
2025-08-25	14:44:16	0	0.00	61.73	196.6		
2025-08-26	0:00:00	0	0.00	61.97	15.5		
2025-08-26	0:00:00	0	0.00	61.67	24.5		
2025-08-26	0:00:00	0	0.00	61.50	728.3		
2025-08-27	0:00:00	0	0.00	61.97	14.7		
2025-08-27	0:00:00	0	0.00	62.06	19.7		
2025-08-27	0:00:00	0	0.00	62.17	13.4		
2025-08-27	0:00:00	0	0.00	61.89	83.9		
2025-08-28	0:00:00	0	0.00	61.94	8.5		
2025-08-28	0:00:00	0	0.00	43.98	86.3		
2025-08-28	7:26:45	0	0.00	31.19	240.6		
2025-08-29	0:00:00	0	0.00	61.96	43.1		
2025-08-29	0:00:00	0	0.00	61.54	78.1		
2025-08-30	0:00:00	0	0.00	62.10	17.2		



# Monthly Chloramination Report

Water System Name: KLEEFELD Water System Code: 104.0

Month: SEPTEMBER Year: 2025 Type of Measurement Device: ELECTRONIC

Operator-in-charge (Print): BARRY BROECKY Other Operators (Print): ROB FRIESEN

Daily Consumption Units: m<sup>3</sup> CLIFF PERKIN

Flow Meter for Daily Consumption: (circle choice) Raw  Treated  No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	7:00	R.F.	3.40		225
2	7:00	C.D.	1.95		342
3	7:00	C.D.	2.44		264
4	7:00	C.D.	1.98		262
5	7:00	C.D.	2.63	3.8	278
6	6:00	C.D.	2.64		250
7	7:30	C.D.	2.57		296
8	6:30	B.B.	2.95		296
9	7:00	B.B.	3.02		292
10	7:00	B.B.	3.08		284
11	7:15	B.B.	3.36		543
12	7:30	B.B.	2.00	3.7	586
13	6:15	B.B.	3.28		245
14	8:00	B.B.	3.17		296
15	7:30	C.D.	3.34		293
16	7:00	R.F.	3.38		281

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	7:00	R.F.	3.18		275
18	7:00	R.F.	2.97		264
19	7:00	R.F.	3.05	4.3	265
20	8:00	R.F.	2.95		284
21	11:00	R.F.	3.06		329
22	7:00	C.D.	2.46		235
23	7:00	C.D.	3.09		289
24	7:00	C.D.	2.82		260
25	7:00	C.D.	2.92		262
26	7:00	C.D.	2.68	4.1	277
27	6:00	C.D.	2.77		266
28	6:45	C.D.	2.73		291
29	7:00	B.B.	3.12		306
30	6:00	B.B.	3.14		269
31					
Total Monthly Consumption					8905

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)
5	7:00	C.D.	0.02	19	7:00	R.F.	0.00				
12	7:30	B.B.	0.04	26	7:00	C.D.	0.00				

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
2	10:30	C.D.	Main Street	2.47	3.50	0.00
16	11:00	C.D.	Main street	2.04	4.30	0.00

Submitted by (Print): BARRY BROECKY Signature: [Signature]

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: KLEEFEL Water System Code: 104.0

Month: SEPTEMBER Year: 2025

Operator-in-charge (Print): BARRY BROESKY Other Operators (Print): ROB FRIESEN

Unit: mJ/cm<sup>2</sup> CLIFF DEKLEN

Date	Time	Operator Initials	UV Dose mJ/cm2	Number of Alarms (A) or Warnings (W)
1	7:00	R.F.	61.02	-
2	7:00	C.D.	61.75	-
3	7:00	C.D.	61.81	-
4	7:00	C.D.	61.81	-
5	7:00	C.D.	61.81	✓
6	6:00	C.D.	61.55	-
7	7:30	C.D.	60.75	-
8	6:45	B.B.	60.75	-
9	7:00	B.B.	60.75	-
10	7:00	B.B.	60.75	-
11	7:30	B.B.	60.75	-
12	7:45	B.B.	60.75	-
13	6:30	B.B.	61.10	-
14	8:00	B.B.	61.10	-
15	7:30	C.D.	61.10	-
16	7:00	R.F.	61.10	-

Date	Time	Operator Initials	UV Dose mJ/cm2	Number of Alarms (A) or Warnings (W)
17	7:00	R.F.	60.54	-
18	7:00	R.F.	60.54	-
19	7:00	R.F.	60.54	-
20	8:00	R.F.	62.19	-
21	11:00	R.F.	61.79	-
22	7:30	C.D.	61.39	-
23	7:00	C.D.	60.83	✓
24	7:00	C.D.	60.83	-
25	7:00	C.D.	60.83	-
26	7:00	C.D.	60.83	-
27	6:00	C.D.	60.22	✓
28	6:45	C.D.	60.22	-
29	7:15	B.B.	60.22	-
30	6:15	B.B.	60.22	-
31				

Date	UVT readings and Alarm or Warning History and actions taken to resolve
5	80.5 UVT
12	UVT TEST: 82.3
19	UVT TEST: 83.2
26	UVT TEST: 80.7

Submitted by (Print): BARRY BROESKY Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.







# Monthly Chloramination Report

Water System Name: KLEEFELD Water System Code: 104.0

Month: October Year: 2025 Type of Measurement Device: ELECTRONIC

Operator-in-charge (Print): Rob Friesen Other Operators (Print): Cliff Decker

Daily Consumption Units: m<sup>3</sup> Barry Braesky

Flow Meter for Daily Consumption: (circle choice) Raw   Treated No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	7:00	B.B.	3.07		342
2	7:00	B.B.	3.10		274
3	7:15	B.B.	3.17	4.1	289
4	6:15	B.B.	3.16		272
5	6:45	B.B.	3.11		303
6	7:30	C.D.	2.22		312
7	7:45	C.D.	2.63		311
8	7:45	C.D.	2.74		301
9	7:15	C.D.	2.90		642
10	7:00	R.F.	3.32	4.7	547
11	9:00	R.F.	3.33		306
12	11:00	R.F.	2.94		323
13	9:00	R.F.	2.62		229
14	6:45	C.D.	2.40		292
15	7:00	C.D.	2.78		267
16	7:00	C.D.	2.61		264

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	7:00	C.D.	3.09	3.4	263
18	6:00	C.D.	2.66		247
19	7:00	C.D.	2.60		295
20	7:00	B.B.	2.78		298
21	7:00	B.B.	2.55		282
22	7:00	B.B.	2.98		255
23	7:15	B.B.	2.79		272
24	7:00	B.B.	2.92	3.6	263
25	5:30	C.D.	2.38		254
26	6:30	C.D.	2.66		304
27	7:30	R.F.	3.05		312
28	7:00	R.F.	2.88		258
29	7:00	R.F.	2.70		277
30	7:00	R.F.	1.98		260
31	7:00	R.F.	2.61	3.3	273
<b>Total Monthly Consumption</b>					<b>9414</b>

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)
3	7:15	B.B.	0.00
10	7:00	R.F.	0.00


Date	Time	Initials	Ammonia (mg/L)
17	7:00	C.D.	0.01
24	7:00	B.B.	0.00

Date	Time	Initials	Ammonia (mg/L)
31	7:00	R.F.	

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
1	10:00	B.B.	Main St.	3.23	3.4	0.00
14	9:00	C.D.	Main St.	2.80	4.1	0.00
28	8:30	R.F.	Main St.	2.34	4.7	0.00

Submitted by (Print): Rob Friesen

Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: KLEEFELD Water System Code: 104.0

Month: October Year: 2025

Operator-in-charge (Print): Rob Frisen Other Operators (Print): Cliff Darksen

Unit: mJ/cm<sup>2</sup> Barry Brossky

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	7:15	B.B.	58.64	-
2	7:00	B.B.	61.01	-
3	7:30	B.B.	60.22	-
4	6:30	B.B.	58.64	-
5	6:45	B.B.	60.22	-
6	7:30	C.D.	60.70	-
7	7:45	C.D.	60.44	-
8	7:45	C.D.	61.51	-
9	7:15	C.D.	61.26	-
10	7:00	R.F.	62.65	-
11	9:00	R.F.	60.33	-
12	11:00	R.F.	60.33	-
13	9:00	R.F.	60.33	-
14	6:45	C.D.	60.33	-
15	7:00	C.D.	60.33	-
16	7:00	C.D.	60.33	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	7:00	C.D.	60.33	-
18	6:00	C.D.	60.80	-
19	7:00	C.D.	60.80	-
20	7:15	B.B.	60.80	-
21	7:15	B.B.	60.80	-
22	7:15	B.B.	60.80	-
23	7:30	B.B.	60.00	-
24	7:15	B.B.	60.80	-
25	5:30	C.D.	60.21	-
26	6:30	C.D.	60.21	-
27	7:30	R.F.	60.21	-
28	7:00	R.F.	60.21	-
29	7:00	R.F.	60.21	-
30	7:00	R.F.	59.42	-
31	7:00	R.F.	58.63	-

Date	UVT readings and Alarm or Warning History and actions taken to resolve
3	UVT TEST: 84.7
10	UVT TEST: 81.4
17	UVT TEST: 83.1
24	UVT TEST: 80.6
31	UVT TEST: 82.6

Submitted by (Print): Rob Frisen Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.







# Monthly Chloramination Report

Water System Name: Kleeefeld Water System Code: 104.0

Month: November Year: 2025 Type of Measurement Device: Electronic

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Cliff Derksen

Daily Consumption Units: m<sup>3</sup>

Flow Meter for Daily Consumption: (circle choice) Raw Treated No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	9:30	R.F.	2.35		282
2	11:30	R.F.	2.48		327
3	7:00	C.D.	2.25		234
4	7:45	C.D.	2.90		278
5	7:45	C.D.	2.86		268
6	7:45	C.D.	2.75		272
7	7:00	B.B.	3.09	3.7	251
8	6:30	B.B.	2.81		248
9	6:00	B.B.	2.70		259
10	6:45	B.B.	2.80		271
11	6:15	B.B.	2.85		243
12	6:45	B.B.	2.73		281
13	6:45	B.B.	2.62		247
14	6:45	B.B.	2.68	3.4	241
15	6:30	B.B.	2.80		238
16	9:45	B.B.	2.70		310

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	7:00	R.F.	2.82		226
18	8:00	R.F.	2.88		278
19	7:00	R.F.	2.25		240
20	8:00	R.F.	3.07		281
21	7:00	R.F.	2.05	2.6	253
22	6:00	C.D.	2.32		235
23	6:00	C.D.	1.84		284
24	7:15	B.B.	2.66		294
25	7:15	B.B.	2.74		260
26	7:15	B.B.	2.91		257
27	6:30	B.B.	2.42		242
28	7:15	B.B.	2.84	3.2	290
29	6:30	B.B.	2.87		253
30	10:15	B.B.	2.88		331
31					
Total Monthly Consumption					7969

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)
7	7:00	B.B.	0.00	21	7:00	R.F.	0.00				
14	6:45	B.B.	0.00	28	7:15	B.B.	0.00				

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
11	9:45	B.B.	Main St.	2.91	3.7	0.00
25	10:15	B.B.	Main St.	2.90	3.7	0.00

Submitted by (Print): BARRY BROESKY Signature: [Signature]

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: Kleeefeld Water System Code: 104.0

Month: November Year: 2025


Operator-in-charge (Print): Barry Broesky Other Operators (Print): Cliff Derksen

Unit: mJ/cm<sup>2</sup>

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	9:30	R.F.	58.63	-
2	11:30	R.F.	58.63	-
3	7:00	C.D.	58.63	-
4	7:45	C.D.	58.63	-
5	7:45	C.D.	58.63	-
6	7:45	C.D.	58.63	-
7	7:15	B.B.	60.21	-
8	6:30	B.B.	60.96	-
9	6:00	B.B.	60.17	-
10	7:00	B.B.	58.59	-
11	6:30	B.B.	58.59	-
12	7:00	B.B.	58.59	-
13	7:00	B.B.	60.17	-
14	7:00	B.B.	60.17	-
15	6:45	B.B.	60.21	-
16	9:45	B.B.	58.63	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	7:00	R.F.	58.63	-
18	8:00	R.F.	58.63	-
19	7:00	R.F.	58.63	-
20	8:00	R.F.	58.63	-
21	7:00	B.B.	58.63	-
22	06:00	C.D.	60.25	-
23	6:00	C.D.	60.25	-
24	7:30	B.B.	60.25	-
25	7:30	B.B.	60.25	-
26	7:30	B.B.	60.25	-
27	6:45	B.B.	60.25	-
28	7:30	B.B.	58.66	-
29	6:30	B.B.	62.57	-
30	<del>6:30</del> 10:15	B.B.	60.24	-
31				

Date	UVT readings and Alarm or Warning History and actions taken to resolve
7	UVT TEST: 80.1
14	UVT TEST: 80.6
21	UVT TEST: 80.9
28	UVT TEST: 80.8

Submitted by (Print): BARRY BROESKY Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

Water System Name: RM of Hanover - Kleefeld Water Treatment Plant

Water System Code: 104.0

Design Minimum UVT 70%

Minimum Dose Required 40 mj/cm2

Month: November Year: 2025

Operator-in-charge (Print): Barry Broesky

Other Operators (Print): Cliff Derksen

Flow Units: Imperial Gallons, U.S. Gallons, Cubic Meters

UV Unit No.1								
Date	Time	Alarm or Warning	UV mj/cm2 Minimum	UV mj/cm2 Average	UV mj/cm2 Measured	Unit Flow M3	Bypass Flow M3	% Disinfected
2025-11-03	0:00:00							
2025-11-06	0:00:00	0						
2025-11-06	0:00:00	0						
2025-11-07	0:00:00	0						
2025-11-07	0:00:00	0						
2025-11-07	0:00:00	0						
2025-11-08	0:00:00	0						
2025-11-08	0:00:00	0						
2025-11-08	0:00:00	0						
2025-11-09	0:00:00	0						
2025-11-09	0:00:00	0						
2025-11-09	0:00:00	0						
2025-11-10	0:00:00	0						
2025-11-10	0:00:00	0						
2025-11-10	0:00:00	0						
2025-11-11	0:00:00	0						
2025-11-11	0:00:00	0						
2025-11-11	0:00:00	0						
2025-11-12	0:00:00	0	0.00	59.07		40.6		
2025-11-12	0:00:00	0	0.00	58.83		46.4		
2025-11-12	0:00:00	0	56.97	58.88		54.6		
2025-11-13	0:00:00	0	58.06	59.79		23.3		
2025-11-13	0:00:00	0	0.00	58.84		34.2		
2025-11-13	0:00:00	0	58.06	58.98		64.2		
2025-11-14	0:00:00	0	0.00	59.29		33.2		
2025-11-14	0:00:00	0	0.00	58.88		51.2		
2025-11-14	0:00:00	0	0.00	59.14		46.1		
2025-11-15	0:00:00	0	0.00	59.61		9.6		
2025-11-15	0:00:00	0	0.00	58.79		93.8		
2025-11-15	0:00:00	0	58.10	58.89		70.7		
2025-11-16	0:00:00	0	0.00	58.74		83.8		
2025-11-16	0:00:00	0	0.00	58.78		81.8		
2025-11-16	0:00:00	0	0.00	59.29		20.2		
2025-11-17	0:00:00	0	0.00	58.68		49.1		
2025-11-17	0:00:00	0	0.00	58.88		126.5		
2025-11-18	0:00:00	0	0.00	58.88		78.8		





# Monthly Chloramination Report

Water System Name: KLEEFELD Water System Code: 104.0

Month: December Year: 2025 Type of Measurement Device: Electronic

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Cliff Derksen

Daily Consumption Units: m<sup>3</sup>

Flow Meter for Daily Consumption: (circle choice) Raw  Treated No Metering

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
1	7:30	C.D.	3.06		250
2	7:30	C.D.	2.90		276
3	7:30	C.D.	3.04		268
4	7:30	C.D.	3.08		298
5	7:30	C.D.	2.80	3.8	280
6	7:30	C.D.	2.71		248
7	6:30	C.D.	2.91		253
8	7:15	B.B.	2.60		299
9	7:00	B.B.	2.95		298
10	7:00	B.B.	2.89		297
11	6:30	B.B.	2.99		272
12	7:00	B.B.	3.05	4.1	275
13	6:30	B.B.	3.04		240
14	10:00	B.B.	2.90		329
15	7:30	C.D.	2.90		251
16	7:45	C.D.	2.49		274

Date	Time	Initials	Residuals (mg/L)		Daily Consumption
			Mono	Total	
17	7:30	C.D.	2.40		262
18	7:45	C.D.	2.52		274
19	7:30	C.D.	2.81	3.8	297
20	6:00	C.D.	2.67		251
21	6:45	C.D.	2.84		294
22	7:00	C.D.	3.20		297
23	6:30	C.D.	3.05		255
24	5:30	C.D.	3.02		275
25	7:00	C.D.	2.98		290
26	9:00	C.D.	3.01	4.3	274
27	7:30	C.D.	2.96		249
28	6:30	C.D.	2.92		271
29	6:45	C.D.	2.94		268
30	6:45	C.D.	2.56		261
31	6:45	C.D.	2.79		265

Total Monthly Consumption 134,393,000

### Ammonia in Treated Water

Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)	Date	Time	Initials	Ammonia (mg/L)
5	7:30	C.D.	0.00	19	7:30	C.D.	0.00				
12	7:00	B.B.	0.00	26	9:00	C.D.	0.00				

### Residuals at Distribution Sample Locations

Date	Time	Initials	Location	Residuals (mg/L)		
				Mono	Total	Ammonia
9	10:45	B.B.	MAIN ST.	2.98	3.9	0.00
22	9:30	C.D.	MAIN ST.	3.12	4.1	0.00

Submitted by (Print): Cliff Derksen Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS. PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

# Monthly Ultraviolet (UV) Report

Water System Name: Kleeefeld Water System Code: 104.0

Month: December Year: 2025

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Cliff Derksen

Unit: mJ/cm<sup>2</sup>

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
1	7:30	C.D.	60.24	-
2	7:30	C.D.	60.24	-
3	7:30	C.D.	60.24	-
4	7:30	C.D.	60.24	-
5	7:30	C.D.	60.24	-
6	7:30	C.D.	61.06	-
7	6:30	C.D.	61.06	-
8	7:30	B.B.	58.69	-
9	7:15	B.B.	60.28	-
10	7:00	B.B.	60.28	-
11	6:30	B.B.	61.06	-
12	7:15	B.B.	60.28	-
13	6:45	B.B.	60.91	-
14	10:00	B.B.	60.91	-
15	7:30	C.D.	60.31	-
16	7:45	C.D.	60.31	-

Date	Time	Operator Initials	UV Dose mJ/cm <sup>2</sup>	Number of Alarms (A) or Warnings (W)
17	7:30	C.D.	60.31	-
18	7:45	C.D.	60.31	-
19	7:30	C.D.	60.31	-
20	6:00	C.D.	60.22	-
21	6:45	C.D.	60.22	-
22	9:00	C.D.	61.34	-
23	6:30	C.D.	60.22	-
24	5:30	C.D.	60.22	-
25	7:00	C.D.	60.22	-
26	9:00	C.D.	60.22	-
27	7:30	C.D.	60.16	-
28	6:30	C.D.	60.16	-
29	8:45	C.D.	60.16	-
30	6:45	C.D.	60.16	-
31	6:45	C.D.	60.16	-

Date	UVT readings and Alarm or Warning History and actions taken to resolve
5	UVT TEST: 81.1
12	UVT TEST: 81.3
19	UVT TEST: 80.7
26	UVT TEST: 79.7

Submitted by (Print): Cliff Derksen Signature: 

PLEASE REFER TO OPERATING LICENCE FOR APPLICABLE TREATMENT STANDARDS AND MONITORING REQUIREMENTS.  
PLEASE CONTACT YOUR DRINKING WATER OFFICER WITH ANY COMMENTS, QUESTIONS OR CONCERNS.

Monthly Ultraviolet (UV) Report



Water System Name: RM of Hanover - Kleefeld Water Treatment Plant

Water System Code: 104.0

Design Minimum UVT 70%

Minimum Dose Required 40 mj/cm2

Month: December Year: 2025

Operator-in-charge (Print): Barry Broesky Other Operators (Print): Cliff Derksen

Flow Units: Imperial Gallons, U.S. Gallons, Cubic Meters

UV Unit No.1								
Date	Time	Alarm or Warning	UV mj/cm2 Minimum	UV mj/cm2 Average	UV mj/cm2 Measured	Unit Flow M3	Bypass Flow M3	% Disinfected
2025-12-01	0:00:00	0	0.00	60.09		51.2		
2025-12-01	0:00:00	0	0.00	60.39		90.5		
2025-12-01	0:00:00	0	0.00	60.47		52.0		
2025-12-02	0:00:00							
2025-12-02	0:00:00							
2025-12-03	0:00:00	0	60.24	60.24		1.1		
2025-12-03	0:00:00	0						
2025-12-04	0:00:00	0						
2025-12-04	0:00:00	0						
2025-12-04	0:00:00	0						
2025-12-05	0:00:00							
2025-12-05	0:00:00							
2025-12-06	0:00:00							
2025-12-06	0:00:00							
2025-12-07	0:00:00							
2025-12-07	0:00:00							
2025-12-07	0:00:00							
2025-12-08	0:00:00	0						
2025-12-08	0:00:00	0						
2025-12-08	0:00:00	0						
2025-12-09	0:00:00	0						
2025-12-09	0:00:00	0						
2025-12-09	0:00:00	0	0.00	60.04		93.7		
2025-12-10	0:00:00	0	58.69	60.20		77.6		
2025-12-10	0:00:00	0	0.00	59.94		196.1		
2025-12-11	0:00:00	0	0.00	59.61		42.2		
2025-12-11	0:00:00	0	0.00	59.90		40.8		
2025-12-11	0:00:00	0	0.00	59.90		94.0		
2025-12-12	0:00:00	0	0.00	60.51		32.3		
2025-12-12	0:00:00	0	0.00	60.44		56.9		
2025-12-12	0:00:00	0	0.00	60.68		45.6		
2025-12-13	0:00:00	0	60.31	61.31		7.4		
2025-12-13	0:00:00	0	58.72	60.49		98.6		
2025-12-13	0:00:00	0	0.00	60.45		68.9		
2025-12-14	0:00:00	0	59.52	60.64		74.1		

2025-12-14	0:00:00	0	60.31	60.73	68.5
2025-12-14	0:00:00	0	0.00	60.68	43.6
2025-12-15	0:00:00				
2025-12-15	0:00:00				
2025-12-16	7:50:28				
2025-12-16	0:00:00				
2025-12-16	0:00:00				
2025-12-17	7:19:30				
2025-12-17	0:00:00				
2025-12-18	0:00:00				
2025-12-18	0:00:00				
2025-12-18	0:00:00				
2025-12-18	0:00:00				
2025-12-19	0:00:00				
2025-12-19	0:00:00				
2025-12-19	0:00:00				
2025-12-20	5:54:58				
2025-12-20	0:00:00				
2025-12-20	0:00:00				
2025-12-21	0:00:00				
2025-12-21	0:00:00				
2025-12-21	0:00:00				
2025-12-22	0:00:00				
2025-12-22	0:00:00				
2025-12-22	0:00:00				
2025-12-23	0:00:00				
2025-12-23	11:49:28				
2025-12-23	0:00:00				
2025-12-24	0:00:00				
2025-12-24	10:47:43				
2025-12-24	0:00:00				
2025-12-25	0:00:00				
2025-12-25	0:00:00				
2025-12-25	0:00:00				
2025-12-26	0:00:00				
2025-12-26	0:00:00				
2025-12-27	0:00:00				
2025-12-27	0:00:00				
2025-12-27	11:03:13				
2025-12-27	0:00:00				
2025-12-28	0:00:00				
2025-12-28	0:00:00				
2025-12-28	0:00:00				
2025-12-29	0:00:00				
2025-12-29	0:00:00				
2025-12-29	0:00:00				
2025-12-30	0:00:00				
2025-12-30	0:00:00				
2025-12-30	18:30:30				
2025-12-31	0:00:00				
2025-12-31	0:00:00				
2025-12-31	0:00:00				



# Appendix F

## **INCIDENT ADVISORY NOTIFICATION PLAN**



## Kleefeld Advisory Notification Plan

February 18, 2026

The Kleefeld Water system has one water treatment plant which provides water for the town of Kleefeld, MB.

If there is a water quality issue with the system, please contact our Water and Wastewater Treatment Operators, Cliff Derksen at 204-392-8285, or Mike Berg at 204-381-2124. Our Utilities Manager, Barry Broesky, can also be contacted at 204-371-0484, along with the Regional Drinking Water Officer (DWO) Wajed Shah at 204-408-8807 or 204-346-6346. A voice conversation must be had with a Drinking Water Officer. If you cannot reach anyone at those numbers, call the emergency line at 1-855-944-4888. Using the attached Emergency action chart, the DWO, Operators and Manager will determine the appropriate actions to take to rectify the situation.

Customers in the affected area(s) will be notified by the municipalities Facebook page and website, as well as the electronic community billboards. Critical customers will be notified by phone and paper notice, and in isolated incidents localized canvassing may also be carried out.

28 Westland Drive, Mitchell, Manitoba R5G 2N9 P:204.326.4488 F:204.326.4830 E:general@hanovermb.ca www.hanovermb.ca

28 Westland Drive, Mitchell, Manitoba, R5G 2N9  
Phone (204) 326-4488 Fax (204) 326-4830  
e-mail: [general@hanovermb.ca](mailto:general@hanovermb.ca) website: [www.hanovermb.ca](http://www.hanovermb.ca)

